



**MAIN FLOOR - LIGHTING & SYSTEMS PLAN**

SCALE: 1:50

**DRAWING NOTES**

- ① COORDINATE LUMINAIRE CONNECTIONS WITH MECHANICAL PIPING AND DUCTWORK. WHERE REQUIRED SUSPEND LUMINAIRES BELOW SUCH EQUIPMENT.
- ② 3/C#12 TECK TO PANEL HEAA IN HEADWORKS BUILDING ELECTRICAL ROOM.
- ③ 2/C#12 TECK TO PANEL TAA IN ELECTRICAL ROOM.

**GENERAL NOTES**

- 1. COORDINATE WITH OTHER TRADES TO PREVENT CONFLICTS.
- 2. USE PVC JACKETED HITECK CABLE FOR ALL POWER WIRING.
- 3. WIRING FOR LIGHTING, RECEPTACLES AND COMMUNICATIONS TO IN RGD ALUMINUM CONDUIT.
- 4. ALL CONDUIT TO BE 21mm $\phi$  MINIMUM UNLESS OTHERWISE NOTED.



NO.	REVISIONS	DATE	BY	DATE	BY
02	ISSUED FOR CONSTRUCTION	06/09/22	SRP		
01	21-2006 ADDENDUM 6	06/07/05	SRP		
00	ISSUED FOR TENDER	06/04/26	ERC		

**EarthTech**  
A Tyco International Ltd. Company

DESIGNED BY: GSN	CHECKED BY: PS
DRAWN BY: ERC	APPROVED BY: JEH
HOR. SCALE: NTS	RELEASED FOR CONSTRUCTION BY: J. VEILLEUX
DATE: 2005/11/22	DATE: 2006/04/26

ENGINEER'S SEAL  
ORIGINAL SIGNED BY  
**P. STRYK**  
2006/04/26  
CONSULTANT DRAWING NO.  
TE1.01

**THE CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
ENGINEERING DIVISION

**WEWPC**  
BIOLOGICAL NUTRIENT REMOVAL UPGRADE  
CONTRACT 3

ELECTRICAL  
AREA T - DAF THICKENER BUILDING  
MAIN FLOOR LIGHTING AND SYSTEMS PLAN

CITY FILE NUMBER  
SHEET OF  
CITY DRAWING NUMBER