



A AREA U – TUNNEL VENTILATION – SITE PLAN
SCALE 1:500

GENERAL NOTES

1. PERFORM ALL WORK IN ACCORDANCE WITH ALL APPLICABLE CODES, STANDARDS AND PROVINCIAL MECHANICAL ENGINEERING & INSPECTIONS BRANCH REQUIREMENTS.
2. COORDINATE WORKS WITH OTHER SUB-TRADES. REFER TO SPECIFIC DETAILS FOR CUTTING AND SEALING PENETRATIONS THROUGH OPENINGS & FIRE SEPARATIONS.
3. REFER TO TECHNICAL SPECIFICATIONS FOR EQUIPMENT AND MATERIAL SPECIFICATIONS AND INSTALLATION CONSTRUCTION AND PHASING REQUIREMENTS.
4. INSULATE DUCTWORK WHERE INDICATED AND SPECIFIED.
5. SUPPORT ALL DUCTWORK TO MEET CODE REQUIREMENTS & ESTABLISHED INDUSTRY TRADE PRACTICES, (SMACNA, ASHRAE).
6. INVESTIGATE SITE PRIOR TO CONSTRUCTION TO CONFIRM ALL DIMENSIONS AND INSTALLATION REQ'S.
7. PERFORM ALL CUTTING & PATCHING NECESSARY FOR ANY REQUIRED OPENINGS.
8. PROVIDE TAB TO ENSURE AIR DISTRIBUTION TO VOLUMES INDICATED.
9. NOT ALL EQUIPMENT/PIPING, ETC. IS SHOWN.

APEGM
Certificate of Authorization
Alliance Engineering Services Inc.
No.2906 Date: _____

| | |
|----------------------|----------------|
| B.M. ELEV. | FIELD BOOK #: |
| POSTED TO LBIS | |
| | |
| | |
| | |
| 00 ISSUED FOR TENDER | 2010-12-21 AFG |
| NO. REVISIONS | DATE BY |

ALLIANCE
Engineering Services Inc.

| | |
|------------------|---------------------------|
| DESIGNED BY JC | CHECKED BY AFG |
| DRAWN BY JC | APPROVED BY |
| HOR. SCALE 1:500 | RELEASED FOR CONSTRUCTION |
| VERTICAL 1:500 | |
| DATE 2010-02-23 | DATE |

ENGINEER'S SEAL

 CONSULTANT DRAWING NO.
UM1.1

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

2010 HVAC REPLACEMENT
AND ASSOCIATED WORKS
WEWPCC
AREA U – TUNNEL VENTILATION
SITE PLAN

SHEET 1 of 1
CITY DRAWING NUMBER
1-0103V-M0001-001