

THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT

\ SECONDARY CLARIFIER 3

2010HVAC REPLACEMENT AND ASSOCIATED WORKS WEWPCC

AREA U — UTILITY BUILDING

UTILITY BUILDING ROOF — EXISTING CONDITIONS ISOMETRIC

APPROVED

RELEASED FOR CONSTRUCTION

CONSULTANT DRAWING NO.

UM5.7

AS

2010-06-23 DATE

HOR. SCALE NTS

VERTICAL

2010-12-21 AFG

DATE BY DATE

00 ISSUED FOR TENDER

NO. REVISIONS

CITY DRAWING NUMBER 1-0103V-M0040-001

SHEET 1 OF 1

AND PHASING REQUIREMENTS. INSULATE DUCTWORK WHERE INDICATED AND SPECIFIED.

PERFORM ALL CUTTING & PATCHING NECESSARY FOR ANY REQUIRED OPENINGS.

PROVIDE TAB TO ENSURE AIR DISTRIBUTION TO VOLUMES INDICATED.

- SUPPORT ALL DUCTWORK TO MEET CODE REQUIREMENTS & ESTABLISHED INDUSTRY TRADE PRACTICES, (SMACNA, ASHRAE). INVESTIGATE SITE PRIOR TO CONSTRUCTION TO CONFIRM ALL DIMENSIONS AND INSTALLATION REQ'S.
- 9. NOT ALL EQUIPMENT/PIPING, ETC. IS SHOWN.