



NOTES:

- PULL FOUR (4) CAT6 CABLES IN 1" CONDUIT FROM PLC PANEL TO BAILEY CONTROL PANEL. FINAL TERMINATIONS WITHIN BAILEY DCS PANEL SHALL BE SUPERVISED BY CITY OF WINNIPEG INSTRUMENTATION STAFF.

LEGEND:

- RJ45 CONNECTOR
- ST CONNECTOR
- LC CONNECTOR
- SC CONNECTOR
- TERMINAL STRIP
- 62.5/125 MULTIMODE
- CAT6 ETHERNET

NOTE 1

REFER TO DWG: 1-0103V-P0005-001

 Certificate of Authorization KGS Group No. 245 Date: 2010/12/21		B.M. ELEV. . POSTED TO LBIS	FIELD BOOK #: 00 ISSUED FOR TENDER 2010-12-21 01 REVISIONS DATE BY	 DESIGNED BY DDW CHECKED BY REW DRAWN BY MMP APPROVED BY REW HDR. SCALE N.T.S. VERTICAL N.T.S. 2009 09 29	ENGINEER'S SEAL TENDER No. SE29 FILENAME: 1-0103S-P0021-001.dwg PLOT DATE: 2010/12/29	 2009 HVAC REPLACEMENT AND ASSOCIATED WORKS WEWPC AREA S - SECONDARY CLARIFIERS 1 & 2 NETWORK SYSTEM ARCHITECTURE	SHEET 1 OF 1 CITY DRAWING NUMBER 1-0103S-P0021-001
---	--	--------------------------------	--	---	--	---	--