



NO.	CONSTRUCTION NOTES
1	INSTALL NEW 40A CUTLER HAMMER HFD BREAKERS IN CDP-E1 AS SHOWN.

**NOTES:**

- SUPERSEDES PART OF DWG. SEP-823
- ALL CONDUIT IS RIGID ALUMINUM UNLESS OTHERWISE NOTED.



NO.	REVISIONS	DATE	DESIGN	CHECK
01	ADDED BREAKERS FOR UPS-M1 AND UPS-G1	2011/03/11	TMC	CJR
00	ISSUED FOR TENDER, BID OPP 837-2009	2009/12/07	-	NB

		SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-786-8080	
DESIGNED BY:	EXISTING	CHECKED BY:	N. BRADDOO
DRAWN BY:	S. JUGANAS	APPROVED BY:	C. REIMER
SCALE:	NTS	RELEASED FOR CONSTRUCTION BY:	J. VEILLEUX
DATE:	2009/12/07	DATE:	2009/12/02
CONSULTANT NO.:		112577-0105-47DD-0202	

ENGINEER'S SEAL  
 ORIGINAL DRAWING  
 SEALED BY:  
 T. M. CHURCH  
 SNC-LAVALIN  
 MEMBER # 32682  
 2011/03/25  
 REV. 01  
 CHANGES ONLY

THE CITY OF WINNIPEG  
 WATER AND WASTE DEPARTMENT  
 SOUTH END WATER POLLUTION CONTROL CENTRE  
 ESSENTIAL SYSTEM UPGRADES  
 SINGLE LINE DIAGRAM  
 SERVICE BUILDING

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1-0102B-E0007	001	01	A1

DRAWING NUMBER	REFERENCE DRAWINGS
----------------	--------------------