



ADMINISTRATION BUILDING ELECTRICAL ROOM
1:30

PHASE	NO.	CONSTRUCTION NOTES
1	①	INSTALL TEMPORARY FEEDER CABLE FROM XFMR-2X TO PNL-2X.
2	②	REMOVE EXISTING UPS TRANSFORMER AND ASSOCIATED WIRING.
	③	CONNECT GROUND FROM MTS-M1 TO GROUND CONDUCTOR IN CEILING SPACE.

NOTES:

1. THIS DRAWING IS BASED ON THE EXISTING LAYOUT OF THE ELECTRICAL ROOM.



NO.	REVISIONS	DATE	DESIGN	CHECK
01	REMOVED UPS TRANSFORMER XFMR-2X	2011/03/11	TMC	CJR
00	ISSUED FOR TENDER, BID OPP 837-2009	2010/12/07	-	NB

SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-786-8080	
DESIGNED BY: EXISTING	CHECKED BY: N. BRADDOO
DRAWN BY: E. BOHNCKE	APPROVED BY: C. REIMER
SCALE: 1:30	RELEASED FOR CONSTRUCTION BY: J. VEILLEUX
DATE: 2009/12/07	DATE: 2009/12/02
CONSULTANT NO.: 112577-0105-47DD-0100	

ENGINEER'S SEAL
ORIGINAL DRAWING
SEALED BY:
T. M. CHURCH
SNC-LAVALIN
MEMBER #32682
2011/03/25
REV. 01
CHANGES ONLY

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT
 SOUTH END WATER POLLUTION CONTROL CENTRE
 ELECTRICAL INSPECTION & UPGRADES
 PLAN LAYOUT
 ADMINISTRATION BUILDING ELECTRICAL ROOM
 CITY DRAWING NUMBER: **1-0102M-E0006**

SHEET	REV.	SIZE
001	01	A1

DRAWING NUMBER	REFERENCE DRAWINGS
----------------	--------------------