

PART 1 GENERAL

1.1 SUMMARY

- .1 Section Includes:
 - .1 Materials and requirements for the identification of piping systems, plumbing systems, duct work, valves and controllers, including the installation and location of identification systems.

1.2 RELATED SECTIONS

- .1 Section 22 11 16 Domestic Water Piping
- .2 Section 22 13 18 - Drainage Waste & Vent - Plastic
- .3 Section 23 05 05 - Installation of Pipework
- .4 Section 23 73 11 - Air Handling Units - Packaged

1.3 REFERENCES

- .1 Canadian Gas Association (CGA)
 - .1 CSA/CGA B149.1, Natural Gas and Propane Installation Code.
- .2 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-1.60, Interior Alkyd Gloss Enamel.
 - .2 CAN/CGSB-24.3, Identification of Piping Systems.
- .3 National Fire Protection Association (NFPA)
 - .1 NFPA 13, Standard for the Installation of Sprinkler Systems.
 - .2 NFPA 14, Standard for the Installation of Standpipe and Hose Systems.

1.4 SUBMITTALS

- .1 Product Data:
 - .2 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
 - .3 Product data to include paint colour chips, other products specified in this section.
 - .4 Samples:
 - .1 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.
-

-
- .2 Samples to include nameplates, labels, tags, lists of proposed legends.

1.5 QUALITY ASSURANCE

- .1 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Contractor's COR Safety Program and requirements of authority-having-jurisdiction.

1.6 DELIVERY, STORAGE, AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Waste Management and Disposal:
 - .1 Dispose of unused paint and coating material at official hazardous material collections site approved by Authorities having Jurisdiction.
 - .2 Do not dispose of unused paint and coating material into sewer system, into streams, lakes, onto ground or in locations where it will pose health or environmental hazard.

PART 2 PRODUCTS

2.1 MANUFACTURER'S EQUIPMENT NAMEPLATES

- .1 Metal or plastic laminate nameplate mechanically fastened to each piece of equipment by manufacturer.
- .2 Lettering and numbers raised or recessed.
- .3 Information to include, as appropriate:
 - .1 Equipment: manufacturer's name, model, size, serial number, capacity.
 - .2 Motor: voltage, Hz, phase, power factor, duty, frame size.

2.2 SYSTEM NAMEPLATES

- .1 Colours:
 - .1 Hazardous: red letters, white background.
 - .2 Elsewhere: black letters, white background (except where required otherwise by applicable codes).
 - .2 Construction:
-

.1 3 mm thick white anodized aluminum, matte finish, with square corners, letters accurately aligned and machine engraved into core.

.3 Sizes:

.1 Conform to following table:

Size #	mm	Sizes (mm)	No. of Lines	Height of Letters (mm)
1	10 x 50	1	3	
2	13 x 75	1	5	
3	13 x 75	2	3	
4	20 x 100	1	8	
5	20 x 100	2	5	
6	20 x 200	1	8	
7	25 x 125	1	12	
8	25 x 125	2	8	
9	35 x 200	1	20	

.2 Use maximum of 25 letters/numbers per line.

.3 Locations:

.4 Terminal cabinets, control panels: use size # 5.

.5 Equipment in Mechanical Rooms: use size # 9.

.6 New Fans, AHUs, VAVs, etc: use size # 9.

2.3 EXISTING IDENTIFICATION SYSTEMS

.1 Apply existing identification system to new work.

.2 Where existing identification system does not cover for new work, use identification system specified this section.

.3 Before starting work, obtain written approval of identification system from Contract Administrator.

2.4 PIPING SYSTEMS GOVERNED BY CODES

.1 Identification:

.1 Natural gas: to CSA/CGA B149.1.

2.5 IDENTIFICATION OF PIPING SYSTEMS

.1 Identify contents by background colour marking, pictogram (as necessary), legend; direction of flow by arrows. To CAN/CGSB 24.3 except where specified otherwise.

.2 Pictograms:

.1 Where required: Workplace Hazardous Materials Information System (WHMIS) regulations.

.3 Legend:

- .1 Block capitals to sizes and colours listed in CAN/CGSB 24.3.
- .4 Arrows showing direction of flow:
 - .1 Outside diameter of pipe or insulation less than 75 mm: 100 mm long x 50 mm high.
 - .2 Outside diameter of pipe or insulation 75 mm and greater: 150 mm long x 50 mm high.
 - .3 Use double-headed arrows where flow is reversible.
- .5 Extent of background colour marking:
 - .1 To full circumference of pipe or insulation.
 - .2 Length to accommodate pictogram, full length of legend and arrows.
- .6 Materials for background colour marking, legend, arrows:
 - .1 Pipes and tubing 20 mm and smaller: waterproof and heat-resistant pressure sensitive plastic marker tags.
 - .2 Other pipes: pressure sensitive vinyl with protective overcoating, waterproof contact adhesive undercoating, suitable for ambient of 100% RH and continuous operating temperature of 150 degrees C and intermittent temperature of 200 degrees C.
- .7 Colours and Legends:
 - .1 Where not listed, obtain direction from Contract Administrator.
 - .2 Colours for legends, arrows: to following table:

<u>Background colour: Legend, arrows:</u>	
Yellow	BLACK
Green	WHITE
Red	WHITE
 - .3 Background colour marking and legends for piping systems:

Contents	Background colour	Legend marking
City water	Green	CITY WATER (POTABLE)
Treated water	Dark Green	SECONDARY EFFLUENT WATER
Hot water heating supply	Yellow	HEATING SUPPLY
Hot water heating return	Yellow	HEATING RETURN
High temp HW Htg. supply	Yellow	HTHW HTG. SUPPLY++
High temp HW Htg. return	Yellow	HTHW HTG. RETURN++
Make-up water	Yellow	MAKE-UP WTR
Chilled drinking water	Green	CH. DRINK WTR
Domestic hot water supply	Green	DOM. HW SUPPLY
Dom. HWS recirculation	Green	DOM. HW CIRC
Domestic cold water supply	Green	DOM. CWS
Waste water	Green	WASTE WATER
Storm water	Green	STORM
Sanitary	Green	SAN

Plumbing vent	Green	SAN. VENT
Refrigeration suction	Yellow	REF. SUCTION
Refrigeration liquid	Yellow	REF. LIQUID
Refrigeration hot gas	Yellow	REF. HOT GAS
Natural gas	to Codes	
Gas regulator vents	to Codes	
Distilled water	Green	DISTILL. WTR
Compressed air (<700kPa)	Green	COMP. AIR
Instrument air	Green	INSTRUMENT AIR

2.6 IDENTIFICATION DUCTWORK SYSTEMS

- .1 50 mm high stencilled letters and directional arrows 150 mm long x 50 mm high.
- .2 Colours: back, or co-ordinated with base colour to ensure strong contrast.

2.7 VALVES, CONTROLLERS

- .1 Brass tags with 12 mm stamped identification data filled with black paint.
- .2 Include flow diagrams for each system, of approved size, showing charts and schedules with identification of each tagged item, valve type, service, function, normal position, location of tagged item.

2.8 CONTROLS COMPONENTS IDENTIFICATION

- .1 Identify all systems, equipment, components, controls, sensors with system nameplates specified in this section.
- .2 Inscriptions to include function and (where appropriate) fail-safe position.

2.9 LANGUAGE

- .1 Identification in English.

PART 3 EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 TIMING

- .1 Provide identification only after painting has been completed.
-

3.3 INSTALLATION

- .1 Perform work in accordance with CAN/CGSB-24.3 except as specified otherwise.
- .2 Provide ULC or CSA registration plates as required by respective agency.

3.4 NAMEPLATES

- .1 Locations:
 - .1 In conspicuous location to facilitate easy reading and identification from operating floor.
- .2 Standoffs:
 - .1 Provide for nameplates on hot and/or insulated surfaces.
- .3 Protection:
 - .1 Do not paint, insulate or cover.

3.5 LOCATION OF IDENTIFICATION ON PIPING AND DUCTWORK SYSTEMS

- .1 On long straight runs in open areas in boiler rooms, equipment rooms, galleries, tunnels: at not more than 17 m intervals and more frequently if required to ensure that at least one is visible from any one viewpoint in operating areas and walking aisles.
 - .2 Adjacent to each change in direction.
 - .3 At least once in each small room through which piping or ductwork passes.
 - .4 On both sides of visual obstruction or where run is difficult to follow.
 - .5 On both sides of separations such as walls, floors, partitions.
 - .6 Where system is installed in pipe chases, ceiling spaces, galleries, confined spaces, at entry and exit points, and at access openings.
 - .7 At beginning and end points of each run and at each piece of equipment in run.
 - .8 At point immediately upstream of major manually operated or automatically controlled valves, and dampers. Where this is not possible, place identification as close as possible, preferably on upstream side.
 - .9 Identification easily and accurately readable from usual operating areas and from access points.
-

- .1 Position of identification approximately at right angles to most convenient line of sight, considering operating positions, lighting conditions, risk of physical damage or injury and reduced visibility over time due to dust and dirt.

3.6 VALVES, CONTROLLERS

- .1 Valves and operating controllers, except at plumbing fixtures, radiation, or where in plain sight of equipment they serve: Secure tags with non-ferrous chains or closed "S" hooks.
- .2 Install one copy of flow diagrams, valve schedules mounted in frame behind non-glare glass where directed by Contract Administrator. Provide one copy (reduced in size if required) in each operating and maintenance manual.
- .3 Number valves in each system consecutively.

3.7 CLEANING

- .1 Proceed in accordance with Section 01 74 00 - Cleaning and Waste Management.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION
