

DRY-CHEMICAL FIRE-EXTINGUISHING EQUIPMENT

1. GENERAL

1.1 Summary

- .1 Section includes
 - .1 Fire extinguishers.

1.2 References

- .1 American National Standards Institute/National Fire Protection Association (ANSI/NFPA)
 - .1 ANSI/NFPA 10-2010, Standard for Portable Fire Extinguishers.

1.3 Submittals

- .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit Material Safety Data Sheets for each chemical used in the fire extinguishers in accordance with Section 01 33 00 - Submittal Procedures.

2. PRODUCTS

2.1 Portable Hand Fire Extinguishers

- .1 Multi-Purpose Dry Chemical: Pressurised with hose and shut-off nozzle or integral shut-off nozzle and wall mounting brackets 4.5 kg capacity rating 4A:60BC.

3. EXECUTION

3.1 Installation

- .1 Install extinguishers so that the bottom of extinguisher is 900 mm above floor.
- .2 All fire extinguishers shall be conspicuously and clearly marked using arrows and signs.

END OF SECTION