

THE GENERAL CONTRACTOR SHALL VERIFY ALL DIMENSIONS, DATUMS, AND LEVELS PRIOR TO COMMENCEMENT OF WORK. ALL ERRORS AND OMISSIONS TO BE REPORTED TO NUMBER TEN ARCHITECTURAL GROUP BEFORE PROCEEDING.

VARIATIONS AND MODIFICATIONS TO WORK SHOWN ON THESE DRAWINGS SHALL NOT BE CARRIED OUT WITHOUT WRITTEN PERMISSION OF NUMBER TEN ARCHITECTURAL GROUP.

THIS DRAWING MUST NOT BE SCALED.

REVISED/ ISSUED/ PLOTTED

Rev. 0 - ISSUED FOR TENDER

THIS DRAWING IS THE EXCLUSIVE PROPERTY OF NUMBER TEN ARCHITECTURAL GROUP AND THE COPYRIGHT IN THE SAME BEING RESERVED TO THEM. IT MAY BE REPRODUCED ONLY WITH THE PERMISSION OF NUMBER TEN ARCHITECTURAL GROUP, IN WHICH CASE THE REPRODUCTION

Rev. 1 - ISSUED FOR TENDER FEBRUARY 03/2012

NOVEMBER 21/2011

NOTES:

- 1. REFER TO PANEL SCHEDULE FOR ADDITIONAL LOADS.
- 2. ELECTRICAL SERVICE IS PRIMARY METERED. PROVIDE UTILITY GRADE METERING SECTION CT, PT AND METER FOR CUSTOMER USE.
- 3. CONTRACTOR TO ARRANGE AND COORDINATE AN ARC FLASH STUDY AND PROVIDE ARC FLASH HAZARD LABELS FOR ALL APPLICABLE ELECTRICAL EQUIPMENT IN THE BUILDING.
- 4. CABLES ARE TO BE DIRECT BURIED AS PER DIAGRAM B4-1, DETAIL 1 AND RATED AS PER TABLE D9B IN THE CANADIAN ELECTRICAL CODE
- 5. CONTRACTOR IS TO COORDINATE WITH MANITOBA HYDRO AND PROVIDE SERVICE FROM THE MANITOBA HYDRO PADMOUNT TRANSFORMER.

numberTEN architectural group

winnipeg MB regina SK victoria BC 204 942.0981 306 721.1501 250 360.2106

architecture = interior design = graphic design

PEGUIS PAVILION UPGRADES AND ENTRY ADDITION BIDDING #913-2011

SINGLE LINE DIAGRAM AND LEGEND

KGS GROUP CONSULTING ENGINEERS

consultant



project no. 2011026

No. 245

PAWLIKEWICH Member 23235

drawn by: GCN checked by: