



FIRE DAMPER SCHEDULE

TAG	DUCT SIZE (MM)	ORIENTATION	STATUS
B103-FD-01	150 x 150	VERTICAL	EXISTING
B103-FD-02	250 x 200	VERTICAL	EXISTING
B103-FD-03	300 x 350	VERTICAL	EXISTING
B103-FD-04	150 x 150	VERTICAL	NEW
B103-FD-05	250 x 200	VERTICAL	NEW
B103-FD-06	300 x 350	VERTICAL	NEW
B103-FD-07	406 x 350	VERTICAL	NEW, TYPE A

GENERAL NOTES:

- CONTRACTOR SHALL SUPPLY AND INSTALL FIRE DAMPERS IN LOCATIONS SHOWN ON DRAWINGS WHERE DUCTING PENETRATES A FIRE SEPARATION. CONTRACTOR IS TO VERIFY DIMENSIONS PRIOR TO ORDERING FIRE DAMPERS.
- FIRE DAMPERS SHALL BE INSTALLED IN ACCORDANCE WITH SMACNA STANDARDS, NATIONAL FIRE CODE AND THE NATIONAL BUILDING CODE.
- REFER TO DRAWING 1-0102G-M0007 FOR FIRE DAMPER INSTALLATION DETAILS.
- ACCESS DOORS SHALL BE PROVIDED FOR ALL FIRE DAMPERS IN ACCORDANCE WITH SMACNA AND THE NATIONAL FIRE CODE.
- INSPECT EXISTING FIRE DAMPERS AND NOTIFY THE CONTRACT ADMINISTRATOR OF ANY DAMAGED OR DEFICIENT ITEMS.



NO.	REVISIONS	DATE	DESIGN	CHECK
02	REVISED TABLE	2013/04/22	TRS	SN
01	ISSUED FOR TENDER, BID OPP. 42-2013	2013/03/25	TRS	SN
00	ISSUED FOR TENDER, BID OPP. 545-2012	2012/09/10	TRS	SN

SNC-LAVALIN INC.
148 Nature Park Way
Winnipeg, MB, Canada R3P 0X7
204-786-8080

DESIGNED BY: S. NORSWORTHY
DRAWN BY: K. MOHAMMED
SCALE: 1 : 50
DATE: 2012/10/10
CONSULTANT NO.: 112577-0116-450D-0203

CHECKED BY: S. NORSWORTHY
APPROVED BY: C. REIMER
RELEASED FOR CONSTRUCTION BY: NEIL HARRINGTON
DATE: 2012/10/10

ENGINEER'S SEAL
ORIGINAL DRAWING SEALED BY:
S. S. NORSWORTHY
SNC-LAVALIN
MEMBER #20725
2012/10/11
REV. 00

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTRE
VENTILATION & MISC. UPGRADES
PLAN VIEW
FIRE DAMPER UPGRADES
BOILER ROOM

CITY DRAWING NUMBER: 1-0102B-M0003
SHEET: 001
REV.: 02
SIZE: A1