



1 TYP. WATER COLUMN DETAIL
WS-M0202 1:20

NOTE:
1. WATER LEVEL SHOULD BE 100mm BELOW THE INVERT OF THE INVERT OF THE 180° BEND.

NOTE:
1. SLOPE FILL LINES TO TANKS.
2. SEE DRAWINGS WS-M0451 AND WS-M0452 FOR TANK DETAILS AND NOZZLE SCHEDULE.

AECOM
As of January 3, 2009, EarthTech became AECOM Canada Ltd.

AECOM AS-CONSTRUCTED
SIG. _____ DATE _____

 Certificate of Authorization AECOM Canada Ltd. Original dated on: No. 4671 Date: 2007/01/31	B.M. ELEV.	 Frederickson Cooper ARCHITECTS DESIGNED BY SBW DRAWN BY JBC SCALE: 1:50 DATE 2006/03/15	 CHECKED BY SRB APPROVED BY AHL RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI DATE 2007/01/31	ENGINEER'S SEAL	 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION WATER TREATMENT PLANT BULK CHEMICAL BUILDING SODIUM HYPOCHLORITE AND CHEMICAL STORAGE BUILDING PROCESS MECHANICAL SECTION SHEET 2 OF 6	CITY FILE NUMBER
				ORIGINAL SIGNED BY		CITY DRAWING NUMBER
				S.B. WILLIAMSON		1-0601S-M0045-002-02
				2007/01/31		
	CONSULTANT DRAWING NO. WS-M0202					