



## REQUEST FOR PROPOSAL No. 1100-2014 ADDENDUM No. 1

REQUEST FOR PROPOSAL FOR PROFESSIONAL CONSULTING  
SERVICES FOR THE PROVISION OF PRELIMINARY DESIGN SERVICES  
FOR THE OLIVE WASTEWATER PUMPING STATION UPGRADES

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
REQUEST FOR PROPOSAL**

ISSUED: November 25, 2014  
BY: D. Berg, C.E.T.  
TELEPHONE NO. (204) 986-4452

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE REQUEST FOR PROPOSAL AND  
SHALL FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: Ar20131129

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.**

---

### **PART D – SUPPLEMENTAL CONDITIONS**

Add: D3.2 (b) Some of the historical record drawings in Appendix A reference the name “Ainslie” Station, which is the same as the Olive Station today.

Revise: D4.1.3 (d) (ii) to read: Provide design recommendation for replacement of two (2) existing wastewater sewage pumps and pump motors in the “dry-pit” section of the Station with three (3) new pumping units (pumps, motors, driveshafts).

- The new pump motors shall be sized at a minimum in accordance with the following:
  - 30 HP
  - 575 Volt, 3 Phase, 60 Cycle
- The new pumps shall be sized at a minimum capacity in accordance with the following:
  - **154 L/sec (2441 USGPM)**