

SUPPLY AND DELIVERY OF UV DISINFECTION LAMPS AND BALLASTS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: March 20, 2014
BY: Ken Stelmack
TELEPHONE NO. (204) 986-2293

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is **4:00 p.m.** Winnipeg time, **March 26, 2014**

PART D – SUPPLEMENTAL CONDITIONS

Revise D17.1.1 to read: Should the lamp fail within the first **six thousand (6,000)** hours of operation, the Contractor shall provide the City of Winnipeg with a replacement lamp free of charge.

Revise D17.1.2 to read: Should the lamp fail after **six thousand (6,000)** hours and prior to twelve thousand (12,000) hours of operation, the Contractor shall provide the City of Winnipeg with a replacement lamp at a pro-rated price. The following formula is used to determine the pro-rated price for lamps:

NOTE: Replacement Lamp Price = (Lamp Operating Hours) / 12000 x Lamp Original Purchase Price)

Revise D10.4.1 to read: Further to D10, offloading of the supplied items means the delivery company to move the product, which is generally delivered on pallets, to the back of the truck. The City has a forklift at both facilities that is used to pick up the pallet and handle it from there.

PART E – SPECIFICATIONS

Revise: E2.2 to read: Item No. 1 - lamp assembly shall be compatible with a Trojan UV 4000 system (Trojan part # **441169-024**).

Revise: E2.3 to read: Item No. 2 – electronic ballast shall be compatible with a Trojan UV 4000 & Trojan UV 4000 plus systems (Trojan part # **490291-A**).

Revise: E2.4 to read: Item No. 3 – electronic ballast shall be compatible with a Trojan UV 4000 & Trojan UV 4000 plus systems (Trojan part # **490291**).

Revise: E2.6to read: Item No. 5 - lamp assembly shall be compatible with a Trojan UV 4000 plus system (Trojan part # **441169-028**).