



GENERAL NOTES:

1. DESIGN IS IN ACCORDANCE WITH THE NATIONAL BUILDING CODE OF CANADA, 2005 EDITION PLUS 1998 MANITOBA AMENDMENTS. CONCRETE WALLS ARE DESIGNED IN ACCORDANCE WITH THE RECOMMENDATIONS CONTAINED IN ACI 35OR FOR WATERTIGHT STRUCTURES.

CAST IN PLACE CONCRETE:

- 1. TO BE READ IN CONJUNCTION WITH CW 2160 AND AS AMENDED IN ACCORDANCE WITH THESE NOTES.
- 2. CONCRETE MIX WAS IN ACCORDANCE WITH ALTERNATIVE 1, AND POSSESSED THE FOLLOWING PROPERTIES:

a. CLASS OF EXPOSURE: b. MINIMUM COMPRESSIVE STRENGTH AT 28 DAYS: 35MPa


c. MAXIMUM SLUMP: 80mm ± 20mm d. AIR CONTENT: 5 - 8% e. MAXIMUM WATER/CEMENT RATIO: 0.40

CONCRETE COVER = 50mm.

ALL EXTERIOR CORNERS CHAMFERED 20mm.

REINFORCING STEEL:

- 1. TO BE READ IN CONJUNCTION WITH CW 2160 AND AS AMENDED IN ACCORDANCE WITH THESE NOTES.
- 2. ALL REINFORCING STEEL CONFORMS TO CSA G30.18M, GRADE 400W.
- 3. ALL CONCRETE REINFORCING WORK PERFORMED IN ACCORDANCE WITH CSA A23.1.
- 4. LAPS AT LEAST 40 BAR DIAMETERS, REINFORCING SPLICES NOT INDICATED IN THE DRAWINGS LOCATED AT POINTS OF MINIMUM STRESS.
- 5. BEFORE PLACING CONCRETE, REINFORCING WAS CLEAN, FREE OF LOOSE SCALE, DIRT OR OTHER FOREIGN MATTER THAT WOULD REDUCE OR PREVENT BOND TO THE CONCRETE.



METRIC WHOLE NUMBERS INDICATE MILLIMETRES DECIMALIZED NUMBERS INDICATE METRES

Certificate of Authorization

MMM Group Limited

No. 4531

BID NO.

742-2014

STAIR - SECTION B-B

MANITOR	Wir
er er	NORT

S1.2

THE CITY OF WINNIPEG PUBLIC WORKS DEPARTMENT ENGINEERING SERVICES DIVISION

CITY OF WINNIPEG

BERTHA & JOHN HIRSCH STAIR & RAMP

TH EAST EXCHANGE DISTRICT ENGINEERING STUDY

These design documents are prepared solely for the use by the party with whom the design professional has entered into a contract and there are no representations of any kind made by the design professional to any party with whom the design professional has not entered into a contract.

LOCATIONS APPROVED MMM Group Limited. Suite 111 - 93 Lombard Ave. UNDERGROUND STRUCTURES Winnipeg, MB R3B 3B1 t. 204.943.3178 **MMM GROUP** f. 204.943.4948 www.mmm.ca SUPV U/G STRUCTURES CHECKED LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION APPROVED WC AVAILABLE BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT CONFIRMATION OF EXISTANCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES AS NOTED RELEASED FOR CONSULTANT ACAD DWG. NO. CONSTRUCTION AS NOTED BEFORE PROCEEDING A ISSUED FOR TENDER 07/08/14 MS NO. REVISIONS DATE BY DATE JUL 29/14 DATE

S1.2