



## 778-2015 ADDENDUM 01

### SUPPLY AND DELIVERY OF MANUAL ISOLATION VALVES AND FLOW CONTROL VALVES

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY**

ISSUED: September 15, 2015  
BY: Jason Smith  
TELEPHONE NO. 204 896-1209

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20150806

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART E – SPECIFICATIONS**

- Revise: E3.1 (a) to read: Resilient seated eccentric plug valve, 100% full port, non-lubricated, quarter turn, with cast iron body with Class 125 flanged ends, 316 SS bearings, welded-in nickel seat, ductile iron plug. Valve body shall have exterior epoxy coating.
- Revise: E3.1 (e) to read: Acceptable Products: Dezurik, Valmatic, Milliken or approved equivalent in accordance with B6
- Revise: E3.2 (e) to read: Acceptable Products: Dezurik BAW, Mueller Lineseal or approved equivalent in accordance with B6