



8-2015 ADDENDUM 1

2015 LOCAL STREETS PACKAGE – BERRY STREET AND SCURFIELD BOULEVARD

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: March 16, 2015
BY: Ron Bruce
TELEPHONE NO. (204) 977-8370

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20150105

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Add: E5.1.6 The Contractor shall make a written request to the Contract Administrator at least seven (7) Working Days prior to his intention to switch the direction of traffic at either location. Co-ordination with City of Winnipeg Traffic Signals, Traffic Services as well as Winnipeg Transit will be required. The Contractor shall schedule these events to occur on a weekend (between Friday at 18:00 and Monday at 07:00).
- Add: **E16** **Natural Gas Mains**
- E16.1 The Contractor shall follow all requirements listed in Appendix 'C' when working around natural gas mains and services.
- E16.2 A 219.1 mm distribution pressure natural gas main runs along Berry Street. A Manitoba Hydro High Pressure Safety Watch may be required where excavations are within 1.0 m of the gas main.
- E16.3 Prior to excavation expose the main by hydro-excavation every 25 m and at CB locations in order to confirm elevation of the pipe.
- E16.4 No measurement or payment will be made for the works listed in this Specification.

APPENDICES

- Add: Appendix "C" – Manitoba Hydro (Gas) Requirements