



822-2015 ADDENDUM 1

COMMUNOTOR CHAMBER PIPING AND VALVE UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 30, 2015
BY: Newton Conti, P.Eng.
TELEPHONE NO. 204 986-3179

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E18.10.2 to read: For pipe interior, use either:

- a) concrete lined pipe approved for wastewater use; or
- b) paint using Devco Devgrip 238 abrasion resistant coating or equal in accordance with B7.