



930-2015 ADDENDUM 5

WILKES RESERVOIR NORTH CELL REHABILITATION

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: December 23, 2015
BY: Sital Rihal, M.Eng., P.Eng.
TELEPHONE NO. (204) 453-2301

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E14.8.2(a)(ii) to read: Thermal performance – minimum of **five (5) year Warranty**.

Revise: E14.8.2(a)(iii) to read: Structural performance – minimum of **five (5) year Warranty**.

Add: E22.8.2 to read: Fabricate Work in strict accordance with the Shop Drawings. Shop Drawings are to be based on details, sizes, and materials shown on the Drawings and specified herein.

Add: E22.8.3 to read: All welding shall conform to the requirements of the current AWS D1.6 Structural Welding Code – Stainless Steel and the fabricator shall be fully approved by the Canadian Welding Bureau or American Welding Society, in conformance with the requirements of the current CSA Standard W47 or AWS equivalent. Welding shall be done by currently licensed welders only.

Add: E22.8.4 to read: Manufacturer shall be a member of the Canadian Welding Bureau or American Welding Society.

Add: E22.8.5 to read: All exposed portions of the Work shall be neatly finished. Exposed ends and edges of metal, welding splatter, and other fabrication burrs where exposed shall be ground or filed smooth.

NMS SPECIFICATIONS

Section 07 53 23 Ethylene Propylene Diene Monomer (EPDM) Roofing

Replace: Form W1: Manufacturer's Warranty Agreement with 930-2015_Addendum_5-Form_W1(R1): Manufacturer's Warranty Agreement

Replace: Form W2: Applicator's Warranty Agreement with 930-2015_Addendum_5-Form_W2(R1): Applicator's Warranty Agreement