

ION APPROVED ROUND STRUCTURES	B.M. ELEV.				CHECKED	DRA		ENGINEER'S SEAL	Q	THE CITY OF WINNIPEG	
	CONSTRUCTION COMPLETION DATE:				BY APPROVED BY	SSR			Winnipeg	WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	
						FAK	DILLON			ES RESERVOIR NORTH CELL REHABILITATION BEARING PLATE MARK P-5	
					DRAWN BY	TLK	CONSULTING RELEASED FOR CONSTRUCTION		SECTIONS AND DETAILS		
					SCALE: HORIZONTAL			CONSULTANT DRAWING NUMBER	SHEET OF	CONSTRUCTION PROCEDURES	
	1 ISSUED FO	R TENDER REVISIONS	2015 11 20 DATE	SSR	VERTICAL DATE		DATE	14-1411-S-124	32 47	1-0650R-S0022-001	
	NO.		DAIE		PLOT DATE:	2015 11 18		BID OPPORTUNITY: 930-2015 CONTRACT NUMBER:	FILE PATH: P:\20154593\00_K FILE NAME: 1-0650R-S0022-00	emp_Wilkes\Working_Dwgs\300_Structural\ D1.dwg	

BEARING PLATE MARK P-5 INSTALLATION AND ASSEMBLY - CONSTRUCTION PROCEDURE NOTES:

1. CLEAN EXPOSED BEAM ENDS, SIDES, AND BOTTOMS BY SANDBLASTING TO REMOVE OLD COATINGS AND SURFACE CONTAMINANTS EXPOSING THE FINE AGGREGATE.

2. JACK EXISTING BEAM SIMULTANEOUSLY 75 mm ABOVE COLUMN TOP. NO TWO ADJACENT DOUBLE COLUMNS ON THE SAME BEAM LINE SHALL BE JACKED AND SUSPENDED AT THE SAME TIME. JACKING FRAMES SAFE CAPACITY TO BE 50 TONNES (490 kN) PER PAIR OF BEAMS ON THE NORTH AND SOUTH SIDES OF THE SUPPORTING COLUMNS AND DESIGNED TO TRANSFER LOADS TO THE FOUNDATION PILING.

3. JACKING FRAME SHALL BE DESIGNED BY A STRUCTURAL PROFESSIONAL ENGINEER REGISTERED IN THE PROVINCE OF MANITOBA.

4. SEALED DESIGN DRAWINGS AND CALCULATIONS SHALL BE SUBMITTED TO THE CONTRACT ADMINISTRATOR FOR REVIEW PRIOR TO COMMENCING OF THE WORK IN ACCORDANCE WITH THE SPECIFICATIONS.

5. REMOVE EXISTING BEARING PADS AND WIRE BRUSH CLEAN THE TOP OF THE COLUMN AND UNDERSIDE OF THE BEAM AT THE BEARING AREA. INSTALL NEW BEARING PADS AND BEARING PLATES AS SHOWN ON THE DRAWINGS AND IN ACCORDANCE WITH THE SPECIFICATIONS.

6. SPREAD TOP OF THE NEW BEARING PLATE WITH SPECIFIED EPOXY GEL AND SIMULTANEOUSLY LOWER THE BEAMS ON TO THE NEW BEARINGS.

7. REPAIR EXISTING BEAM SPALLS AS DETAILED, REFER TO SHEET 13 FOR LOCATIONS AND REPAIR PROCEDURES. PROTECT BEARINGS AND BEARING PADS FROM ANY SPILLS OR DAMAGE DURING THIS OPERATION.

8. SHOULD NEW BEAM SPALLS DEVELOP DURING THIS OPERATION, INFORM THE CONTRACT ADMINISTRATOR IMMEDIATELY AND REPAIR IN ACCORDANCE WITH THE SPECIFICATIONS.