

HAULED WASTEWATER BUILDING NO. 1
(FORMERLY HAULED WASTEWATER BUILDING)

HAULED WASTEWATER BUILDING NO. 2
(FORMERLY LEACHATE RECEIVING BUILDING)

WHOLE NUMBERS INDICATE MILLIMETRES

DECIMALIZED NUMBERS INDICATE METRES

NOTES:


1. ALL PROPOSED FLUSHING WATER PIPING SHALL BE SCH 10S STAINLESS STEEL UNLESS OTHERWISE INDICATED

2. INSTALL PIPING TO AVOID CONFLICTS WITH EX. INFRASTRUCTURE. CONFIRM PROPOSED LAYOUT WITH CONTRACT ADMINISTRATOR PRIOR TO COMMENCING WORK.

Certificate of Authorization
Stantec Consulting Ltd.
No. 1301

4

LOCATION APPROVED Stantec UNDERGROUND STRUCTURES 500-311 Portage Ave, Winnipeg MB Canada SUPV. U/G STRUCTURES www.stantec.com DATE COMMITTÉE DESIGNED CHECKED R.G. S.A.B. LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION DRAWN APPROVED K.R. S.K.B. AVAILABLE BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR ISSUED FOR TENDER 16.03.09 S.K.B. THAT THE GIVEN LOCATIONS ARE EXACT. RELEASED FOR AS NOTED CONFIRMATION OF EXISTENCE AND EXACT HOR. SCALE: ISSUED FOR TENDER REVIEW 16.03.07 S.K.B. CONSTRUCTION: LOCATION OF ALL SERVICES MUST BE VERTICAL: TENDER NO. OBTAINED FROM THE INDIVIDUAL UTILITIES ISSUED FOR 95% REVIEW 16.01.29 S.K.B. BEFORE PROCEEDING WITH CONSTRUCTION. NO. REVISIONS DATE BY DATE 2016.01.05 DATE PLOT DATE: 2016 03 08



Winnipeg

THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT

NORTH END SEWAGE TREATMENT PLANT (NEWPCC)
HAULED LIQUID WASTE FACILITY PHASE II UPGRADE

HAULED WASTEWATER BUILDINGS | & 2 FLUSHING WATER PLAN UPGRADES

CITY DRAWING NUMBER

I-OIOIY-POOO4-OOI

BID OPPORTUNITY: 952-2015 FILE PATH:

952-2015

FILE PATH: V:\1112\active\111216000\0300_drawing\0302_sheet_files\06_process\
FILE NAME: 1-0101Y-P0004-001.dwg