

1044-2016 ADDENDUM 6

SEVEN OAKS POOL ADDITION & RENOVATION

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: January 12, 2017
BY: Damien Fenez
TELEPHONE NO. 204 956 0938

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: Division 090600 Room Finish Schedule

111 Shower: North, South, East & West WALL MAT'L:T4

118 Corridor: North, South, East & West WALL FIN: EX

119 Splashpad: South WALL MAT'L: CB, FIN: EP

119 Splashpad: West WALL MAT'L: CB/GL, FIN: EP

119 Splashpad: North WALL MAT'L: SD/GL/T4, FIN: EP

119 Splashpad: East WALL MAT'L: CB/GL, FIN: EP

Revise: Division 093013 Item 2.1.1 to read:

T1: Porcelain tile to CAN/CGSB-75.1, Class MR (02 -3.0%), frost resistant with a slip resistant surface. Acceptable products: 300 x 600mm size, Olympia Tile Regal Collection. Colours: allow for 70% field colour and 30% accent colour, to be selected by Contract Administrator from standard range. Base tile: to match floor tile for each room scheduled and cut to 100mm high. Locations: floors and walls, as scheduled and as indicated on drawings.

DRAWINGS

Replace: 1044-2016 _Drawing_A2-06-R0 with 1044-2016 _Addendum_6-Drawing_A2-06-R1

Replace: 1044-2016 _Drawing_S-00-R1 with 1044-2016 _Addendum_6-Drawing_S-00-R2

END OF 1044-2016_ADDENDUM 6