



NOTES:

1. GREY ITEMS DENOTES EXISTING EQUIPMENT NOT INCLUDED IN SCOPE.
2. THIS DRAWING INDICATES REVISED I/O WIRING TO THE EXISTING RTU PANEL ONLY. REFER TO CITY OF WINNIPEG DRAWING 4319 FOR RTU PANEL WIRING.
3. ANY PROGRAMMING MODIFICATIONS TO THE RTU PANEL EQUIPMENT IS TO BE PROVIDED BY OTHERS.
4. REFER TO DRAWING 1-0153F-E0004-001 FOR ADDITIONAL INFORMATION.
5. EXISTING WIRING TO CONTROL RELAYS AND INDICATING LIGHTS IN RTU PANEL SHALL REMAIN. PROVIDE LAMACOID LABELS ON RTU PANEL INDICATING LIGHTS AS REQUIRED TO SUIT NEW ALARM SIGNALS.

LEGEND

- STARTER TERMINALS
- FUSE
- - - FIELD WIRING
- MANUFACTURER WIRING
- o|o NORMALLY OPEN

1 RTU PANEL PARTIAL FIELD WIRING SCHEMATIC (NOTE 2)
SCALE: N.T.S.



B.M.	-
ELEV.	-
DESIGNED BY:	J. BOUCHARD
CHECKED BY:	J. DELEON
DRAWN BY:	AS NOTED
SCALE:	2016/12/08
DATE:	2017/01/20
ISSUED FOR CONSTRUCTION	2017/01/20
NO.	REVISIONS

KGS GROUP
CONSULTING ENGINEERS

DESIGNED BY: J. BOUCHARD
CHECKED BY: J. DELEON
DRAWN BY: AS NOTED
SCALE: AS NOTED
DATE: 2016/12/08
ISSUED FOR CONSTRUCTION
BY: J. BOUCHARD
DATE: 2017/01/20

CONSULTANT NO.: 16-0107-025_E05

ENGINEER'S SEAL

2017/01/23

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

LARCHDALE FLOOD PUMP STATION
GENERATOR REPLACEMENT PROJECT
ELECTRICAL
MISCELLANEOUS WIRING SCHEMATIC

CITY DRAWING NUMBER: 1-0153F-E0005-001
SHEET: 00
REV: 00
SIZE: A1