



## 15-2016 ADDENDUM 4

### LIGHTING UPGRADE – RIVER EAST ARENA, 1410 ROTHESAY

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: January 21, 2016  
BY: Kathy Roberts  
TELEPHONE NO. 204 470-7380

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20150806

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART A – BID SUBMISSION**

Replace: 15-2016 \_Addendum\_3\_Bid Submission with 15-2016 \_Addendum\_4\_Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B(R2): Item No. 18. – Model number is amended

#### **PART D – SUPPLEMENTAL CONDITIONS**

Add: D2,2(i) Item No. 18 on Form B(R2): Prices comes with integral photocell. Contractor will need to make an internal modification to the fixtures to jumper out the photocell, to enable the fixtures to operate only on a switch.

#### **APPENDICES**

Replace: 15-2016\_Lighting Schedule with 15-2016\_Addendum\_4\_Lighting Schedule-R1