ASBESTOS INVENTORY CONTROL



Planning, Property and Development Department Municipal Accommodations Division 4th Floor - 185 King Street • Winnipeg, MB • R3B 1J1

Building Name:	River East Indoor Arena	Inspection Date:	May 29, 2015
Building Code:	AR-11	Inspected By:	Ryan Matthews & James Neufeld
Building Address:	1410 Rothesay Street	Construction Date:	1972

		Drawing	Material	Testing	Date	Test	Est.
Material Location	Material Description	Label	Condition	Status	M/Y	%	%
Main Floor	All asbestos floor and ceiling tiles removed on main						
	floor May 2012						
Main Hall/Lobby	12x12 Floor Tile	F12	Removed	TESTED	Sep/'08	1-5	
Main Hall (West side near washrooms)	12x12 Floor Tile	F12	Removed	TESTED	Apr/'10	0	
Conference room	12x12 Floor Tile	F12	Removed		May'12		1-5
Ticket booth & side entrance	12x12 Floor Tile	F12	Removed		May'12		1-5
	24x48 Ceiling Tile		Removed		May'12		5
Canteen	24x48 Ceiling Tile	C48	Removed	TESTED	Apr/'10	5	
Arena office	12x12 Floor Tile	F12	Removed/May/12		May'12		1-5
Janitor's room	12x12 Floor Tile	F12	Good	TESTED	Apr/'10	0	
Men's washroom	12x12 Floor Tile	F12	Good	TESTED	Apr/'11	0	
Women's washroom	12x12 Floor Tile	F12	Good	TESTED	Apr/'11	0	
East level landings	12x12 Floor Tile	F12	Removed		Apr/'11		
West level landings	12x12 Floor Tile	F12	Removed		Apr/'11		
Ramp	Rubber Mats						0
Second Floor							
West & east level landings	12x12 Floor Tile	F12	Good				1-5
Play area / Kitchen	12x12 Floor Tile	F12	Good				10
	24x48 Ceiling Tile	C48	Good	TESTED	Jul/'09	2-5	
South storage room	24x48 Ceiling Tile	C48	Good				2-5
	12x12 Floor Tile	F12	Good				10
Storage room	12x12 Floor Tile	F12	Good	TESTED	Apr/'10	10	
Boy's washroom	24x48 Ceiling Tile	C48	Good				2-5
Girl's washroom	24x48 Ceiling Tile	C48	Good				2-5

		Drawing	Material	Testing	Date	Test	Est.
Material Location	Material Description	Label	Condition	Status	M/Y	%	%
Ice Shed	Asphalt Plank Flooring	APF	Good			1	
Zamboni Room	Hardboard - Ceiling (around hatch)	HB	Good				
Basement							
West level landings	12x12 Floor Tile	F12	Removed		Apr/'11		
Dressing Room 2 Washroom	Asphalt Plank Flooring (1' x 4' Planks)	APF	Good	TESTED	Mar/'13	2	
Referee Room	Asphalt Plank Flooring (1' x 4' Planks)	APF	Good				2
Team Washrooms/Shower	Asphalt Plank Flooring (1'x 4' Planks)	APF					2
Dressing Rooms & Hall	Asphalt Plank Flooring (1' x 2' Planks)	APF					0
Exterior Block Walls	Randomly Inspected & Appear To Be Empty (Do Not Contian Vermiculite Insulaton)	_					
							1

NOTES:

1. Asbestos inspections and inventory updates are conducted annually.

2. There may be asbestos containing materials present that were not located during asbestos inspections.

3. Floor tile and sheet flooring installed before 1990 may contain asbestos and must be treated as an asbestos containing material.

4. Vermiculite insulation may contain pockets of asbestos. All vermiculite insulation must be treated as an asbestos containing material.

5. For asbestos related inquiries, call Central Control at 204-986-2382

AR-11







