



NOTES:
 1. THIS DRAWING CONTAINS UNVERIFIED INFORMATION FROM EXISTING DOCUMENTATION.
 2. THE ENGINEER'S RESPONSIBILITY IS LIMITED TO THE ARC FLASH STUDY AND RECOMMENDED MITIGATION.

REQUIRED WORK:
 (A) AFFIX NEW IDENTIFICATION LAMACOIDS TO:
 DS-L1
 ATS-L1
 PNL-L1
 MSP-L2
 XFMR-L10
 PNL-L10
 XFMR-L11

LEGEND:
 PPE: 4 — HAZARD/RISK CATEGORY
 29 cal/cm² — INCIDENT ENERGY

ARC FLASH VALUES CALCULATED ARE BASED ON THE PROTECTION SETTINGS SPECIFIED IN THIS DRAWING.



00	ISSUED FOR CITY USE	2012/01/31	TMC	CJR
NO.	REVISIONS	DATE	DESIGN	CHECK

SNC-LAVALIN INC.
 148 Nature Park Way
 Winnipeg, MB, Canada R3P 0X7
 204-786-8080

DESIGNED BY: T. CHURCH
 CHECKED BY: C. REIMER
 DRAWN BY: S. FUNK
 APPROVED BY: C. REIMER
 SCALE: NTS
 RELEASED FOR CONSTRUCTION BY: []
 DATE: 2011/02/02
 CONSULTANT NO.:

ENGINEER'S SEAL
 ORIGINAL DRAWING
 SEALED BY:
 T. M. CHURCH
 SNC-LAVALIN
 MEMBER # 32682
 2012/02/01
 REV. 00

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

BURROWS WASTEWATER LIFT STATION
 PUMPING STATION CONDITION ASSESSMENT PHASE 1
 SINGLE LINE DIAGRAM

CITY DRAWING NUMBER: 1-0121L-E0001
 SHEET: 001
 REV: 00
 SIZE: A1