

THIS DRAWING MUST NOT BE SCALED.
 THE GENERAL CONTRACTOR SHALL VERIFY ALL DIMENSIONS, DATUMS, AND LEVELS PRIOR TO COMMENCEMENT OF WORK. ALL ERRORS AND OMISSIONS TO BE REPORTED TO NUMBER TEN ARCHITECTURAL GROUP BEFORE PROCEEDING.
 VARIATIONS AND MODIFICATIONS TO WORK SHOWN ON THESE DRAWINGS SHALL NOT BE CARRIED OUT WITHOUT WRITTEN PERMISSION OF NUMBER TEN ARCHITECTURAL GROUP.
 THIS DRAWING IS THE EXCLUSIVE PROPERTY OF NUMBER TEN ARCHITECTURAL GROUP AND THE COPYRIGHT IN THE SAME IS RESERVED TO THEM. IT MAY BE REPRODUCED ONLY WITH THE PERMISSION OF NUMBER TEN ARCHITECTURAL GROUP, IN WHICH CASE THE REPRODUCTION MUST BEAR THEIR NAME.

REVISED/ ISSUED/ PLOTTED	DATE
ISSUED FOR DECONSTRUCTION	2017.03.24
REVISION 1	2017.06.26

GENERAL NOTES:

- THIS DRAWING IS DIAGRAMMATIC ONLY. DO NOT SCALE.
- THE MECHANICAL SYSTEMS SHOWN ARE APPROXIMATE IN LOCATION ONLY. CONTRACTOR TO VERIFY EXACT LOCATION OF SYSTEMS BEING MODIFIED ON SITE PRIOR TO COMMENCEMENT OF WORK.
- ALL WORK SHALL COMPLY WITH THE MOST CURRENT VERSION OF ALL APPLICABLE CODES AND STANDARDS, WHICH SHALL BE CONSIDERED PART OF THESE CONTRACT DOCUMENTS. IN THE CASE OF CONFLICTING REQUIREMENTS, THE MOST STRINGENT REGULATION SHALL PREVAIL.
- CONTRACTOR TO MAINTAIN CURRENT AND READILY REVIEWABLE AS-BUILT DRAWINGS ACCURATELY REFLECTING SITE INSTALLATIONS.
- CONTRACTOR TO ENSURE ALL MATERIALS MODIFIED OR INSTALLED IN AN AIR PLENUM ARE RATED FOR SUCH USE.
- CONTRACTOR TO MAINTAIN DIGITAL PHOTOGRAPHIC RECORDS OF ALL INSTALLATIONS PRIOR TO CONCEALMENT BY SUPPORTING TRADES.
- CONTRACTOR TO CONFIRM EXACT LOCATIONS OF HEADS AND BRANCH LINES ON SITE PRIOR TO BID.
- CONTRACTOR TO COORDINATE ALL NEW SPRINKLER PIPING WITH ALL EXISTING AND NEW SYSTEMS, ALONG WITH ARCHITECTURAL CEILING HEIGHTS. THERE SHALL BE NO EXTRAS TO THE CONTRACT OR ADJUSTMENTS TO CEILING HEIGHT TO COMPLETE THIS WORK. MAINTAIN AS MUCH CLEAR CEILING SPACE AS POSSIBLE.
- REVIEW SITE FOR EXISTING CONDITIONS AND SPRINKLER HEAD COUNT PRIOR TO SUBMISSION OF BIDS.

DRAWING NOTES:

- APPROXIMATE LOCATION OF EXISTING SPRINKLER TREE TO REMAIN.
- EXISTING FIRE DEPARTMENT CONNECTION TO REMAIN.
- EXISTING FIRE HOSE TO REMAIN.
- ALL EQUIPMENT AND SERVICES WITHIN THE SPRINKLER TREE ROOM AND ADJACENT ELECTRICAL ROOM TO REMAIN, MODIFY SPRINKLER PIPING AS REQUIRED.

SCOPE OF WORK:

- DEMOLISH ALL FIRE PROTECTION PIPING AND SPRINKLER HEADS LOCATED ON THE MAIN FLOOR.
- REROUTE SPRINKLER PIPING FROM THE SPRINKLER TREE TO CONNECT TO THE SPRINKLER PIPING SERVING THE UNDERSIDE OF THE ROOF.
- SPRINKLER HEADS CURRENTLY SERVING THE WAREHOUSE AND MEZZANINE SHALL REMAIN.
- FIRE EXTINGUISHER WITHIN THE DEMOLITION FOOTPRINT SHALL BE TURNED OVER TO THE CONTRACT ADMINISTRATOR. FIELD CONFIRM LOCATION AND QUANTITY.

SYMBOL LEGEND

FIRE PROTECTION	
—	SPRINKLER PIPE
—	PIPE CONTINUATION
○	UPRIGHT SPRINKLER HEAD
● FE	FIRE EXTINGUISHER
+	FIRE DEPARTMENT CONNECTION
Q	FIRE HOSE

MECHANICAL DRAWING LIST	
M1.1	MAIN FLOOR PLAN – FIRE PROTECTION DEMOLITION LAYOUT
M1.2	MEZZANINE PLAN – FIRE PROTECTION DEMOLITION LAYOUT
M2.1	MAIN FLOOR PLAN – HVAC DEMOLITION LAYOUT
M2.2	MEZZANINE PLAN – HVAC DEMOLITION LAYOUT
M3.1	MECHANICAL SPECIFICATION



number TEN architectural group 10

Winnipeg Office: 204 942.0981
 Victoria Office: 250 360.2106

architecture • interior design • planning

850 EMPRESS BUILDING UPGRADE
 850 EMPRESS STREET, WINNIPEG, MB

project
 MAIN FLOOR PLAN - FIRE PROTECTION DEMOLITION LAYOUT

sheet title
MCW / AGE
 Consulting Professional Engineers
 2104 6211 Wellington Avenue
 Winnipeg, Manitoba, R3W 0G4
 Phone: (204) 778-7900 Fax: (204) 778-1119
 E-Mail: info_winnipeg@mcw.com

11661 consultant



scale: AS SHOWN
 date: JUNE 26/17
 drawn by: EJ
 checked by: CP
 project no. 2016094
 sheet no. M1.1R1

1 MAIN FLOOR PLAN – FIRE PROTECTION DEMOLITION LAYOUT
 M1.1 SCALE: 1/8"=1'-0"

