



ELECTRICAL LIGHTING RENOVATION NOTES: "x"

ALSO SEE NOTES & SPECIFICATIONS.
ALL WIRING & CABLING IN RETURN AIR CEILING SPACE SHALL BE PLENUM RATED AS PER LATEST CEC.

NOTE: ORIENTATE 2x2 LUMINAIRE WITH LENGTH OF DIFFUSER PERPENDICULAR TO LONGEST LENGTH OF ROOM OR AREA.

1. PROVIDE LUMINAIRES TO DEDICATED CIRCUIT SHOWN WITH SEPARATED NEUTRAL CONDUCTOR FOR EACH CIRCUIT. DO NOT SHARE NEUTRAL CONDUCTORS WITH OTHER CIRCUITS.
2. PROVIDE WALL-MOUNTED DIMMER TO DAISY CHAIN TO nLIGHT LUMINAIRE WITH PLENUM RATED CAT5e. COLOUR WHITE. REFER TO ELECTRICAL SPECIFICATION. REFER TO DATA CABLING SPECIFICATION DRAWING FOR BUNDLING, SUPPORT & ROUTING. AFFIX nLIGHT LUMINAIRE NETWORK ID STICKER TO REFLECTOR (FINISH SPACE SIDE) & ALSO AFFIX OTHER nLIGHT LUMINAIRE NETWORK ID STICKER ON DRAWING FOR FUTURE PROGRAMMING OF nLIGHT SYSTEM.

- NOTES:**
1. THESE DRAWINGS SHALL NOT BE SCALED. CONSULT WITH CLIENT AND DESIGNER ON ANY CONCERNS.
 2. DIMENSIONS & UNITS SHOWN IN WHOLE NUMBERS ARE IN MILLIMETRES (mm).
 3. DIMENSIONS & UNITS SHOWN TO DECIMAL PLACES ARE IN METRES (M).
 4. ALSO REFER TO SHEET E1 & ELECTRICAL SPECIFICATIONS.

No.	REVISION/DESCRIPTION	BY	DATE
0	ISSUED FOR CONSTRUCTION	DTA	2017.03.20



DRAWN	CHECKED	DESIGNED	APPROVED
DTA	DTA	DTA	DTA
DATE: 2017.01.27	USER APPROVAL		

Winnipeg THE CITY OF WINNIPEG
PLANNING, PROPERTY AND
DEVELOPMENT DEPARTMENT
MUNICIPAL ACCOMMODATIONS DIVISION
3-65 GARRY STREET, R3C 4K4

PROJECT
BRADY ROAD LANDFILL
ADMINISTRATION BUILDING
DEVELOPMENT FOR BRADY LANDFILL
1777 BRADY ROAD

SHEET TITLE
MAIN FLOOR REFLECTED CEILING PLAN
ELECTRICAL
LIGHTING

SCALE	PROJECT No:	SHEET No:
AS SHOWN	2015-037-02	E6