



FUSE SCHEDULE			
TB	IDENTIFIER	SIZE	RATED CURRENT (A) FA
TB03	65P	5x20mm	0.1
	66P	5x20mm	0.1
	67P	5x20mm	0.1
	68P	5x20mm	0.1
	69P	5x20mm	0.1
	70P	5x20mm	0.1
	71P	5x20mm	0.1
	72P	5x20mm	0.1
	73P	5x20mm	0.1
	74P	5x20mm	0.1
	75P	5x20mm	0.1
	76P	5x20mm	0.1
	77P	5x20mm	0.1
	78P	5x20mm	0.1
	79P	5x20mm	0.1
	80P	5x20mm	0.1
	81P	5x20mm	0.1
	82P	5x20mm	0.1
	83P	5x20mm	0.1
	84P	5x20mm	0.1
	85P	5x20mm	0.1
	86P	5x20mm	0.1
	87P	5x20mm	0.1
	88P	5x20mm	0.1
89P	5x20mm	0.1	
90P	5x20mm	0.1	
91P	5x20mm	0.1	
92P	5x20mm	0.1	
93P	5x20mm	0.1	
94P	5x20mm	0.1	
95P	5x20mm	0.1	
96P	5x20mm	0.1	

- NOTES**
- ALL 120VAC POWER WIRING TO BE A MINIMUM OF 12 AWG UNLESS OTHERWISE INDICATED.
 - ALL 24VDC POWER WIRING TO BE A MINIMUM OF 14 AWG UNLESS OTHERWISE INDICATED.



00	ISSUED FOR TENDER, BID OPP. 639-2017	2017-07-25	TMC	BJC
NO.	REVISIONS	DATE	DESIGN	CHECK

SNC-LAVALIN INC.
148 Nature Park Way
Winnipeg, MB, Canada R3P 0X7
204-786-8080

DESIGNED BY: T. CHURCH
DRAWN BY: Y. KONIG
SCALE: NTS
DATE: 2017/05/18
CONSULTANT NO.:

CHECKED BY: B. CLEVEN
APPROVED BY: B. CLEVEN
ISSUED FOR CONSTRUCTION BY:
DATE:

ENGINEER'S SEAL

PRELIMINARY
NOT TO BE
USED FOR
CONSTRUCTION

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

COMMUNITY ROW WASTEWATER PUMPING STATION
2017 UPGRADES
10 WIRING DIAGRAMS
CONTROL PANEL CP-L81
DISCRETE INPUTS

CITY DRAWING NUMBER: 1-0130L-A0003
SHEET: 003
REV: 00
SIZE: A1

DRAWING NUMBER	REFERENCE DRAWINGS
----------------	--------------------