



FUSE SCHEDULE			
TB	IDENTIFIER	SIZE	RATED CURRENT (A) FA
TB06	1P	5x20mm	1
	2P	5x20mm	1
	3P	5x20mm	1
	4P	5x20mm	1
	5P	5x20mm	1
	6P	5x20mm	1
	7P	5x20mm	1
	8P	5x20mm	1
TB07	9P	5x20mm	1
	10P	5x20mm	1
	11P	5x20mm	1
	12P	5x20mm	1
	13P	5x20mm	1
	14P	5x20mm	1
	15P	5x20mm	1
	16P	5x20mm	1

- NOTES**
- CONNECT FLYING LEADS CABLE OVERALL SHIELD TO TERMINAL 1S.
  - CONNECT FLYING LEADS CABLE OVERALL SHIELD TO TERMINAL 9S.



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER, BID OPP. 639-2017	2017-07-25	TMC	BJC

**SNC-LAVALIN**

DESIGNED BY: T. CHURCH  
 CHECKED BY: B. CLEVEN

DRAWN BY: Y. KONIG  
 APPROVED BY: B. CLEVEN

SCALE: NTS  
 ISSUED FOR CONSTRUCTION

DATE: 2017/05/24  
 BY:

CONSULTANT NO.:

ENGINEER'S SEAL

**PRELIMINARY**  
 NOT TO BE  
 USED FOR  
 CONSTRUCTION

**THE CITY OF WINNIPEG**  
 WATER AND WASTE DEPARTMENT

COMMUNITY ROW WASTEWATER PUMPING STATION  
 2017 UPGRADES  
 IO WIRING DIAGRAMS  
 CONTROL PANEL CP-L81  
 ANALOG INPUTS

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1-0130L-A0005	001	00	A1