


**PLAN - TEMPORARY BYPASS PUMPING POWER SUPPLY**  
SCALE: 1 : 200

**NOTES:**

1. CONTRACTOR TO DESIGN METHOD OF ROADWAY CROSSING, COMPLETE WITH SEALED ENGINEERING PLANS. SUBMIT SEALED PLANS TO CONTRACT ADMINISTRATOR FOR REVIEW AND SUBMISSION TO TRAFFIC SERVICES FOR APPROVAL. DO NOT BEGIN CONSTRUCTION UNTIL APPROVAL FROM TRAFFIC SERVICES IS RECEIVED.
2. CONTRACTOR MAY UTILIZE OVERHEAD CABLING TO PROVIDE POWER TO TEMPORARY BYPASS PUMPS IN JUNCTION CHAMBER "B". MINIMUM VERTICAL CLEARANCE TO OVERHEAD CABLING SHALL BE 5.3 METERS OR GREATER.
3. PROVIDE TEMPORARY FENCING AND TRAFFIC SIGNS AROUND ABOVE-GRADE EQUIPMENT, CABLING, AND BELOW-GRADE OPENINGS TO ENSURE THE SAFETY OF THE PUBLIC, AND TO ENSURE VEHICLES AND SNOW PLOWS DO NOT DAMAGE TEMPORARY BYPASS PUMPING INFRASTRUCTURE.
4. CONTRACTOR IS RESPONSIBLE FOR RESTORING SITE CONDITIONS FOLLOWING REMOVAL OF TEMPORARY BYPASS PUMPING EQUIPMENT.

**LEGEND**

- NEW BUILDING
- EXIST. STRUCTURE TO REMAIN
- EXIST. GAS SERVICE
- NEW GAS SERVICE
- EXIST. WATERMAIN
- TEMPORARY POWER



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER, BID OPP. 639-2017	2017-07-25	FZ	BJC

<b>SNC-LAVALIN</b>		SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-786-8080	
DESIGNED BY:	F. ZURZOLO	CHECKED BY:	B. CLEVEN
DRAWN BY:	D. CALVERLEY	APPROVED BY:	B. CLEVEN
SCALE:	AS NOTED	ISSUED FOR CONSTRUCTION BY:	
DATE:	2017/07/25	DATE:	
CONSULTANT NO.:			

ENGINEER'S SEAL  
**PRELIMINARY**  
NOT TO BE  
USED FOR  
CONSTRUCTION

**THE CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT

COMMUNITY ROW WASTEWATER PUMPING STATION  
2017 UPGRADES  
SITE PLAN  
TEMPORARY BYPASS PUMPING

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1-0130L-C0001	002	00	A1