

958-2017 ADDENDUM 1

REQUEST FOR PROPOSAL FOR PROFESSIONAL CONSULTING SERVICES FOR PROVISION OF DETAILED DESIGN AND CONTRACT ADMINISTRATION SERVICES FOR THE HAWTHORNE WASTEWATER PUMPING STATION UPGRADES

ISSUED: November 17, 2017 BY: Doug Berg, C.E.T. TELEPHONE NO. 204 - 986-4452

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE REQUEST FOR PROPOSAL

THIS ADDENDUM SHALL BE INCORPORATED INTO THE REQUEST FOR PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.

PART D - SUPPLEMENTAL CONDITIONS

Revise: D4.1 to read: The Services required under this Contract shall consist of providing the preliminary and

detailed design, bid opportunity preparation, tendering and contract administration services for work to upgrade the **Hawthorne Wastewater Pumping Station** in

accordance with the following:

(a) Preliminary Engineering;

- (b) Geotechnical Engineering;
- (c) Design and Specification Development;
- (d) Contract Document Preparation;
- (e) Procurement Process:
- (f) Non-Resident Construction Services:
- (g) Resident Construction Services:
- (h) Record Drawings and Project Closeout Services.

Revise: D9.1 (a) to read: Bid Opportunity for supply of goods and materials with long deliveries (pumps and

motors, large diameter valves, etc.) closing by March 29, 2018.

PART E - SPECIFICATIONS

Add:	E1.1.6 (b) (xii)	Provision for priming and painting all interior surfaces (floors, walls and ceilings) in all levels of the Station.
Add:	E1.1.6 (b) (xiii)	Provision to improve pump room floor drainage to the sump pit and pump location (i.e.: re-slope pump room floor; installation of floor drain channel).
Add:	E1.1.6 (c) (xii)	Extend permanent water supply lines to each new pump installed, complete with isolation valves, to provide seal water supply to pumps.
Add:	E1.1.6 (c) (xiii)	Provision to paint all process piping, valves, fittings, etc. inside Station.