EXISTING BULK FILL

EXISTING 50mm

CAMLOCK

EXISTING ACCESS

HATCH/

EXISTING BULK FILL-

OPERATOR INTERFACE

DRAIN

NEW SERVICE

ENTRANCE CB-L01

EXISTING

PIPING

CRAWLSPACE

OPERATOR INTERFACE

NEW GROUND BUS-

EXISTING ANTENNA

NEW CSTE CABINET-

NEW UTILITY METER

EXISTING BULK FILL

CONTROL PANEL

EXISTING SUMP

NEW 5 kW 240/208 **VAC UNIT HEATER** WITH INTEGRAL THERMOSTAT

PUMP IN CRAWLSPACE

POLE AND CONC.

BASE

NEW RGS SLEEVE. REFER TO NOTE 1

NEW RGS SLEEVE

REFER TO NOTE 1

EXISTING 75mm CAMLOCK

NEW HEAT TRACE THERMOSTAT

NEW ALARM PANEL

NEW RTU CONTROL PANEL

NEW HEAT TRACE CONTROL PANEL


NEW ALARM KEY SWITCH

(REFER TO NOTE 5)


- NEW BOLLARD (TYP.)


CONSTRUCTION NOTES

- 1. INSTALL RGS SLEEVES FOR HEAT TRACE CABLES. CORE OPENINGS THROUGH FOUNDATION WALL AND SEAL OPENING.
 - 2. DISCONNECT CABLES AND REMOVE PANELS.
- 3. PROVIDE WALL MOUNTED 21mm THICK, GOOD ONE SIDE, PLYWOOD BACKBOARD PAINTED WITH MIN. 2 COATS WHITE PAINT, FOR SURFACE MOUNTING OF NEW ELECTRICAL EQUIPMENT AND ENCLOSURES.



A SECTION - SOUTH — SCALE 1:25





NEW BUILDING POWER FLOOR PLAN SCALE 1:25

DRAIN

Certificate of Authorization **Dillon Consulting Limited (MB)** No. 1789 Date: 04/15/19

| LOCATION APPROVED | | B.M. ELEV. | | | | , , , , , , , , , , , , , , , , , , , | ENGINEER'S SEAL | | |
|---|--|----------------------------|----------|--------|----------------------|---------------------------------------|-----------------|----|---|
| UNDERGROUND STRUCTURES | CONSTRUCTION COMPLETION DATE: YYYY MM DD | | | | | | | | AND WANTED |
| | | | | | | DIL | LON | | 12/2/21 |
| SUPV. U/G STRUCTURES DATE COMMITTEE | | | | | CONSULTING | | | |] |
| | | | | | DESIGNED | B.L.M | CHECKED | XX | MOORE E |
| NOTE: | | | | | BY | D.L.IVI | BY | ^^ | Hpril 12/1/6/ |
| | | | | | DRAWN | S.C.K. | APPROVED | XX | A TO COUNTY |
| LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE BUT | | | | | BY | 3.U.N. | BY | ^^ | THOFESSION OF THE PROPERTY OF |
| NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING WITH CONSTRUCTION. | | | | | SCALE: HORIZONTAL | AS SHOWN | RELEASED FOR | | |
| | 1 | ISSUED FOR BID OP 103-2019 | 04/15/19 | B.L.M. | | | CONSTRUCTION | | CONSULTANT DRAWING NUMBER |
| | 0 | ISSUED FOR 90% REVIEW | 03/07/19 | C.A.L. | VERTICAL | | | | E-02 |
| | NO. | REVISIONS | DATE | BY | DATE | 2017 07 07 | DATE | | |

PLOT DATE:

2019 04 23

Winnipeg

BID OPPORTUNITY: 634-2017

CONTRACT NUMBER: X

THE CITY OF WINNIPEG

WATER AND WASTE DEPARTMENT ENGINEERING DIVISION 2019 REHABILITATION OF PUBLIC WATER SERVICE SHEET 6 OF 20

OUTLET PAVEMENT WORKS, BUILDING REPAIRS, AND ELECTRICAL UPGRADES ELECTRICAL - CHEVRIER BLVD BUILDING POWER

D-14912

CITY DRAWING NUMBER

FILE PATH: C:\projectwise\working directory\active\40cal\d0713845\ FILE NAME: 175009-06A-SHT-Chev-PWR.dwg