



## 1195-2019 ADDENDUM 3

### WAYFINDING PHASE 1 CONSTRUCTION ST. JAMES-ASSINIBOIA CENTENNIAL POOL

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
TENDER**

ISSUED: December 4, 2019  
BY: Lou M. Chubenko  
TELEPHONE NO. 204 470-7881

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE TENDER AND SHALL FORM A PART  
OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

#### **QUESTIONS AND ANSWERS**

- Q1: What type of cable fibre is required?  
A1: Fibre type shall be confirmed by monument sign supplier.
- Q2: Is the Contractor responsible to supply and pull the cable from the new sign to the Electrical Room complete with a tail of additional cable?  
A2: Refer to Drawing Note 1 on 1195-2019\_Drawing\_E2.0-R0.
- Q3: Who is responsible for all termination and testing of the cable fibre?  
A3: The electrical sub-contractor is responsible for all termination and testing of the cable fibre.