



413-2021 ADDENDUM No. 2

AIR HANDLING UNIT REPLACEMENT GLENWOOD COMMUNITY CENTRE - 27 OVERTON STREET

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: June 30, 2021
BY: P. Silva, P.Eng.
TELEPHONE NO. 204 896-1209

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

NMS SPECIFICATIONS

Section 23 73 11 AIR HANDLING UNIT:

- Add 2.1.2.9 The unit base shall be constructed of a 6061-T6-Extruded 8 Inch aluminum channel. The base must be welded not mechanically fastened together. The frame structure of the outer walls shall also be welded to the base frame and continuously sealed at the junction between the wall and the base of the unit connects.
- Revise 2.1.13 Air Handling Unit Schedule - REMARKS to read:
- Unit to be manufactured to match existing RTU dimensions, roof curb and supply/return duct sizes.
 - Extend flue 24" above unit roof.
 - ***Unit weight shall not exceed 4,950 lbs.***