



THE CITY OF WINNIPEG

TENDER

TENDER NO. 884-2021

**2022 LOCAL AND INDUSTRIAL STREET AND ALLEY RENEWAL PROGRAM –
WATERFORD AV, GERARD ST, OAKENWALD AV AND VARIOUS LOCATIONS**

TABLE OF CONTENTS

PART A - BID SUBMISSION

- Form A: Bid/Proposal
- Form B: Prices
- Form G1: Bid Bond and Agreement to Bond

PART B - BIDDING PROCEDURES

B1. Contract Title	1
B2. Submission Deadline	1
B3. Site Investigation	1
B4. Enquiries	1
B5. Confidentiality	1
B6. Addenda	2
B7. Substitutes	2
B8. Bid Components	3
B9. Bid	3
B10. Prices	4
B11. Disclosure	4
B12. Conflict of Interest and Good Faith	5
B13. Qualification	6
B14. Bid Security	7
B15. Opening of Bids and Release of Information	7
B16. Irrevocable Bid	8
B17. Withdrawal of Bids	8
B18. Evaluation of Bids	8
B19. Award of Contract	8

PART C - GENERAL CONDITIONS

C0. General Conditions	1
------------------------	---

PART D - SUPPLEMENTAL CONDITIONS

General

D1. General Conditions	1
D2. Form of Contract Documents	1
D3. Scope of Work	1
D4. Contract Administrator	3
D5. Contractor's Supervisor	3
D6. Notices	4
D7. Furnishing of Documents	4

Submissions

D8. Authority to Carry on Business	4
D9. Safe Work Plan	4
D10. Insurance	4
D11. Contract Security	5
D12. Subcontractor List	6
D13. Detailed Work Schedule	6

Schedule of Work

D14. Commencement	6
D15. Working Days	7
D16. Restricted Work Hours	7
D17. Work By Others	8
D18. Sequence of Work	8
D19. Critical Stages	8
D20. Substantial Performance	9
D21. Total Performance	9

D22. Liquidated Damages	9
D23. COVID-19 Schedule Delays	10
D24. Scheduled Maintenance	10
Control of Work	
D25. Job Meetings	10
D26. Prime Contractor – The Workplace Safety and Health Act (Manitoba)	11
D27. The Workplace Safety and Health Act (Manitoba) – Qualifications	11
Measurement and Payment	
D28. Payment	11
Warranty	
D29. Warranty	11
Dispute Resolution	
D30. Dispute Resolution	11
Third Party Agreements	
D31. Funding and/or Contribution Agreement Obligations	12
Form H1: Performance Bond	15
Form H2: Labour and Material Payment Bond	17
Form J: Subcontractor List	19

PART E - SPECIFICATIONS

General

E1. Applicable Specifications and Drawings	1
E2. Mobilization and Demobilization Payment	2
E3. Geotechnical Report	3
E4. Protection Of Existing Trees	3
E5. Traffic Control	4
E6. Traffic Management	5
E7. Refuse and Recycling Collection	5
E8. Pedestrian Safety	7
E9. Water Obtained From the City	7
E10. Surface Restorations	7
E11. Infrastructure Signs	7
E12. Patching of Existing Pavement	7
E13. Supply and Installation of Pavement Repair Fabric	8
E14. Partial Depth Patching of Existing Joints	12
E15. Supply and Install Watermain and Water Service Insulation	13
E16. Adjustment of Sprinkler Heads and/or Drainage Pipe	14
E17. Hydro Excavation	15
E18. Soft Excavation to Expose Underground Utilities	16
E19. Concrete Constituent Materials, Mix Design Requirements, and Hot and Cold Weather Concreting	16
E20. Landscaping Curb	31
E21. Construction of Barrier Curb for Asphalt Pavement	31
E22. Pruning of Existing Trees and Shrubs	33
E23. Water and Waste Sewer Repairs	34
E24. Installation of Street Lighting and Associated Works	34
E25. Working Around Teraspan Fibre Optic Lines	48
E26. Site Requirements for Accessibility	49

APPENDIX 'A' – GEOTECHNICAL

APPENDIX 'B' – MANITOBA HYDRO ELECTRICAL STANDARDS – 2020 STREET LIGHT INSTALLATIONS

APPENDIX 'C' – SAFE EXCAVATION SAFETY WATCH GUIDELINES

APPENDIX 'D' – GELCAP KIT

APPENDIX 'E' – ELECTRIC GAS LOCATE

APPENDIX 'F' – MANITOBA HYDRO SAMPLE JOB PLAN
APPENDIX 'G' – NETWORK COMMISSIONING REPORT

PART B - BIDDING PROCEDURES

B1. CONTRACT TITLE

B1.1 2022 Local and Industrial Street and Alley Renewal Program – Waterford Av, Gerard St, Oakenwald Av and Various Locations

B2. SUBMISSION DEADLINE

B2.1 The Submission Deadline is 12:00 noon Winnipeg time, March 24, 2022.

B2.2 The Contract Administrator or the Manager of Materials may extend the Submission Deadline by issuing an addendum at any time prior to the time and date specified in B2.1.

B3. SITE INVESTIGATION

B3.1 Further to C3.1, the Bidder may view the Site without making an appointment.

B4. ENQUIRIES

B4.1 All enquiries shall be directed to the Contract Administrator identified in D4.1.

B4.2 If the Bidder finds errors, discrepancies or omissions in the Tender, or is unsure of the meaning or intent of any provision therein, the Bidder shall notify the Contract Administrator of the error, discrepancy or omission, or request a clarification as to the meaning or intent of the provision at least five (5) Business Days prior to the Submission Deadline.

B4.3 Responses to enquiries which, in the sole judgment of the Contract Administrator, require a correction to or a clarification of the Tender will be provided by the Contract Administrator to all Bidders by issuing an addendum.

B4.4 Responses to enquiries which, in the sole judgment of the Contract Administrator, do not require a correction to or a clarification of the Tender will be provided by the Contract Administrator only to the Bidder who made the enquiry.

B4.5 The Bidder shall not be entitled to rely on any response or interpretation received pursuant to B4 unless that response or interpretation is provided by the Contract Administrator in writing.

B4.6 Any enquiries concerning submitting through MERX should be addressed to:
MERX Customer Support
Phone: 1-800-964-6379
Email: merx@merx.com

B5. CONFIDENTIALITY

B5.1 Information provided to a Bidder by the City or acquired by a Bidder by way of further enquiries or through investigation is confidential. Such information shall not be used or disclosed in any way without the prior written authorization of the Contract Administrator. The use and disclosure of the confidential information shall not apply to information which:

- (a) was known to the Bidder before receipt hereof; or
- (b) becomes publicly known other than through the Bidder; or
- (c) is disclosed pursuant to the requirements of a governmental authority or judicial order.

B5.2 The Bidder shall not make any statement of fact or opinion regarding any aspect of the Tender to the media or any member of the public without the prior written authorization of the Contract Administrator.

B6. ADDENDA

- B6.1 The Contract Administrator may, at any time prior to the Submission deadline, issue addenda correcting errors, discrepancies or omissions in the Tender, or clarifying the meaning or intent of any provision therein.
- B6.2 The Contract Administrator will issue each addendum at least two (2) Business Days prior to the Submission Deadline, or provide at least two (2) Business Days by extending the Submission Deadline.
- B6.3 Addenda will be available on the MERX website at www.merx.com.
- B6.4 The Bidder is responsible for ensuring that he/she has received all addenda and is advised to check the MERX website for addenda regularly and shortly before the Submission Deadline, as may be amended by addendum.
- B6.5 The Bidder shall acknowledge receipt of each addendum in Paragraph 10 of Form A: Bid/Proposal. Failure to acknowledge receipt of an addendum may render a Bid non-responsive.
- B6.6 Notwithstanding B4, enquiries related to an Addendum may be directed to the Contract Administrator indicated in D4.

B7. SUBSTITUTES

- B7.1 The Work is based on the Plant, Materials and methods specified in the Tender.
- B7.2 Substitutions shall not be allowed unless application has been made to and prior approval has been granted by the Contract Administrator in writing.
- B7.3 Requests for approval of a substitute will not be considered unless received in writing by the Contract Administrator at least five (5) Business Days prior to the Submission Deadline.
- B7.4 The Bidder shall ensure that any and all requests for approval of a substitute:
- (a) provide sufficient information and details to enable the Contract Administrator to determine the acceptability of the Plant, Material or method as either an approved equal or alternative;
 - (b) identify any and all changes required in the applicable Work, and all changes to any other Work, which would become necessary to accommodate the substitute;
 - (c) identify any anticipated cost or time savings that may be associated with the substitute;
 - (d) certify that, in the case of a request for approval as an approved equal, the substitute will fully perform the functions called for by the general design, be of equal or superior substance to that specified, is suited to the same use and capable of performing the same function as that specified and can be incorporated into the Work, strictly in accordance with the proposed work schedule and the dates specified in the Supplemental Conditions for Substantial Performance and Total Performance;
 - (e) certify that, in the case of a request for approval as an approved alternative, the substitute will adequately perform the functions called for by the general design, be similar in substance to that specified, is suited to the same use and capable of performing the same function as that specified and can be incorporated into the Work, strictly in accordance with the proposed work schedule and the dates specified in the Supplemental Conditions for Substantial Performance and Total Performance.
- B7.5 The Contract Administrator, after assessing the request for approval of a substitute, may in his/her sole discretion grant approval for the use of a substitute as an “approved equal” or as an “approved alternative”, or may refuse to grant approval of the substitute.

- B7.6 The Contract Administrator will provide a response in writing, at least two (2) Business Days prior to the Submission Deadline, to the Bidder who requested approval of the substitute.
- B7.6.1 The Contract Administrator will issue an Addendum, disclosing the approved materials, equipment, methods and products to all potential Bidders. The Bidder requesting and obtaining the approval of a substitute shall be responsible for disseminating information regarding the approval to any person or persons he/she wishes to inform.
- B7.7 If the Contract Administrator approves a substitute as an “approved equal”, any Bidder may use the approved equal in place of the specified item.
- B7.8 If the Contract Administrator approves a substitute as an “approved alternative”, any Bidder bidding that approved alternative may base his/her Total Bid Price upon the specified item but may also indicate an alternative price based upon the approved alternative. Such alternatives will be evaluated in accordance with B18.
- B7.9 No later claim by the Contractor for an addition to the Total Bid Price because of any other changes in the Work necessitated by the use of an approved equal or an approved alternative will be considered.

B8. BID COMPONENTS

- B8.1 The Bid shall consist of the following components:
- (a) Form A: Bid;
 - (b) Form B: Prices;
 - (c) Form G1: Bid Bond and Agreement to Bond.
- B8.2 All components of the Bid shall be fully completed or provided, and submitted by the Bidder no later than the Submission Deadline, with all required entries made clearly and completely.
- B8.3 The Bid shall be submitted electronically through MERX at www.merx.com.
- B8.3.1 Bids will **only** be accepted electronically through MERX.
- B8.4 Bidders are advised that inclusion of terms and conditions inconsistent with the Tender document, including the General Conditions, will be evaluated in accordance with B18.1(a).

B9. BID

- B9.1 The Bidder shall complete Form A: Bid/Proposal, making all required entries.
- B9.2 Paragraph 2 of Form A: Bid/Proposal shall be completed in accordance with the following requirements:
- (a) if the Bidder is a sole proprietor carrying on business in his/her own name, his/her name shall be inserted;
 - (b) if the Bidder is a partnership, the full name of the partnership shall be inserted;
 - (c) if the Bidder is a corporation, the full name of the corporation shall be inserted;
 - (d) if the Bidder is carrying on business under a name other than his/her own, the business name and the name of every partner or corporation who is the owner of such business name shall be inserted.
- B9.2.1 If a Bid is submitted jointly by two or more persons, each and all such persons shall identify themselves in accordance with B9.2.
- B9.3 In Paragraph 3 of Form A: Bid/Proposal, the Bidder shall identify a contact person who is authorized to represent the Bidder for purposes of the Bid.

- B9.4 Paragraph 13 of Form A: Bid/Proposal shall be signed in accordance with the following requirements:
- (a) if the Bidder is a sole proprietor carrying on business in his/her own name, it shall be signed by the Bidder;
 - (b) if the Bidder is a partnership, it shall be signed by the partner or partners who have authority to sign for the partnership;
 - (c) if the Bidder is a corporation, it shall be signed by its duly authorized officer or officers;
 - (d) if the Bidder is carrying on business under a name other than his/her own, it shall be signed by the registered owner of the business name, or by the registered owner's authorized officials if the owner is a partnership or a corporation.

B9.4.1 The name and official capacity of all individuals signing Form A: Bid/Proposal should be entered below such signatures.

B9.5 If a Bid is submitted jointly by two or more persons, the word "Bidder" shall mean each and all such persons, and the undertakings, covenants and obligations of such joint Bidders in the Bid and the Contract, when awarded, shall be both joint and several.

B10. PRICES

B10.1 The Bidder shall state a price in Canadian funds for each item of the Work identified on Form B: Prices.

B10.1.1 Prices stated on Form B: Prices shall not include any costs which may be incurred by the Contractor with respect to any applicable funding agreement obligations as outlined in D31. Any such costs shall be determined in accordance with D31.

B10.2 The quantities listed on Form B: Prices are to be considered approximate only. The City will use said quantities for the purpose of comparing Bids.

B10.3 The quantities for which payment will be made to the Contractor are to be determined by the Work actually performed and completed by the Contractor, to be measured as specified in the applicable Specifications.

B10.4 Payments to Non-Resident Contractors are subject to Non-Resident Withholding Tax pursuant to the Income Tax Act (Canada).

B10.5 The Bidder shall enter the Total Bid Price from Form B: Prices into the Total Bid Price field in MERX.

B10.5.1 Bidders are advised that the calculation indicated in B18.4 will prevail over the Total Bid Price entered in MERX.

B10.6 Form B: Prices is organized into Parts: Part 1 of the Work and Part 2 of the Work. Bidders shall provide a total price for each Part and, on the summary sheet, a Total Bid Price consisting of the sum of prices for Part 1 and Part 2.

B11. DISCLOSURE

B11.1 Various Persons provided information or services with respect to this Work. In the City's opinion, this relationship or association does not create a conflict of interest because of this full disclosure. Where applicable, additional material available as a result of contact with these Persons is listed below.

B11.2 The Persons are:

- (a) N/A

B12. CONFLICT OF INTEREST AND GOOD FAITH

B12.1 Further to C3.2, Bidders, by responding to this Tender, declare that no Conflict of Interest currently exists, or is reasonably expected to exist in the future.

B12.2 Conflict of Interest means any situation or circumstance where a Bidder or employee of the Bidder proposed for the Work has:

- (a) other commitments;
- (b) relationships;
- (c) financial interests; or
- (d) involvement in ongoing litigation;

that could or would be seen to:

- (i) exercise an improper influence over the objective, unbiased and impartial exercise of the independent judgment of the City with respect to the evaluation of Bids or award of the Contract; or
- (ii) compromise, impair or be incompatible with the effective performance of a Bidder's obligations under the Contract;
- (e) has contractual or other obligations to the City that could or would be seen to have been compromised or impaired as a result of its participation in the Tender process or the Work; or
- (f) has knowledge of confidential information (other than confidential information disclosed by the City in the normal course of the Tender process) of strategic and/or material relevance to the Tender process or to the Work that is not available to other bidders and that could or would be seen to give that Bidder an unfair competitive advantage.

B12.3 In connection with its Bid, each entity identified in B12.2 shall:

- (a) avoid any perceived, potential or actual Conflict of Interest in relation to the procurement process and the Work;
- (b) upon discovering any perceived, potential or actual Conflict of Interest at any time during the Tender process, promptly disclose a detailed description of the Conflict of Interest to the City in a written statement to the Contract Administrator; and
- (c) provide the City with the proposed means to avoid or mitigate, to the greatest extent practicable, any perceived, potential or actual Conflict of Interest and shall submit any additional information to the City that the City considers necessary to properly assess the perceived, potential or actual Conflict of Interest.

B12.4 Without limiting B12.3, the City may, in its sole discretion, waive any and all perceived, potential or actual Conflicts of Interest. The City's waiver may be based upon such terms and conditions as the City, in its sole discretion, requires to satisfy itself that the Conflict of Interest has been appropriately avoided or mitigated, including requiring the Bidder to put into place such policies, procedures, measures and other safeguards as may be required by and be acceptable to the City, in its sole discretion, to avoid or mitigate the impact of such Conflict of Interest.

B12.5 Without limiting B12.3, and in addition to all contractual or other rights or rights at law or in equity or legislation that may be available to the City, the City may, in its sole discretion:

- (a) disqualify a Bidder that fails to disclose a perceived, potential or actual Conflict of Interest of the Bidder or any of its employees proposed for the Work;
- (b) require the removal or replacement of any employees proposed for the Work that has a perceived, actual or potential Conflict of Interest that the City, in its sole discretion, determines cannot be avoided or mitigated;
- (c) disqualify a Bidder or employees proposed for the Work that fails to comply with any requirements prescribed by the City pursuant to B12.4 to avoid or mitigate a Conflict of Interest; and

- (d) disqualify a Bidder if the Bidder, or one of its employees proposed for the Work, has a perceived, potential or actual Conflict of Interest that, in the City's sole discretion, cannot be avoided or mitigated, or otherwise resolved.

B12.6 The final determination of whether a perceived, potential or actual Conflict of Interest exists shall be made by the City, in its sole discretion.

B13. QUALIFICATION

B13.1 The Bidder shall:

- (a) undertake to be in good standing under The Corporations Act (Manitoba), or properly registered under The Business Names Registration Act (Manitoba), or otherwise properly registered, licensed or permitted by law to carry on business in Manitoba; and
- (b) be financially capable of carrying out the terms of the Contract; and
- (c) have all the necessary experience, capital, organization, and equipment to perform the Work in strict accordance with the terms and provisions of the Contract.

B13.2 The Bidder and any proposed Subcontractor (for the portion of the Work proposed to be subcontracted to them) shall:

- (a) be responsible and not be suspended, debarred or in default of any obligations to the City. A list of suspended or debarred individuals and companies is available on the Information Connection page at The City of Winnipeg, Corporate Finance, Materials Management Division website at <https://www.winnipeg.ca/matmgt/Templates/files/debar.pdf>

B13.3 The Bidder and/or any proposed Subcontractor (for the portion of the Work proposed to be subcontracted to them) shall:

- (a) have successfully carried out work similar in nature, scope and value to the Work; and
- (b) be fully capable of performing the Work required to be in strict accordance with the terms and provisions of the Contract; and
- (c) have a written workplace safety and health program if required pursuant to The Workplace Safety and Health Act (Manitoba).

B13.4 Further to B13.3(c), the Bidder shall, within five (5) Business Days of a request by the Contract Administrator, provide proof satisfactory to the Contract Administrator that the Bidder/Subcontractor has a workplace safety and health program meeting the requirements of The Workplace Safety and Health Act (Manitoba), by providing:

- (a) Written confirmation of a safety and health certification meeting SAFE Work Manitoba's SAFE Work Certified Standard (e.g., COR™ and SECOR™) in the form of:
 - (i) a copy of their valid Manitoba COR certificate and Letter of Good Standing (or Manitoba equivalency) as issued under the Certificate of Recognition (COR) Program administered by the Construction Safety Association of Manitoba or by the Manitoba Heavy Construction Association's WORKSAFELY™ COR™ Program; or
 - (ii) a copy of their valid Manitoba SECOR™ certificate and Letter of Good Standing (or Manitoba equivalency) as issued under the Small Employer Certificate of Recognition Program (SECOR™) administered by the Construction Safety Association of Manitoba or by the Manitoba Heavy Construction Association's WORKSAFELY™ COR™ Program; or
- (b) a report or letter to that effect from an independent reviewer acceptable to the City. (A list of acceptable reviewers and the review template are available on the Information Connection page at The City of Winnipeg, Corporate Finance, Materials Management Division website at <http://www.winnipeg.ca/matmgt/>).

B13.5 The Bidder shall submit, within three (3) Business Days of a request by the Contract Administrator, proof satisfactory to the Contract Administrator of the qualifications of the Bidder and of any proposed Subcontractor.

B13.6 The Bidder shall provide, on the request of the Contract Administrator, full access to any of the Bidder's equipment and facilities to confirm, to the Contract Administrator's satisfaction, that the Bidder's equipment and facilities are adequate to perform the Work.

B14. BID SECURITY

B14.1 The Bidder shall include in its Bid Submission bid security in the form of a digital bid bond, in the amount of at least ten percent (10%) of the Total Bid Price, and agreement to bond of a company registered to conduct the business of a surety in Manitoba, in Form G1: Bid Bond and Agreement to Bond, available on The City of Winnipeg, Corporate Finance, Materials Management Division website at <https://www.winnipeg.ca/MatMgt/templates/files/eBidsecurity.pdf>.

B14.2 Bid security shall be submitted in a digital format meeting the following criteria:

- (a) The version submitted by the Bidder must have valid digital signatures and seals;
- (b) The version submitted by the Bidder must be verifiable by the City with respect to the totality and wholeness of the bond form, including: the content; all digital signatures and digital seals; with the surety company, or an approved verification service provider of the surety company.
- (c) The version submitted must be viewable, printable and storable in standard electronic file formats compatible with the City, and in a single file. Allowable formats include pdf.
- (d) The verification may be conducted by the City immediately or at any time during the life of the bond and at the discretion of the City with no requirement for passwords or fees.
- (e) The results of the verification must provide a clear, immediate and printable indication of pass or fail regarding B14.2(a).

B14.3 Bonds failing the verification process will not be considered to be valid and the bid shall be determined to be non-responsive in accordance with B18.1(a).

B14.4 Bonds passing the verification process will be treated as original and authentic.

B14.4.1 If the Bidder submits alternative bids, the bid security shall be in the amount of the specified percentage of the highest Total Bid Price submitted.

B14.5 The bid security of the successful Bidder and the next two lowest evaluated responsive and responsible Bidders will be released by the City when a Contract for the Work has been duly formed with the successful Bidder and the contract securities are furnished as provided herein. The bid securities of all other Bidders will be released when a Contract is awarded.

B14.6 The bid securities of all Bidders will be released by the City as soon as practicable following notification by the Contract Administrator to the Bidders that no award of Contract will be made pursuant to the Tender.

B15. OPENING OF BIDS AND RELEASE OF INFORMATION

B15.1 Bids will not be opened publicly.

B15.2 Following the submission deadline, the names of the Bidders and their Total Bid Prices (unevaluated, and pending review and verification of conformance with requirements) will be available on the MERX website at www.merx.com.

B15.3 After award of Contract, the name(s) of the successful Bidder(s) and their Contract amount(s) will be available on the MERX website at www.merx.com.

B15.4 The Bidder is advised that any information contained in any Bid may be released if required by The Freedom of Information and Protection of Privacy Act (Manitoba), by other authorities having jurisdiction, or by law or by City policy or procedures (which may include access by members of City Council).

B15.4.1 To the extent permitted, the City shall treat as confidential information, those aspects of a Bid Submission identified by the Bidder as such in accordance with and by reference to Part 2, Section 17 or Section 18 or Section 26 of The Freedom of Information and Protection of Privacy Act (Manitoba), as amended.

B16. IRREVOCABLE BID

B16.1 The Bid(s) submitted by the Bidder shall be irrevocable for the time period specified in Paragraph 11 of Form A: Bid/Proposal.

B16.2 The acceptance by the City of any Bid shall not release the Bids of the next two lowest evaluated responsive Bidders and these Bidders shall be bound by their Bids on such Work until a Contract for the Work has been duly formed and the contract securities have been furnished as herein provided, but any Bid shall be deemed to have lapsed unless accepted within the time period specified in Paragraph 11 of Form A: Bid/Proposal.

B17. WITHDRAWAL OF BIDS

B17.1 A Bidder may withdraw his/her Bid without penalty prior to the Submission Deadline.

B18. EVALUATION OF BIDS

B18.1 Award of the Contract shall be based on the following bid evaluation criteria:

- (a) compliance by the Bidder with the requirements of the Tender, or acceptable deviation therefrom (pass/fail);
- (b) qualifications of the Bidder and the Subcontractors, if any, pursuant to B13 (pass/fail);
- (c) Total Bid Price;
- (d) economic analysis of any approved alternative pursuant to B7.

B18.2 Further to B18.1(a), the Award Authority may reject a Bid as being non-responsive if the Bid is incomplete, obscure or conditional, or contains additions, deletions, alterations or other irregularities. The Award Authority may reject all or any part of any Bid, or waive technical requirements or minor informalities or irregularities, if the interests of the City so require.

B18.3 Further to B18.1(b), the Award Authority shall reject any Bid submitted by a Bidder who does not demonstrate, in his/her Bid or in other information required to be submitted, that he/she is qualified.

B18.4 Further to B18.1(c), the Total Bid Price shall be the sum of the quantities multiplied by the unit prices for each item shown on Form B: Prices.

B18.4.1 Further to B18.1(a), in the event that a unit price is not provided on Form B: Prices, the City may determine the unit price by dividing the Amount (extended price) by the approximate quantity, for the purposes of evaluation and payment.

B18.4.2 Bidders are advised that the calculation indicated in B18.4 will prevail over the Total Bid Price entered in MERX.

B19. AWARD OF CONTRACT

B19.1 The City will give notice of the award of the Contract or will give notice that no award will be made.

- B19.2 The City will have no obligation to award a Contract to a Bidder, even though one or all of the Bidders are determined to be qualified, and the Bids are determined to be responsive.
- B19.2.1 Without limiting the generality of B19.2, the City will have no obligation to award a Contract where:
- (a) the prices exceed the available City funds for the Work;
 - (b) the prices are materially in excess of the prices received for similar work in the past;
 - (c) the prices are materially in excess of the City's cost to perform the Work, or a significant portion thereof, with its own forces;
 - (d) only one Bid is received; or
 - (e) in the judgment of the Award Authority, the interests of the City would best be served by not awarding a Contract.
- B19.3 If funding for the Work is provided to the City of Winnipeg by the Government of Manitoba and/or the Government of Canada, Bidders are advised that the terms of D31 shall immediately take effect upon confirmation of such funding, regardless of when funding is confirmed.
- B19.4 Where an award of Contract is made by the City, the award shall be made to the qualified Bidder submitting the lowest evaluated responsive Bid, in accordance with B18.
- B19.4.1 Following the award of contract, a Bidder will be provided with information related to the evaluation of his/her Bid upon written request to the Contract Administrator.

PART C - GENERAL CONDITIONS

C0. GENERAL CONDITIONS

- C0.1 The *General Conditions for Construction* (Revision 2020-01-31) are applicable to the Work of the Contract.
- C0.1.1 The *General Conditions for Construction* are available on the Information Connection page at The City of Winnipeg, Corporate Finance, Materials Management Division website at http://www.winnipeg.ca/matmgt/gen_cond.stm
- C0.2 A reference in the Tender to a section, clause or subclause with the prefix “**C**” designates a section, clause or subclause in the *General Conditions for Construction*.

PART D - SUPPLEMENTAL CONDITIONS

GENERAL

D1. GENERAL CONDITIONS

D1.1 In addition to the General Conditions for Construction, these Supplemental Conditions are applicable to the Work of the Contract.

D2. FORM OF CONTRACT DOCUMENTS

D2.1 Notwithstanding C4.1(c) and C4.4, the Contract Documents will be provided to the Contractor electronically and there will be no requirement for execution and return to the City by the Contractor. Accordingly, the provisions under C4.4(a) and C4.4(b) are no longer applicable.

D3. SCOPE OF WORK

D3.1 The Work to be done under the Contract shall consist of two parts:

- (a) Part 1 – City Funded Work
- (b) Part 2 – Manitoba Hydro Funded Work.

Part 1 – City Funded Work

D3.2 Part 1 – City Funded Work shall consist of:

- (a) Asphalt Pavement Reconstruction
 - (i) Waterford Av - Pembina Hw/Lyon St
- (b) Pavement Rehabilitation
 - (i) Gerard St - River Av/End
 - (ii) Oakenwald Av - Wicklow St/Point Rd
 - (iii) Roslyn Rd - Osborne St/Roslyn Cr
 - (iv) Wardlaw Av - Scott St/Donald St
 - (v) Wardlaw Av - Scott St/Osborne St
- (c) Alley Renewal
 - (i) Jarvis Av/Dufferin Av Alley bounded by Jarvis Av/Dufferin Av/Powers St/Salter St.

Part 2 – Manitoba Hydro Funded Work

D3.3 Part 2 – Manitoba Hydro Funded Work shall consist of:

- (a) Street Lighting and Associated Works
 - (i) Waterford Av - Pembina Hw/Lyon St

D3.4 The City currently has no approved funding in the Capital Budget for Part 2 of the Work, but is anticipating receiving notification about funding from the Manitoba Hydro by the Award Date. Part 2 of the Work is contingent upon Manitoba Hydro approving sufficient funding.

D3.4.1 Further to C7.1, if notice of sufficient funding is not received, the City shall have the right to eliminate all or any portion of Part 2, and the Contract Price will be reduced accordingly.

D3.4.2 Further to C7.5, C7.5.1, and C7.6, a reduction in the Contract Price pursuant to D3.4.1 shall not be considered in calculating the aggregate reduction in the Contract Price for purposes of C7.5.

D3.4.3 If all or any portion of Part 2 is eliminated pursuant to D3.4.1, the time periods stipulated in D20 for Substantial Performance of the Work and in D21 for Total Performance of the Work will be reduced proportionally by the Contract Administrator acting reasonably.

D3.5 The major components of the Work are as follows:

(a) Asphalt Pavement Reconstruction:

- (i) Pavement Removal;
- (ii) Excavation;
- (iii) Placement of suitable site sub base material as required;
- (iv) Placement of geotextile fabric;
- (v) Placement of geogrid;
- (vi) Insulation of water services;
- (vii) Subgrade compaction;
- (viii) Placement of sub-base and base course material;
- (ix) Installation of Catch Basin and connecting pipes;
- (x) Installation of subdrains;
- (xi) Construction of barrier curb for asphalt pavements – utilizing slip form paving equipment for Waterford Avenue;
- (xii) Construction of modified barrier for asphalt pavements;
- (xiii) Construction of lip curb for asphalt pavements;
- (xiv) Construction of ramp curb for asphalt pavements;
- (xv) Placement and compaction of 50mm sub-base material as backfill behind barrier curb for asphalt pavement within excavated area;
- (xvi) Placement and compaction of suitable site material as backfill behind barrier curb for asphalt pavement within excavated area;
- (xvii) Installation of 150mm reinforced approach;
- (xviii) Sidewalk renewal;
- (xix) Installation of detectable warning surface tiles;
- (xx) Adjustment of precast sidewalk blocks;
- (xxi) Placement of asphalt pavement (Type III, 70mm thickness);
- (xxii) Placement of asphalt pavement (Type 1A, 50mm thickness);
- (xxiii) Adjustment of existing catch basins, manholes and appurtenances;
- (xxiv) Boulevard restoration and sod;
- (xxv) Street lighting improvement and associated works.

(b) Pavement Rehabilitation

- (i) Planing of existing asphalt as required;
- (ii) Renewal of existing sidewalk as required;
- (iii) Construction of concrete sidewalk;
- (iv) Installation of detectable warning surface tiles;
- (v) Installation of catch basin/catch pits and connection pipe;
- (vi) Abandon existing drainage inlets;
- (vii) Installation of catch pits and drainage connection pipes;
- (viii) Full-depth concrete repairs of existing joints and slabs;
- (ix) Planing/ Removal / Renewal of existing barrier curb as required;
- (x) Construction of modified barrier curb;
- (xi) Adjustment of precast sidewalk blocks;
- (xii) Adjustment of existing catch basins, manholes and appurtenances;
- (xiii) Placement of pavement repair fabric as required;
- (xiv) Placement of asphalt overlay;
- (i) Gerard St - River Av/End (average thickness 75mm)

- (ii) Oakenwald Av - Wicklow St/Point Rd (average thickness 90mm)
- (iii) Roslyn Rd - Osborne St/Roslyn Cr (average thickness 75mm)
- (iv) Wardlaw Av - Scott St/Donald St (average thickness 90mm)
- (v) Wardlaw Av - Scott St/Osborne St (average thickness 90mm)
- (xv) Boulevard restoration and sod.
- (c) Alley Renewal
 - (i) Remove existing concrete pavement;
 - (ii) Installation of land drainage pipe, manholes, catch basins and catch pits where required;
 - (iii) Removal of any existing manholes, catch basins and catch pits;
 - (iv) Land drainage sewer excavations jetted, flooded and tamped;
 - (v) Televiser new land drainage sewer pipe;
 - (vi) Excavation;
 - (vii) Compaction of sub-grade;
 - (viii) Placement of separation/reinforcement fabric;
 - (ix) Placement of geo-grid;
 - (x) Installation of subdrains;
 - (xi) Placement of sub-base granular B and base course granular B limestone materials;
 - (xii) Adjustments of existing watermain valves, manholes, catch basins, catch pit frame and covers;
 - (xiii) Construction of asphalt pavement mainline (125mm thickness) or construction of concrete pavement mainline (200mm);
 - (xiv) Construction of new concrete (reinforced) catch basin/manhole aprons and tees (150mm thickness);
 - (xv) Construction of new mainline concrete (reinforced) approaches (150mm thickness);
 - (xvi) Construction of new concrete barrier curbs in the alley where required;
 - (xvii) Renewal of existing residential approaches;
 - (xviii) Renewal of miscellaneous concrete slabs, curbs and sidewalk;
 - (xix) Final restorations.

D4. CONTRACT ADMINISTRATOR

D4.1 The Contract Administrator is WSP Canada Inc., represented by:

Scott Minty, P.Eng., M.Sc.
Senior Project Manager

Telephone No. 204-259-1578 Email Address Scott.Minty@wsp.com

D4.2 At the pre-construction meeting, Scott Minty, P.Eng., M.Sc. will identify additional personnel representing the Contract Administrator and their respective roles and responsibilities for the Work.

D5. CONTRACTOR'S SUPERVISOR

D5.1 At the pre-construction meeting, the Contractor shall identify his/her designated supervisor and any additional personnel representing the Contractor and their respective roles and responsibilities for the Work.

D5.2 At least two (2) Business Days prior to the commencement of any Work on the site, the Contractor shall provide the Contract Administrator with a phone number where the supervisor identified in D5.1 or an alternate can be contacted twenty-four (24) hours a day to respond to an emergency.

D6. NOTICES

- D6.1 Except as provided for in C22.4, all notices, requests, nominations, proposals, consents, approvals, statements, authorizations, documents or other communications to the Contractor shall be sent to the address or facsimile number identified by the Contractor in Paragraph 2 of Form A: Bid/Proposal.
- D6.2 All notices, requests, nominations, proposals, consents, approvals, statements, authorizations, documents or other communications to the City, except as expressly otherwise required in D6.3 or elsewhere in the Contract, shall be sent to the attention of the Contract Administrator identified in D4.
- D6.3 All notices, requests, nominations, proposals, consents, approvals, statements, authorizations, documents or other communications required to be submitted or returned to the City Solicitor shall be sent to the following facsimile number:
- The City of Winnipeg
Legal Services Department
Attn: Director of Legal Services
Facsimile No.: 204-947-9155

D7. FURNISHING OF DOCUMENTS

- D7.1 Upon award of the Contract, the Contractor will be provided with 'issued for construction' Contract Documents electronically, including Drawings in PDF format only.

SUBMISSIONS

D8. AUTHORITY TO CARRY ON BUSINESS

- D8.1 The Contractor shall be in good standing under The Corporations Act (Manitoba), or properly registered under The Business Names Registration Act (Manitoba), or otherwise properly registered, licensed or permitted by law to carry on business in Manitoba, or if the Contractor does not carry on business in Manitoba, in the jurisdiction where the Contractor does carry on business, throughout the term of the Contract, and shall provide the Contract Administrator with evidence thereof upon request.

D9. SAFE WORK PLAN

- D9.1 The Contractor shall provide the Contract Administrator with a Safe Work Plan at least five (5) Business Days prior to the commencement of any Work on the Site but in no event later than the date specified in C4.1 for the return of the executed Contract Documents, if applicable.
- D9.2 The Safe Work Plan shall be prepared and submitted in the format shown in the City's template which is available on the Information Connection page at The City of Winnipeg, Corporate Finance, Materials Management Division website at <http://www.winnipeg.ca/matmgt/safety/default.stm>
- D9.3 Notwithstanding B13.4 at any time during the term of the Contract, the City may, at its sole discretion and acting reasonably, require an updated COR Certificate or Annual Letter of good Standing. A Contractor, who fails to provide a satisfactory COR Certificate or Annual Letter of good Standing, will not be permitted to continue to perform any Work.

D10. INSURANCE

- D10.1 The Contractor shall provide and maintain the following insurance coverage:
- (a) commercial general liability insurance, in the amount of at least two million dollars (\$2,000,000.00) inclusive, with The City of Winnipeg added as an additional insured, with a cross-liability clause, such liability policy to also contain contractual liability,

unlicensed motor vehicle liability, non-owned automobile liability, broad form property damage cover and products and completed operations, to remain in place at all times during the performance of the Work and throughout the warranty period;

- (b) if applicable, Automobile Liability Insurance covering all motor vehicles, owned and operated and used or to be used by the Contractor directly or indirectly in the performance of the Work. The Limit of Liability shall not be less than \$2,000,000 inclusive for loss or damage including personal injuries and death resulting from any one accident or occurrence;
- (c) an all risks Installation Floater carrying adequate limits to cover all machinery, equipment, supplies and/or materials intended to enter into and form part of any installation.

D10.2 Deductibles shall be borne by the Contractor.

D10.3 The Contractor shall provide the City Solicitor with a certificate(s) of insurance, in a form satisfactory to the City Solicitor, at least two (2) Business Days prior to the commencement of any Work but in no event later than the date specified in the C4.1 for the return of the executed Contract Documents, as applicable.

D10.4 The Contractor shall not cancel, materially alter, or cause each policy to lapse without providing at least thirty (30) Calendar Days prior written notice to the Contract Administrator.

D11. CONTRACT SECURITY

D11.1 The Contractor shall provide and maintain the performance bond and the labour and material payment bond until the expiration of the warranty period in the form of:

- (a) a performance bond of a company registered to conduct the business of a surety in Manitoba, in the form attached to these Supplemental Conditions (Form H1: Performance Bond), in the amount of fifty percent (50%) of the Contract Price; and
- (b) a labour and material payment bond of a company registered to conduct the business of a surety in Manitoba, in the form attached to these Supplemental Conditions (Form H2: Labour and Material Payment Bond), in an amount equal to fifty percent (50%) of the Contract Price.

D11.1.1 Where the contract security is a performance bond, it may be submitted in hard copy or digital format. If submitted in digital format the contract security must meet the following criteria:

- (a) the version submitted by the Contractor must have valid digital signatures and seals;
- (b) the version submitted by the Contractor must be verifiable by the City with respect to the totality and wholeness of the bond form, including: the content; all digital signatures and digital seals; with the surety company, or an approved verification service provider of the surety company.
- (c) the version submitted must be viewable, printable and storable in standard electronic file formats compatible with the City, and in a single file. Allowable formats include pdf.
- (d) the verification may be conducted by the City immediately or at any time during the life of the bond and at the discretion of the City with no requirement for passwords or fees.
- (e) the results of the verification must provide a clear, immediate and printable indication of pass or fail regarding D11.1(c).

D11.1.2 Digital bonds failing the verification process will not be considered to be valid and may be determined to be an event of default in accordance with C18.1. If a digital bond fails the verification process, the Contractor may provide a replacement bond (in hard copy or digital format) within seven (7) Calendar Days of the City's request or within such greater period of time as the City in its discretion, exercised reasonably, allows.

- D11.1.3 Digital bonds passing the verification process will be treated as original and authentic.
- D11.2 The Contractor shall provide the City Solicitor with the required performance and labour and material payment bonds within seven (7) Calendar Days of notification of the award of the Contract by way of an award letter and prior to the commencement of any Work on the Site but in no event later than the date specified in C4.1 for the return of the executed Contract Documents, if applicable.
- D11.3 The Contractor shall, as soon as practicable after entering into a contract with a Subcontractor:
- (a) give the Subcontractor written notice of the existence of the labour and material payment bond in D11.1(b); and
 - (b) post a notice of the bond and/or a copy of that bond in a conspicuous location at the Site of the Work.

D12. SUBCONTRACTOR LIST

- D12.1 The Contractor shall provide the Contract Administrator with a complete list of the Subcontractors whom the Contractor proposes to engage (Form J: Subcontractor List) at or prior to a pre-construction meeting, or at least two (2) Business Days prior to the commencement of any Work on the Site but in no event later than the date specified in the C4.1 for the return of the executed Contract Documents, if applicable.

D13. DETAILED WORK SCHEDULE

- D13.1 The Contractor shall provide the Contract Administrator with a detailed work schedule at least two (2) Business Days prior to the commencement of any Work on the Site but in no event later than the date specified in the General Conditions for the return of the executed Contract Documents, as applicable.
- D13.2 If, prior to submitting the Detailed Work Schedule, the Contractor does not receive notification pursuant to D14.4 that all or some portion of Part 2 of the Work may be commenced, he/she shall complete the Detailed Work Schedule for only Part 1 of the Work assuming that, if all of Part 2 is eliminated, the time periods stipulated in D20 for Substantial Performance of the Work and in D21 for Total Performance of the Work will be reduced by five (5) Working Days.
- D13.3 If, after submitting the Detailed Work Schedule, the Contractor receives notification that all or any portion of Part 2 of the Work may be commenced, he/she shall submit a revised Detailed Work Schedule no later than two (2) Business Days from receipt of the notification.
- D13.4 The detailed work schedule shall consist of the following:
- (a) a critical path method (C.P.M.) schedule for the Work;
 - (b) a Gantt chart for the Work based on the C.P.M. schedule;
- all acceptable to the Contract Administrator.
- D13.5 Further to D13.4(b), the Gantt chart shall show the time on a weekly basis, required to carry out the Work of each trade, or specification division. The time shall be on the horizontal axis, and the type of trade shall be on the vertical axis.

SCHEDULE OF WORK

D14. COMMENCEMENT

- D14.1 The Contractor shall not commence any Work until he/she is in receipt of an award letter from the Award Authority authorizing the commencement of the Work.

- D14.2 The Contractor shall not commence any Work on the Site until:
- (a) the Contract Administrator has confirmed receipt and approval of:
 - (i) evidence of authority to carry on business specified in D8;
 - (ii) evidence of the workers compensation coverage specified in C6.15;
 - (iii) the twenty-four (24) hour emergency response phone number specified in D5.2.
 - (iv) the Safe Work Plan specified in D9;
 - (v) the Pedestrian and Cyclist Accessibility Plan specified in E26
 - (vi) evidence of the insurance specified in D10;
 - (vii) the contract security specified in D11;
 - (viii) the subcontractor list specified in D12;
 - (ix) the detailed work schedule specified in D13; and
 - (x) the direct deposit application form specified in D28
 - (b) the Contractor has attended a pre-construction meeting with the Contract Administrator, or the Contract Administrator has waived the requirement for a pre-construction meeting.
- D14.3 The Contractor shall commence the Work on the Site within seven (7) Working Days of receipt of the award letter.
- D14.4 The Contractor shall not commence Part 2 of the Work as described in D3 and identified in Form B: Prices, unless prior to award, he/she has received notification from the Contract Administrator that the City has received notice of sufficient funding from Manitoba Hydro.
- D14.5 The City intends to award this Contract by May 16, 2022.
- D14.5.1 If the actual date of award is later than the intended date, the dates specified for Critical Stages, Substantial Performance, and Total Performance will be adjusted by the difference between the aforementioned intended and actual dates.

D15. WORKING DAYS

- D15.1 Further to C1.1(tt);
- D15.1.1 The Contract Administrator will determine daily if a Working Day has elapsed and will record his/her assessment. On a weekly basis the Contract Administrator will provide the Contractor with a record of the Working Days assessed for the preceding week. The Contractor shall sign each report signifying that he/she agrees with the Contract Administrator's determination of the Working Days assessed for the report period.
- D15.1.2 Work done to restore the Site to a condition suitable for Work, shall not be considered "work" as defined in the definition of a Working Day.
- D15.1.3 When the Work includes two or more major types of Work that can be performed under different atmospheric conditions, the Contract Administrator shall consider all major types of Work in determining whether the Contractor was able to work in assessing Working Days.

D16. RESTRICTED WORK HOURS

- D16.1 Further to clause 3.10 of CW 1130, the Contractor shall require written permission forty-eight (48) hours in advance from the Contract Administrator for any work to be performed between 2000 hours and 0700 hours, or on Saturdays, Sundays, Statutory Holidays and or Civic Holidays.

D17. WORK BY OTHERS

- D17.1 Further to C6.25, the Contractor's attention is directed to the fact that other Contractors, the personnel of Utilities and the staff of the City may be working with in the project limit, approach roadway, adjacent roadways or right-of-way. The activities of these agencies may coincide with the Contractors execution of work and it will be the Contractor's responsibility to cooperate to the fullest extent with other personnel working in the area, and such cooperation is an obligation of the Contractor under the terms of Contract.
- D17.2 Work by others on or near the Site will include but not necessarily be limited to:
- (a) City of Winnipeg geomatics branch – various works survey monuments.
 - (b) BELLMTS – adjusting BELLMTS manhole frame at Wardlaw Av.
 - (c) Manitoba Hydro – adjusting Manitoba Hydro manhole frames at Roslyn Rd.
 - (d) Manitoba Hydro – electrical supply and inspection of new street lighting hardware (to be installed by the Contractor) and de-energizing and energizing of new street lights plant on Waterford Av.
 - (e) Condo development at 160 Osborne St, 424 Wardlaw Av and 425 Wardlaw. Works on Wardlaw Av will require staging and coordination directly with the Prime Contractor.
- D17.3 Further to D17.1 the Contractor shall cooperate and coordinate all activities with all parties performing required Work by Others. The Contractor must include and accommodate Work by Others identified in D17.2 or additional parties, in their construction schedule as per D13 and accommodate the necessary area on site required for the Work by Others to complete the Work.

D18. SEQUENCE OF WORK

- D18.1 Further to C6.1, the sequence of work shall comply with the following:
- D18.1.1 Providing that the Work on each street is completed in a similar order to the order that the Work was commenced in, the Contractor will be permitted to have a maximum of three (3) streets under construction at any one time. Completion of a street means that all of the necessary concrete, asphalt including approaches and landscaping work is completed to the satisfaction of the Contract Administrator.
- D18.1.2 Where the Contractor utilizes two (2) or more crews that work independently on the same major component of the Work as identified in D3, the Contract Administrator may approve an increase to the maximum number of streets under construction at any time.
- D18.1.3 Placing the topsoil and finished grading of all boulevard and median areas shall be completed prior to commencing construction of asphaltic concrete overlays, including scratch courses.
- D18.1.4 Planing of existing asphalt pavements will be completed lane at a time, with pavement repairs completed prior to planing of remaining lane(s).
- D18.1.5 Work on Oakenwald Av shall not commence before July 1, 2022 (school zone).
- D18.1.6 Work on Waterford Av shall not commence before July 1, 2022 (school zone).

D19. CRITICAL STAGES

- D19.1 The Contractor shall achieve critical stages of the Work in accordance with the following requirements:
- (a) Oakenwald Av
 - (i) Substantial Performance including placement of topsoil and sod, shall be achieved on or before August 31, 2022 (school zone).

(b) Waterford Av

- (i) Substantial Performance including placement of topsoil and sod, shall be achieved on or before August 31, 2022 (school zone).

D20. SUBSTANTIAL PERFORMANCE

- D20.1 The Contractor shall achieve Substantial Performance within fifty (50) consecutive Working Days of the commencement of the Work as specified in D14.
- D20.2 When the Contractor considers the Work to be substantially performed, the Contractor shall arrange, attend and assist in the inspection of the Work with the Contract Administrator for purposes of verifying Substantial Performance. Any defects or deficiencies in the Work noted during that inspection shall be remedied by the Contractor at the earliest possible instance and the Contract Administrator notified so that the Work can be re-inspected.
- D20.3 The date on which the Work has been certified by the Contract Administrator as being substantially performed to the requirements of the Contract through the issue of a certificate of Substantial Performance is the date on which Substantial Performance has been achieved.

D21. TOTAL PERFORMANCE

- D21.1 The Contractor shall achieve Total Performance within fifty-five (55) consecutive Working Days of the commencement of the Work as specified in D14.
- D21.2 When the Contractor or the Contract Administrator considers the Work to be totally performed, the Contractor shall arrange, attend and assist in the inspection of the Work with the Contract Administrator for purposes of verifying Total Performance. Any defects or deficiencies in the Work noted during that inspection shall be remedied by the Contractor at the earliest possible instance and the Contract Administrator notified so that the Work can be re-inspected.
- D21.3 The date on which the Work has been certified by the Contract Administrator as being totally performed to the requirements of the Contract through the issue of a certificate of Total Performance is the date on which Total Performance has been achieved.

D22. LIQUIDATED DAMAGES

- D22.1 If the Contractor fails to achieve Critical Stages, Substantial Performance or Total Performance in accordance with the Contract by the days fixed herein for same, the Contractor shall pay the City the following amounts per Working Day for each and every Working Day following the days fixed herein for same during which such failure continues:
- (a) Critical Stage D19.1 (a) Oakenwald Av- Three Thousand Five Hundred dollars (\$3,500.00);
 - (b) Critical Stage D19.1 (b) Waterford Av - Three Thousand Five Hundred dollars (\$3,500.00);
 - (c) Substantial Performance – Three Thousand Five Hundred dollars (\$3,500.00);
 - (d) Total Performance – Two Thousand dollars (\$2,000.00);
- D22.2 The amounts specified for liquidated damages in D22.1 are based on a genuine pre-estimate of the City's losses in the event that the Contractor does not achieve critical stages, Substantial Performance or Total Performance by the days fixed herein for same.
- D22.3 The City may reduce any payment to the Contractor by the amount of any liquidated damages assessed.

D23. COVID-19 SCHEDULE DELAYS

- D23.1 The City acknowledges that the schedule for this Contract may be impacted by the COVID-19 pandemic. Commencement and progress of the Work shall be performed by the Contractor with due consideration to the health and safety of workers and the public, directives from health authorities and various levels of government and in close consultation with the Contract Administrator.
- D23.2 If the Contractor is delayed in the performance of the Work by reason of the COVID-19 pandemic, the Work schedule may be adjusted by a period of time equal to the time lost due to such delay and costs related to such delay will be determined as identified herein.
- D23.3 A minimum of seven (7) Calendar Days prior to the commencement of Work, the Contractor shall declare whether COVID-19 will affect the start date. The Contractor shall provide sufficient evidence that the delay is directly related to COVID-19, including but not limited to evidence related to availability of staff, availability of Material or work by others.
- D23.4 For any delay related to COVID-19 and identified after Work has commenced, the Contractor shall within seven (7) Calendar Days of becoming aware of the anticipated delay declare the additional delay and shall provide sufficient evidence as indicated in D23.3. Failure to provide this notice will result in no additional time delays being considered by the City.
- D23.5 The Work schedule, including the durations identified in D16 to D21 where applicable, will be adjusted to reflect delays accepted by the Contract Administrator. No additional payment will be made for adjustment of schedules except where seasonal work, not previously identified in the Contract, is carried over to the following construction season.
- D23.6 Where Work not previously identified is being carried over solely as a result of delays related to COVID-19, as confirmed by the Contract Administrator, the cost of temporary works to maintain the Work in a safe manner until Work recommences, will be considered by the Contract Administrator. Where the Work is carried over only partially due to COVID-19, a partial consideration of the cost of temporary works will be considered by the Contract Administrator.
- D23.7 Any time or cost implications as a result of COVID-19 and in accordance with the above, as confirmed by the Contract Administrator, shall be documented in accordance with C7.

D24. SCHEDULED MAINTENANCE

- D24.1 The Contractor shall perform the following scheduled maintenance in the manner and within the time periods required by the Specifications:
- (a) Sod Maintenance as specified in CW 3510-R10
 - (b) Reflective Crack Maintenance as specified in CW 3250-R7
- D24.2 Determination of Substantial Performance and Total Performance shall be exclusive of scheduled maintenance identified herein. All scheduled maintenance shall be completed prior to the expiration of the warranty period. Where the scheduled maintenance cannot be completed during the warranty period, the warranty period shall be extended for such period of time as it takes the Contractor to complete the scheduled maintenance.

CONTROL OF WORK

D25. JOB MEETINGS

- D25.1 Regular weekly job meetings will be held at the Site. These meetings shall be attended by a minimum of one representative of the Contract Administrator, one representative of the City and one representative of the Contractor. Each representative shall be a responsible person capable of expressing the position of the Contract Administrator, the City and the Contractor respectively on any matter discussed at the meeting including the Work schedule and the need

to make any revisions to the Work schedule. The progress of the Work will be reviewed at each of these meetings.

D25.2 The Contract Administrator reserves the right to cancel any job meeting or call additional job meetings whenever he/she deems it necessary.

D26. PRIME CONTRACTOR – THE WORKPLACE SAFETY AND HEALTH ACT (MANITOBA)

D26.1 Further to C6.26, the Contractor shall be the Prime Contractor and shall serve as, and have the duties of the Prime Contractor in accordance with The Workplace Safety and Health Act (Manitoba).

D27. THE WORKPLACE SAFETY AND HEALTH ACT (MANITOBA) – QUALIFICATIONS

D27.1 Further to B13.4, the Contractor/Subcontractor must, throughout the term of the Contract, have a Workplace Safety and Health Program meeting the requirements of The Workplace Safety and Health Act (Manitoba). At any time during the term of the Contract, the City may, at its sole discretion and acting reasonably, require updated proof of compliance, as set out in B13.4.

MEASUREMENT AND PAYMENT

D28. PAYMENT

D28.1 Further to C12, the City shall make payments to the Contractor by direct deposit to the Contractor's banking institution, and by no other means. Payments will not be made until the Contractor has made satisfactory direct deposit arrangements with the City. Direct deposit application forms are at https://winnipeg.ca/finance/files/Direct_Deposit_Form.pdf.

WARRANTY

D29. WARRANTY

D29.1 Notwithstanding C13.2, the warranty period shall begin on the date of Substantial Performance and shall expire one (1) years thereafter for Rehabilitations, and two (2) years thereafter for pavement reconstruction works, unless extended pursuant to C13.2.1 or C13.2.2, in which case it shall expire when provided for thereunder.

DISPUTE RESOLUTION

D30. DISPUTE RESOLUTION

D30.1 The entire text of C21.4 is deleted, and amended to read: "Intentionally Deleted"

D30.2 The entire text of C21.5 is deleted, and amended to read:

- (a) If Legal Services has determined that the Disputed Matter may proceed in the Appeal Process, the Contractor must, within ten (10) Business Days of the date of the Legal Services Response Letter, submit his written Appeal Form, in the manner and format set out on the City's Materials Management Website, to the Chief Administrative Officer, and to the Contract Administrator. The Contractor may not raise any other disputes other than the Disputed Matter in his Appeal Form.

D30.3 Further to C21, prior to the Contract Administrator's issuance of a Final Determination, the following informal dispute resolution process shall be followed where the Contractor disagrees with any opinion, determination, or decision of the Contract Administrator ("Dispute"):

- (a) In the event of a Dispute, attempts shall be made by the Contract Administrator and the Contractor's equivalent representative to resolve Disputes within the normal course of

project dealings between the Contract Administrator and the Contractor's equivalent representative.

- (b) Disputes which in the reasonable opinion of the Contract Administrator or the Contractor's equivalent representative cannot be resolved within the normal course of project dealings as described above shall be referred to a without prejudice escalating negotiation process consisting of, at a minimum, the position levels as shown below and the equivalent Contractor representative levels:
- (i) The Contract Administrator;
 - (ii) Supervisory level between the Contract Administrator and applicable Department Head;
 - (iii) Department Head.

- D30.3.1 Names and positions of Contractor representatives equivalent to the above City position levels shall be determined by the Contractor and communicated to the City at the pre-commencement or kick off meeting.
- D30.3.2 As these negotiations are not an adjudicative hearing, neither party may have legal counsel present during the negotiations.
- D30.3.3 Both the City and the Contractor agree to make all reasonable efforts to conduct the above escalating negotiation process within twenty (20) Business Days, unless both parties agree, in writing, to extend that period of time.
- D30.3.4 If the Dispute is not resolved to the City and Contractor's mutual satisfaction after discussions have occurred at the final escalated level as described above, or the time period set out in D30.3.3, as extended if applicable, has elapsed, the Contract Administrator will issue a Final Determination as defined in C1.1(v), at which point the parties will be governed by the Dispute Resolution process set out in C21.

THIRD PARTY AGREEMENTS

D31. FUNDING AND/OR CONTRIBUTION AGREEMENT OBLIGATIONS

- D31.1 In the event that funding for the Work of the Contract is provided to the City of Winnipeg by the Government of Manitoba and/or the Government of Canada, the following terms and conditions shall apply, as required by the applicable funding agreements.
- D31.2 Further to D31.1, in the event that the obligations in D31 apply, actual costs legitimately incurred by the Contractor as a direct result of these obligations ("Funding Costs") shall be determined by the actual cost to the Contractor and not by the valuation method(s) outlined in C7.4. In all other respects Funding Costs will be processed in accordance with Changes in Work under C7.
- D31.3 For the purposes of D31:
- (a) "**Government of Canada**" includes the authorized officials, auditors, and representatives of the Government of Canada; and
 - (b) "**Government of Manitoba**" includes the authorized officials, auditors, and representatives of the Government of Manitoba.
- D31.4 Modified Insurance Requirements
- D31.4.1 If not already required under the insurance requirements identified in D10, the Contractor will be required to provide wrap-up liability insurance in an amount of no less than two million dollars (\$2,000,000) inclusive per occurrence. Such policy will be written in the joint names of the City, Contractor, Consultants and all sub-contractors and sub-consultants and include twelve (12) months completed operations. The Government of Manitoba and its Ministers, officers, employees, and agents shall be added as additional insureds.

- D31.4.2 If not already required under the insurance requirements identified in D10, the Contractor will be required to provide builders' risk insurance (including boiler and machinery insurance, as applicable) providing all risks coverage at full replacement cost, or such lower level of insurance that the City may identify on a case-by-case basis, such as an installation floater.
- D31.4.3 The Contractor shall obtain and maintain third party liability insurance with minimum coverage of two million dollars (\$2,000,000.00) per occurrence on all licensed vehicles operated at the Site. In the event that this requirement conflicts with another licensed vehicle insurance requirement in this Contract, then the requirement that provides the higher level of insurance shall apply.
- D31.4.4 Further to D10.3, insurers shall provide satisfactory Certificates of Insurance to the Government of Manitoba prior to commencement of Work as written evidence of the insurance required. The Certificates of Insurance must provide for a minimum of thirty (30) days' prior written notice to the Government of Manitoba in case of insurance cancellation.
- D31.4.5 All policies must be taken out with insurers licensed to carry on business in the Province of Manitoba.
- D31.5 Indemnification By Contractor
- D31.5.1 In addition to the indemnity obligations outlined in C17 of the General Conditions for Construction, the Contractor agrees to indemnify and save harmless the Government of Canada and the Government of Manitoba and each of their respective Ministers, officers, servants, employees, and agents from and against all claims and demands, losses, costs, damages, actions, suit or other proceedings brought or pursued in any manner in respect of any matter caused by the Contractor or arising from this Contract or the Work, or from the goods or services provided or required to be provided by the Contractor, except those resulting from the negligence of any of the Government of Canada's or the Government of Manitoba's Ministers, officers, servants, employees, or agents, as the case may be.
- D31.6 Records Retention and Audits
- D31.6.1 The Contractor shall maintain and preserve accurate and complete records in respect of this Contract and the Work, including all accounting records, financial documents, copies of contracts with other parties and other records relating to this Contract and the Work during the term of the Contract and for at least six (6) years after Total Performance. Those records bearing original signatures or professional seals or stamps must be preserved in paper form; other records may be retained in electronic form.
- D31.6.2 In addition to the record keeping and inspection obligations outlined in C6 of the General Conditions for Construction, the Contractor shall keep available for inspection and audit at all reasonable times while this Contract is in effect and until at least six (6) years after Total Performance, all records, documents, and contracts referred to in D31.6.1 for inspection, copying and audit by the City of Winnipeg, the Government of Manitoba and/or the Government of Canada and their respective representatives and auditors, and to produce them on demand; to provide reasonable facilities for such inspections, copying and audits, to provide copies of and extracts from such records, documents, or contracts upon request by the City of Winnipeg, the Government of Manitoba, and/or the Government of Canada and their respective representatives and auditors, and to promptly provide such other information and explanations as may be reasonably requested by the City of Winnipeg, the Government of Manitoba, and/or the Government of Canada from time-to-time.
- D31.7 Other Obligations
- D31.7.1 The Contractor consents to the City providing a copy of the Contract Documents to the Government of Manitoba and/or the Government of Canada upon request from either entity.
- D31.7.2 If the Lobbyists Registration Act (Manitoba) applies to the Contractor, the Contractor represents and warrants that it has filed a return and is registered and in full compliance

with the obligations of that Act, and covenants that it will continue to comply for the duration of this Contract.

- D31.7.3 The Contractor shall comply with all applicable legislation and standards, whether federal, provincial, or municipal, including (without limitation) labour, environmental, and human rights laws, in the course of providing the Work.
- D31.7.4 The Contractor shall properly account for the Work provided under this Contract and payment received in this respect, prepared in accordance with generally accepted accounting principles in effect in Canada, including those principles and standards approved or recommended from time-to-time by the Chartered Professional Accountants of Canada or the Public Sector Accounting Board, as applicable, applied on a consistent basis.
- D31.7.5 The Contractor represents and warrants that no current or former public servant or public office holder, to whom the Value and Ethics Code for the Public Sector, the Policy on Conflict of Interest and Post Employment, or the Conflict of Interest Act applies, shall derive direct benefit from this Contract, including any employment, payments, or gifts, unless the provision or receipt of such benefits is in compliance with such codes and the legislation.
- D31.7.6 The Contractor represents and warrants that no member of the House of Commons or of the Senate of Canada or of the Legislative Assembly of Manitoba is a shareholder, director or officer of the Contractor or of a Subcontractor, and that no such member is entitled to any benefits arising from this Contract or from a contract with the Contractor or a Subcontractor concerning the Work.

FORM H1: PERFORMANCE BOND
(See D11)

KNOW ALL MEN BY THESE PRESENTS THAT

_____ ,
(hereinafter called the "Principal"), and

_____ ,
(hereinafter called the "Surety"), are held and firmly bound unto **THE CITY OF WINNIPEG** (hereinafter called the "Obligee"), in the sum of

_____ dollars (\$_____)

of lawful money of Canada to be paid to the Obligee, or its successors or assigns, for the payment of which sum the Principal and the Surety bind themselves, their heirs, executors, administrators, successors and assigns, jointly and severally, firmly by these presents.

WHEREAS the Principal has entered into a written contract with the Obligee for

TENDER NO. 884-2021

2022 Local and Industrial Street and Alley Renewal Program – Waterford Av, Gerard St, Oakenwald Av and Various Locations
which is by reference made part hereof and is hereinafter referred to as the "Contract".

NOW THEREFORE the condition of the above obligation is such that if the Principal shall:

- (a) carry out and perform the Contract and every part thereof in the manner and within the times set forth in the Contract and in accordance with the terms and conditions specified in the Contract;
- (b) perform the Work in a good, proper, workmanlike manner;
- (c) make all the payments whether to the Obligee or to others as therein provided;
- (d) in every other respect comply with the conditions and perform the covenants contained in the Contract; and
- (e) indemnify and save harmless the Obligee against and from all loss, costs, damages, claims, and demands of every description as set forth in the Contract, and from all penalties, assessments, claims, actions for loss, damages or compensation whether arising under "The Workers Compensation Act", or any other Act or otherwise arising out of or in any way connected with the performance or non-performance of the Contract or any part thereof during the term of the Contract and the warranty period provided for therein;

THEN THIS OBLIGATION SHALL BE VOID, but otherwise shall remain in full force and effect. The Surety shall not, however, be liable for a greater sum than the sum specified above.

AND IT IS HEREBY DECLARED AND AGREED that the Surety shall be liable as Principal, and that nothing of any kind or matter whatsoever that will not discharge the Principal shall operate as a discharge or release of liability of the Surety, any law or usage relating to the liability of Sureties to the contrary notwithstanding.

IN WITNESS WHEREOF the Principal and Surety have signed and sealed this bond the

_____ day of _____, 20____.

SIGNED AND SEALED
in the presence of:

(Witness as to Principal if no seal)

(Name of Principal)

Per: _____ (Seal)

Per: _____

(Name of Surety)

By: _____ (Seal)
(Attorney-in-Fact)

FORM H2: LABOUR AND MATERIAL PAYMENT BOND
(See D11)

KNOW ALL MEN BY THESE PRESENTS THAT

his/its heirs, executors, administrators, successors or assigns (hereinafter called the "Principal"), and

his/its heirs, executors, administrators, successors or assigns (hereinafter called the "Surety"), are held and firmly bound unto **THE CITY OF WINNIPEG** (hereinafter called the "Obligee"), for the use and benefit of claimants as herein below defined, in the amount of

_____ dollars (\$_____)

of lawful money of Canada, for the payment whereof we, the Principal and the Surety jointly and severally bind ourselves firmly by these presents.

WHEREAS the Principal has entered into a written contract with the Obligee for

TENDER NO. 884-2021

2022 Local and Industrial Street and Alley Renewal Program – Waterford Av, Gerard St, Oakenwald Av and Various Locations

which is by reference made part hereof and is hereinafter referred to as the "Contract".

NOW THEREFORE the condition of the above obligation is such that if the Principal shall promptly make payment to all claimants as hereinafter defined, for all labour, service and material used or reasonably required for use in the performance of the Contract, then this obligation shall be void, otherwise it shall remain in full force and effect subject, however, to the following conditions:

- (a) A claimant is defined as one having a direct contract with the Principal for labour, service and material, or any of them, used or reasonably required for use in the performance of the contract, labour, service and material being construed to include that part of water, gas, power, light, heat, oil, gasoline, telephone service or rental of equipment (but excluding rent of equipment where the rent pursuant to an agreement is to be applied towards the purchase price thereof) directly applicable to the Contract;
- (b) The above-named Principal and Surety hereby jointly and severally agree with the Obligee that every claimant as herein defined, who has not been paid in full before the expiration of a period of ninety (90) days after the date on which the last of such claimant's work, labour or service was done or performed, or materials were furnished by such claimant, may sue on this bond, prosecute the suit to final judgment for such sum or sums as may be justly due claimant, and have execution thereon;
- (c) No suit or action shall be commenced hereunder by any claimant
 - (i) unless claimant shall have given written notice to the Principal and the Surety above-named, within one hundred and twenty (120) days after such claimant did or performed the last of the work, labour or service, or furnished the last of the materials for which said claim is made, stating with substantial accuracy the amount claimed and the name of the party to whom the materials were furnished, or for whom the work, labour or service was done or performed. Such notice shall be served by mailing the same by registered mail to the Principal, and Surety, at any place where an office is regularly maintained for the transaction of business, or served in any manner in which legal process may be served in the Province of Manitoba;

- (ii) after the expiration of one (1) year following the date on which Principal ceased work on said Contract; including work performed under the guarantees provided in the Contract;
 - (iii) other than in a court of competent jurisdiction in the Province of Manitoba.
- (d) The amount of this bond shall be reduced by and to the extent of any payment or payments made in good faith hereunder, inclusive of the payment by Surety of mechanics liens which may be filed of record against said improvement, whether or not claim for the amount of such lien be presented under and against this bond.
- (e) The Surety shall not be liable for a greater sum than the specified penalty of this bond.

The Principal and Surety hereby agree that The Guarantors' Liability Act (Manitoba) shall apply to this Bond.

IN TESTIMONY WHEREOF, the Principal has hereunto set its hand affixed its seal, and the Surety has caused these presents to be sealed and with its corporate seal duly attested by the authorized signature of its signing authority this

_____ day of _____, 20____.

SIGNED AND SEALED
in the presence of:

(Witness as to Principal if no seal)

(Name of Principal)

Per: _____ (Seal)

Per: _____

(Name of Surety)

By: _____ (Seal)
(Attorney-in-Fact)

FORM J: SUBCONTRACTOR LIST
(See D12)

2022 Local and Industrial Street and Alley Renewal Program – Waterford Av, Gerard St, Oakenwald Av
and Various Locations

<u>Portion of the Work</u>	<u>Name</u>	<u>Address</u>
SURFACE WORKS:		
<u>Supply of Materials:</u>		
Concrete		
Asphalt		
Separation Fabric		
Imported fill material		
Geo Grid		
Base Course & Sub-base		
Catch Basins & Catch Pits		
Frames & Covers		
Pipes & Fittings		
Pavement Repair Fabric		
Sod		
<u>Installation and Placement:</u>		
Concrete		
Asphalt		
Base Course & Sub-base		
Underground Works		

PART E - SPECIFICATIONS

GENERAL

E1. APPLICABLE SPECIFICATIONS AND DRAWINGS

- E1.1 These Specifications shall apply to the Work.
- E1.2 *The City of Winnipeg Standard Construction Specifications* in its entirety, whether or not specifically listed on Form B: Prices, shall apply to the Work.
- E1.2.1 *The City of Winnipeg Standard Construction Specifications* is available on the Information Connection page at The City of Winnipeg, Corporate Finance, Materials Management Division website at <http://www.winnipeg.ca/matmgt/Spec/Default.stm>
- E1.2.2 The version in effect three (3) Business Days before the Submission Deadline shall apply.
- E1.2.3 Further to C2.4(d), Specifications included in the Tender shall govern over *The City of Winnipeg Standard Construction Specifications*.
- E1.3 Bidders are reminded that requests for approval of substitutes as an approved equal or an approved alternative shall be made in accordance with B7. In every instance where a brand name or design specification is used, the City will also consider approved equals and/or approved alternatives in accordance with B7.
- E1.4 The following are applicable to the Work:

<u>Drawing No.</u>	<u>Drawing Name/Title</u>	<u>Drawing (Original) Sheet Size</u>
	Cover Sheet	A1
884-2021_Drawing_211-12618-00-01-RA	Gerard Street – From Alley to River Avenue, Minor Rehabilitation, Sta 0+99.42 to 2+25.92	A1
884-2021_Drawing_211-12618-00-02-RB	Oakenwald Street – From Wicklow St to Point Road, Asphalt Rehabilitation, Sta 0+93.90 to 1+85	A1
884-2021_Drawing_211-12618-00-03-RB	Oakenwald Street – From Wicklow St to Point Road, Asphalt Rehabilitation, Sta 1+85 to 3+15	A1
884-2021_Drawing_211-12618-00-04-RB	Oakenwald Street – From Wicklow St to Point Road, Asphalt Rehabilitation, Sta 3+15 to 4+20	A1
884-2021_Drawing_211-12618-00-05-RB	Oakenwald Street – From Wicklow St to Point Road, Asphalt Rehabilitation, Sta 4+20 to 5+40	A1
884-2021_Drawing_211-12618-00-06-RB	Oakenwald Street – From Wicklow St to Point Road, Asphalt Rehabilitation, Sta 5+40 to 6+25.21	A1
884-2021_Drawing_211-12618-00-07-RB	Roslyn Road – From Nassau St to Osborne St, Minor Rehabilitation, Sta 0+74.85 to 1+65	A1
884-2021_Drawing_211-12618-00-08-RB	Roslyn Road – From Nassau St to Osborne St, Minor Rehabilitation, Sta 1+65 to 2+60	A1
884-2021_Drawing_211-12618-00-09-RB	Roslyn Road – From Nassau St to Osborne St, Minor Rehabilitation, Sta 2+60 to 3+45.35	A1
884-2021_Drawing_211-12618-00-10-RB	Wardlaw Avenue – From Osborne St to Scott St, Major Rehabilitation, Sta 0+97.42 to 1+90	A1
884-2021_Drawing_211-12618-00-11-RB	Wardlaw Avenue – From Osborne St to Scott St, Major Rehabilitation, Sta 1+90 to 2+85	A1
884-2021_Drawing_211-12618-00-12-RB	Wardlaw Avenue – From Osborne St to Scott St, Major Rehabilitation, Sta 2+85 to 3+80	A1
884-2021_Drawing_211-12618-00-13-RB	Wardlaw Avenue – From Scott St to Donald St, Major Rehabilitation, Sta 0+80.09 to 1+80	A1
884-2021_Drawing_211-12618-00-14-RB	Wardlaw Avenue – From Scott St to Donald St, Major Rehabilitation, Sta 1+80 to 2+82.5	A1

<u>Drawing No.</u>	<u>Drawing Name/Title</u>	<u>Drawing (Original) Sheet Size</u>
884-2021_Drawing_211-12618-00-15-RB	Waterford Avenue – Pembina Hw to Lyon St, Asphalt Reconstruction, Sta 0+94.90 to 2+10	A1
884-2021_Drawing_211-12618-00-16-RB	Waterford Avenue – Pembina Hw to Lyon St, Asphalt Reconstruction, Sta 2+10 to 3+22.5	A1
884-2021_Drawing_211-12618-00-17-RB	Waterford Avenue – Pembina Hw to Lyon St, Asphalt Reconstruction, Sta 3+22.5 to 4+35	A1
884-2021_Drawing_211-12618-00-18-RB	Waterford Avenue – Pembina Hw to Lyon St, Asphalt Reconstruction, Sta 4+35 to 5+45	A1
884-2021_Drawing_211-12618-00-19-RB	Waterford Avenue – Pembina Hw to Lyon St, Asphalt Reconstruction, Sta 5+45 to 6+60	A1
884-2021_Drawing_211-12618-00-20-RB	Waterford Avenue – Pembina Hw to Lyon St, Asphalt Reconstruction, Sta 6+60 to 7+67.85	A1
884-2021_Drawing_1-04707-DE-50000-P36541 Preliminary	Waterford Avenue Streetlighting	A1

E2. MOBILIZATION AND DEMOBILIZATION PAYMENT

DESCRIPTION

- E2.1 This Specification shall cover all operations relating to the mobilization and demobilization of the Contractor to the project location(s).
- E2.2 The Work to be done by the Contractor under this Specification shall include the furnishing of all superintendence, overhead, labour, materials, equipment, tools, supplies, and all things necessary for and incidental to the satisfactory performance and completion of all Works as hereinafter specified.
- E2.3 The inclusion of a payment item for the Work under this Specification shall not release or reduce the responsibilities of the Contractor under any other specification in this Contract.

SCOPE OF WORK

- E2.4 Further to C12 of the General Conditions, where Mobilization and Demobilization is included as a bid item, it shall consist of the following, as applicable:
- (a) Mobilization shall include, but not be limited to:
 - (i) All activities and associated costs for transportation of the Contractor's personnel, equipment, and operating supplies to the site, and/or sites, and/or between sites;
 - (ii) Establishment of offices, buildings, other necessary general facilities and equipment parking/staging areas for the Contractor's operations at the site or sites;
 - (iii) Premiums paid for performance and payment bonds including coinsurance and reinsurance agreements as applicable;
 - (iv) General cleanup and housekeeping needed maintain a neat and orderly project site and/or sites;
 - (v) Development, and implementation of the Accessibility Site Plan as per E26;
 - (vi) Other job-related items.
 - (b) Demobilization shall include, but not be limited to:
 - (i) All activities and costs for transportation of personnel, equipment, and supplies not used in the project from the site, and/or sites, and/or between sites;
 - (ii) Disassembly, removal, and site cleanup and restoration of offices, buildings, and other facilities assembled on the site and/or sites;

- (iii) Repair of access roads, temporary haul roads, and equipment parking areas leaving the project site in the same or better condition than at the start of the project;
- (iv) General cleanup and housekeeping needed to restore a neat and orderly project site;
- (v) Monitoring, maintenance, and reporting of the Accessibility Site Plan as per E26.

E2.5 Access to the site, equipment parking, and staging areas are limited to that shown on the drawings or as approved by the Contract Administrator.

MEASUREMENT AND PAYMENT

E2.6 The lump-sum price for the Mobilization and Demobilization bid item shall not exceed five percent (5.00%) of the total bid price for the Contract.

E2.6.1 Further to B10, B18, C12 and E2.6, should the lump sum price exceed 5% of the Total Bid Price the lump sum price will be reduced to 5% of the Total Bid Price, the Total Bid Price will be determined using the reduced lump sum price and payment will be based on the reduced lump sum price.

E2.7 Payment for Mobilization:

- (a) 60% of the lump-sum price will be paid to the contractor for Mobilization on the first Progress Estimate for the Contract.

E2.8 Payment for Demobilization:

- (a) The remaining 40% of the lump-sum price will be paid upon:
 - (i) Restoration of the site and/or sites to the satisfaction of the Contract Administrator;
 - (ii) Distribution of the Declaration of Total Performance.

E2.9 Mobilization and Demobilization will be paid only once (to a maximum of 100%), regardless of the number of times the Contractor mobilizes to the site and/or sites.

E2.10 Pay Reduction for Accessibility Site Plan

- (a) The Demobilization payment will be reduced by the number of pay adjustments incurred in accordance with E26 and as determined by the Contract Administrator.

E3. GEOTECHNICAL REPORT

E3.1 Further to C3.1, the geotechnical report is provided to aid the Contractor's evaluation of the pavement structure and/or existing soil conditions. The geotechnical report is contained in Appendix 'A'.

E4. PROTECTION OF EXISTING TREES

E4.1 The Contractor shall take the following precautionary steps to prevent damage from construction activities to existing boulevard trees within the limits of the construction area:

- (a) The Contractor shall not stockpile materials and soil or park vehicles and equipment on boulevards within 2 metres of trees.
- (b) Trees identified to be at risk by the Contract Administrator are to be strapped with 25 x 100 x 2400mm wood planks, or suitably protected as approved by the Contract Administrator.
- (c) Excavation shall be performed in a manner that minimizes damage to the existing root systems. Where possible, excavation shall be carried out such that the edge of the excavation shall be a minimum of 1.5 times the diameter (measured in inches), with the outcome read in feet, from the closest edge of the trunk. Where roots must be cut to facilitate excavation, they shall be pruned neatly at the face of excavation.

- (d) Operation of equipment within the dripline of the trees shall be kept to the minimum required to perform the work required. Equipment shall not be parked, repaired, refuelled; construction materials shall not be stored, and earth materials shall not be stockpiled within the driplines of trees. The dripline of a tree shall be considered to be the ground surface directly beneath the tips of its outermost branches. The Contractor shall ensure that the operations do not cause flooding or sediment deposition on areas where trees are located.
- (e) Work on-site shall be carried out in such a manner so as to minimize damage to existing tree branches. Where damage to branches does occur, they shall be neatly pruned.

E4.2 All damage to existing trees caused by the Contractor's activities shall be repaired to the requirements and satisfaction of the Contract Administrator and the City Forester or his/her designate.

E4.3 No separate measurement or payment will be made for the protection of trees.

E4.4 Except as required in clause E4.1(c) and E4.1(e), Elm trees shall not be pruned at any time between April 1 and July 31.

E5. TRAFFIC CONTROL

E5.1 Further to clauses 3.6, 3.7 and 3.8 of CW 1130:

- (a) Where directed by the Contract Administrator, the Contractor shall construct and maintain temporary asphalt ramps to alleviate vertical pavement obstructions such as manholes and planing drop-offs to the satisfaction of the Contract Administrator. Payment shall be in accordance with CW3410.
- (b) In accordance with the Manual of Temporary Traffic Control on City Streets (MTTC), the Contractor ("Construction Agency" in the manual) shall be responsible for supplying, placing, maintaining and removing the appropriate temporary traffic control devices as specified by the MTTC, the Contract Drawings, Staging Plans, and Traffic Management Plans or by the Traffic Management Branch of the City of Winnipeg Public Works Department. The Contractor shall bear all costs associated with the supply, placement and maintenance of temporary traffic control devices by their own forces or subcontractor.
- (c) In addition, the contractor shall be responsible for removing, placing, and maintaining all regulatory signing including but not limited to:
 - (i) Parking restrictions,
 - (ii) Stopping restrictions,
 - (iii) Turn restrictions,
 - (iv) Diamond lane removal,
 - (v) Full or directional closures on a Regional Street,
 - (vi) Traffic routed across a median,
 - (vii) Full or directional closure of a non-regional street where there is a requirement for regulatory signs (turn restrictions, bus stop relocations, etc.) to implement the closure.
- (d) The Contractor shall remove and stockpile any regulatory signage not required during construction such as but not limited to parking restrictions, turn restrictions and loading restrictions.

E5.2 Further to E5.1(c) the Contractor shall make arrangements with the Traffic Services Branch of the City of Winnipeg to supply regulatory signs as required.

E5.3 Upon request from the Contract Administrator, the Contractor shall provide records demonstrating that the site has been maintained.

- E5.4 Further to E5.1(c) and E5.1(d) the Contractor shall make arrangements with the Traffic Services Branch of the City of Winnipeg to reinstall the permanent regulatory signs after the contract work is complete. At this time the contractor shall make arrangements to drop off the stockpiled materials to Traffic Services at 495 Archibald Street.
- E5.5 Any changes to the approved traffic management plan must be submitted to the Contract Administrator a minimum of 5 Working Days prior to the required change for approval.
- E5.6 If the Contract Administrator determines that the Contractor is not performing Traffic Control in accordance with this specification, Traffic Services may be engaged to perform the Traffic Control and the Contractor shall bear the costs associated by the Traffic Services Branch of the City of Winnipeg in connection with the works undertaken by the Contractor.

E6. TRAFFIC MANAGEMENT

- E6.1 Further to clause 3.7 of CW 1130:
- (a) Single lane closures on intersecting and/or adjoining Regional Streets shall only be permitted during non-peak periods when required for construction activities when approved by the Traffic Management Branch. Storage/parking of materials, equipment or vehicles is not permitted on Regional Streets at any time unless approved by the Contract Administrator, in consultation with the Traffic Management Branch.
- E6.1 Further to clause 3.7 of CW 1130:
- E6.1.1 The Contractor shall schedule construction activities to meet the following:
- (a) Gerard Street from River Av to End, Roslyn Rd from Osborne St to Roslyn Cr, Wardlaw Av from Scott St to Donald St, and Wardlaw Av from Scott St to Osborne St at least one lane for local access traffic shall be maintained along this street during construction. Intersecting streets and private approach access shall be maintained at all times.
 - (b) Oakenwald Av from Wicklow St to Point Rd at least one lane for local access traffic shall be maintained along this street during construction. At least one intersection on adjacent bays shall be open at a time. Private approach access shall be maintained at all times.
 - (c) Waterford Av from Pembina Hw to Lyon St will be closed to all traffic. The Contractor shall sign the street "Road Closed – No Exit" in accordance with the Manual of Temporary Traffic Control.
 - (d) Jarvis Av/Dufferin Av Alley bounded by Jarvis Av/Dufferin Av/Powers St/Salter St. North/South location will be closed to all traffic. The Contractor shall sign the street "Road Closed – No Exit" in accordance with the Manual of Temporary Traffic Control.
 - (e) Wardlaw Av from Scott St to Osborne St requires coordination with Prime Contractor of condo development at 160 Osborne St, 424 Wardlaw Av and 425 Wardlaw Av.
- E6.1.2 Should the Contractor be unable to maintain an existing access to a residence or business, he/she shall review the planned disruption with the business or residence and the Contract Administrator, and take reasonable measures to minimize the impact. The Contractor shall provide a minimum of 24 hours notification to the affected residence or business and the Contract Administrator, prior to disruption of access.
- E6.1.3 Pedestrian and ambulance/emergency vehicle access must be maintained at all times.

E7. REFUSE AND RECYCLING COLLECTION

- E7.1 While access to refuse and/or recycling collection vehicles is restricted, on collection day(s) the Contractor shall move all of the affected property owners refuse and/or recycling materials to a nearby common area, prior to an established time, in accordance with E7.2 to permit the normal collection vehicles to collect the materials. Immediately following recycling collection the Contractor shall return recycling receptacles to the addresses marked on the receptacles.

E7.2 Collection Schedule:

Gerard St - River Av/End.

Collection Day(s): **Monday (B)**
Collection Time: **7:00 a.m.**
Common Collection Area: **Collection back lane**

Oakenwald Av - Wicklow St/Point Rd.

Collection Day(s): **Wednesday (A)**
Collection Time: **7:00 a.m.**
Common Collection Area: **Collection back lane**

Roslyn Rd - Osborne St/Roslyn Cr.

Collection Day(s): **Monday (B)**
Collection Time: **7:00 a.m.**
Common Collection Area: **Collection back lane**

Wardlaw Av - Scott St/Donald St

Collection Day(s): **Monday (B)**
Collection Time: **7:00 a.m.**
Common Collection Area: **Collection back lane**

Wardlaw Av - Scott St/Osborne St

Collection Day(s): **Monday (B)**
Collection Time: **7:00 a.m.**
Common Collection Area: **Collection back lane**

Waterford Av - Pembina Hw/Lyon St

Collection Day(s): **Wednesday (A)**
Collection Time: **7:00 a.m.**
Common Collection Area: **Collection back lane**

Jarvis Av/Dufferin Av Alley bounded by Jarvis Av/Dufferin Av/Powers St/Salter St.

Collection Day(s): **Thursday (A)**
Collection Time: **7:00 am**
Common Collection Area: **Collection back lane. Contractor will be responsible for relocating bins.**

E7.3 No measurement or payment will be made for the work associated with this specification.

E8. PEDESTRIAN SAFETY

E8.1 During the project, the Contractor shall ensure that proper signage is in place during sidewalk construction to direct any pedestrians within the construction zone either around the construction or to the sidewalk on the opposite side of the street. The Contractor must also use proper signage, barricades, and temporary fencing to protect and keep pedestrians safely away from the construction area and open excavations to the satisfaction of the Contract Administrator. No measurement for payment shall be made for this work.

E9. WATER OBTAINED FROM THE CITY

E9.1 Further to clause 3.7 of CW 1120, the Contractor shall pay for all costs, including sewer charges, associated with obtaining water from the City in accordance with the Waterworks and Sewer By-laws.

E10. SURFACE RESTORATIONS

E10.1 Further to clause 3.3 of CW 1130, when Total Performance is not achieved in the year the Contract is commenced, the Contractor shall temporarily repair any Work commenced and not completed to the satisfaction of the Contract Administrator. The Contractor shall maintain the temporary repairs in a safe condition as determined by the Contract Administrator until permanent repairs are completed. The Contractor shall bear all costs associated with temporary repairs and their maintenance.

E11. INFRASTRUCTURE SIGNS

E11.1 The Contractor shall obtain infrastructure signs from the Traffic Services Sign Shop at 421 Osborne Street. The Contractor shall mount each sign securely to a rigid backing material approved by the Contract Administrator. The Contractor shall fasten each sign to a suitable support and erect and maintain one sign at each street as directed by the Contract Administrator. When the Contract Administrator considers the Work on the street complete, the Contractor shall remove and dispose of the signs and supports. No measurement for payment will be made for performing all operations herein described and all other items incidental to the work described

E12. PATCHING OF EXISTING PAVEMENT

DESCRIPTION

E12.1 General

E12.1.1 This specification covers patching of existing concrete pavement in preparation for an asphalt overlay.

E12.1.2 Referenced Standard Construction Specifications

(a) CW 3110 – Sub-Grade, Sub-Base and Base Course Construction.

(b) CW 3130 – Supply and Installation of Geotextile Fabrics.

(c) CW 3410 – Asphaltic Concrete Pavement Works.

MATERIALS

E12.2 Crushed Sub-Base Material

E12.2.1 Crushed Sub-base material will have a maximum aggregate size of 50 millimetre and be supplied in accordance with CW 3110.

E12.3 Geotextile Fabric

E12.3.1 Geotextile fabric will be supplied in accordance with Section 2 of CW 3130.

E12.4 Asphalt Material

- E12.4.1 Asphalt material will be Type 1A and will be supplied in accordance with Sections 5 and 6 of CW 3410.

CONSTRUCTION METHODS

E12.5 General

- E12.5.1 Remove existing concrete pavement to a minimum width of 1.5 metres at locations as shown on the Drawings or as directed by the Contract Administrator in accordance with Section 3.1 of Specification CW 3110.
- E12.5.2 Excavate to a depth of 350 millimetres below the top of the existing pavement.
- E12.5.3 Compact existing sub-grade to a minimum of 95% Standard Proctor Density.
- E12.5.4 Place geotextile fabric in accordance with Specification CW 3130.
- E12.5.5 Place and compact crushed sub-base material in accordance with CW 3110 to a 300 millimetres compacted depth. Compact to a minimum of 100% Standard Proctor Density.
- E12.5.6 Place and compact asphalt material to a 50 millimetres compacted depth matching the top of the existing concrete pavement. Compact to an average of 95% percent of the 75 Blow Marshall Density of the paving mixture with no individual test being less than 90% percent.
- E12.5.7 Each layer must be levelled and accepted by the Contract Administrator before the succeeding layer may be placed.
- E12.5.8 Additional excavation and placement of sub-base material beyond the identified pavement structure will be completed in accordance with CW 3110 as directed by the Contract Administrator.

MEASUREMENT AND PAYMENT

E12.6 Pavement Patching

- E12.6.1 Pavement patching will be measured on an area basis and paid for at the Contract Unit Price per square metre for "Pavement Patching". The area to be paid for will be the total number of square metres of pavement patched in accordance with this specification, accepted and measured by the Contract Administrator.

E13. SUPPLY AND INSTALLATION OF PAVEMENT REPAIR FABRIC

DESCRIPTION

E13.1 General

- E13.1.1 This specification covers the supply and installation of pavement repair fabrics for reinforcement of asphalt layers, distribution of loads, and reducing reflective cracking distresses.

E13.2 Definitions

- E13.2.1 Pavement Repair Fabric composed of fiberglass strands coated with an elastomeric polymer and formed into a grid structure.
- E13.2.2 Minimum Average Roll Value (MARV) is Property value calculated as typical minus two standard deviations. It shall yield a 97.7 percent degree of confidence that any sample taken during quality assurance testing will exceed the value reported.
- E13.2.3 Apertures are the open spaces formed between the interconnected network of longitudinal and transverse ribs of a fabric.
- E13.2.4 Type A Pavement Repair Fabric is composed of fiberglass strands coated with an elastomeric polymer and formed into a grid structure. It will be used for either localized

repair reinforcement (i.e. at joints and cracks) or full width asphalt reinforcement to minimizes both thermal and stress related reflective cracking.

E13.3 Referenced Standard Construction Specifications

E13.3.1 CW 3110 – Sub-Grade, Sub-Base and Base Course Construction

E13.3.2 CW 3410 – Asphaltic Concrete Pavement Works

E13.3.3 Approved Products for Surface Works

MATERIALS

E13.4 Approved Products

E13.4.1 Use only those materials listed as Approved Products for Surface Works. The Approved Products are available at the City of Winnipeg, Corporate Finance, Material Management Internet site at:

https://www.winnipeg.ca/finance/findata/matmgt/std_const_spec/current/Docs/Approved_Products_Surface_Works.pdf .

E13.5 Material Identification

E13.5.1 Pavement Repair Fabric shall be labelled in accordance with ASTM D4873/D4873M, and must clearly show the manufacturer name, product style number and roll number. Products without proper identification or labelling, mislabelling, or misrepresentation of materials shall be rejected.

E13.6 Storage and Handling

E13.6.1 Pavement Repair Fabric rolls shall be elevated off the ground and adequately covered to protect them from site construction damage, precipitation, any contamination of dirt or dust and any other deleterious materials.

E13.6.2 Pavement Repair Fabric rolls shall be protected from extended ultraviolet radiation including sunlight, chemicals that are strong acids or strong bases, flames including welding sparks, excess temperatures, and any other environmental conditions that may damage the physical properties of the fabric.

E13.6.3 Store and handle the Pavement Repair Fabric in accordance with the manufacturer's recommendations. Manufacturer's data sheets shall include preparation instructions and recommendations as well as storage and handling requirements and recommendations.

E13.7 Certification

E13.7.1 The Contractor shall provide Manufacturer's Mill Certificate and MARV Roll Data to the Contract Administrator prior to installation. The Certification shall state that the Pavement Repair Fabric meets MARV requirements as evaluated under the Manufacturer's quality control program. The Certification shall be attested to by a person having legal authority to bind the Manufacturer. The Pavement Repair Fabric shall be annually tested by accredited a third party testing facility.

E13.7.2 The Contractor shall provide a letter to the Contract Administrator stating the product name, manufacturer, style number, and other pertinent information to fully describe the Pavement Repair Fabric.

E13.7.3 All testing and data shall be in accordance with approved ASTM standards. Data reported in accordance with other standards will not be accepted.

E13.8 Pavement Repair Fabric Properties

E13.8.1 Pavement Repair Fabric shall consist of a high strength, fiberglass grid custom knitted and coated with an elastomeric polymer and self-adhesive glue with square or rectangular opening configurations.

E13.8.2 The axis with the least strength will be taken as the ultimate strength of the fabric for any given property.

E13.8.3 Type A Pavement Repair Fabric shall meet the requirements in Table CW 3140.1.

Table CW 3140.1 – Type A Pavement Repair Fabric Property Requirements

Physical Property	Machine Direction	Cross-Machine Direction	Test Method
Tensile Strength, Minimum	100 kN/m	100 kN/m	ASTM D 6637
Tensile Strength @ 2% Strain, Minimum	80 kN/m	80 kN/m	ASTM D 6637
Secant Stiffness EA at 2% Strain	4,000 kN/m	4,000 kN/m	ASTM D 6637
Elongation at Break, Maximum	3%		ASTM D 6637
Coating Softening Point, Minimum	150 °C		ASTM D 36
Coating Melting Point, Minimum	350 °C		ASTM D 276
Glass Melting Point, Minimum	820 °C		ASTM D 338
Mass/Unit Area, Minimum	420 g/m ²		ASTM D 5261

E13.8.4 All physical property requirements are Minimum Average Roll Values (MARV) determined in accordance with ASTM 4759. Values not labelled as MARV will not be accepted.

E13.8.5 Aperture sizes shall be as follows:

- i. Between 10 mm and 14 mm for pavement repair fabric immediately below or within Type 1A asphalt layer.
- ii. Between 19 mm and 25.4 mm for pavement repair fabric immediately below or within Type III asphalt layer.

E13.8.6 If the fabric has a rectangular aperture size, the smaller dimension shall be used to establish the suitable Pavement Repair Fabric.

CONSTRUCTION METHODS

- E13.9 Pavement Repair Fabric shall not be placed when weather conditions, in the opinion of the Contract Administrator, are not suitable for installation including heavy rainfall, extreme cold or frost conditions, or extreme heat.
- E13.10 Make all repairs as required prior to placement of Pavement Repair Fabric. Seal cracks and fill holes using a method that provides a proper level surface. Receiving surface shall be smooth, with the existing cracks pretreated.
- E13.11 Surfaces shall be mechanically cleaned by sweeping and vacuuming and be free of oil, vegetation, sand, dirt, water, gravel, and other contaminants prior to placement of Pavement Repair Fabric.
- E13.12 Pavement Repair Fabric placement should not be undertaken if rain is likely to fall prior to covering the fabric with an asphalt mat overlay. Pavement Repair Fabric that is placed and will not adhere due to moisture shall be removed and replaced at the Contractor's expense.
- E13.13 Pavement Repair Fabric shall be laid out by mechanical means or by hand using sufficient pressure to eliminate ripples. Remove any ripples by pulling the fabric tight. Cutting of the fabric may be permitted on tight radii to prevent ripples.
- E13.14 Transverse joints shall be overlapped 75 mm or as recommended by the manufacturer, whichever is greater. Longitudinal joints shall be overlapped 37.5 mm or as recommended by the manufacturer, whichever is greater.
- E13.15 Prior to the asphalt topping placement, the fabric shall be inspected by the Contract Administrator for damage during installation. Damaged fabric shall be removed and replaced at the Contractor's expense.
- E13.16 Activate self-adhesive glue by rolling with a rubber coated drum roller or a pneumatic tire roller. In no instance shall steel-wheeled or vibratory rollers be used. Rolling shall continue until the adhesive is activated and the fabric is bonded to the leveling course.
- E13.17 Roller tires shall be kept clean to the satisfaction of the Contract Administrator.
- E13.18 If bonding of the fabric is not readily achieved, it shall be removed and replaced at the Contractor's expense.
- E13.19 Pavement Repair Fabric shall be laid and rolled over ironworks (e.g., manhole covers). Once the fabric has been rolled, those portions covering the ironworks shall be removed by cutting the fabric with a utility knife or other methods approved by the Contract Administrator.
- E13.20 Protect the Pavement Repair Fabric until placement of the finished asphalt topping.
- E13.21 Where a tack coat or emulsified asphalt is specified, the approved tack coat/emulsion and dose should be used as recommended by the manufacturer in conjunction with the Pavement Repair Fabric. Tack coat or emulsified asphalts shall not be diluted. Unless otherwise recommended by the manufacturer, apply tack coat or emulsified asphalt at the rate of 0.35 liters per square meter of surface area.
- E13.22 Where tack coat or emulsified asphalt is placed prior to the fabric, it must fully cure prior to placement of the fabric. Where tack coat or emulsified asphalt is placed after the fabric, it must fully cure prior to construction traffic, including paving, travelling on the surface.
- E13.23 Prevent spattering of tack coat or emulsified asphalt when placed adjacent to curbs, gutters, structures and other adjacent surfaces. Clean any surfaces where it has been contaminated by the tack coat or emulsified asphalt.
- E13.24 Leveling course or overlay layer shall be a minimum thickness of 40 mm. Place and compact asphalt over the Pavement Repair Fabric in accordance with CW 3410.

QUALITY ASSURANCE TESTING

E13.25 The Contract Administrator shall test the adhesion for pavement repair fabric in field during construction is as follows:

- E13.25.1 Place approximately 1 m² of fabric on a prepared surface that is representative of the project conditions.
- E13.25.2 Activate self-adhesive glue by rolling with a rubber-tired roller or by applying adequate pressure to fully activate the pressure-sensitive adhesive.
- E13.25.3 Use a calibrated spring balance by inserting the hook of the balance under the centre of the fabric and pulling upward until the fabric starts to pull away from the surface.
- E13.25.4 A 9 kg pull is required without pulling the grid free or creating ripples in the fabric.

E13.26 The minimum frequency shall be one test, then test every 2000 square meters.

MEASUREMENT AND PAYMENT

- E13.27 Supply and installation of Pavement Repair Fabric will be measured on an area basis and paid for at the Contract Unit Price per square metre for "Supply and Install Pavement Repair Fabric". The area to be paid for will be the total number of square metres of Pavement Repair Fabric, supplied and installed in accordance with this specification, accepted and measured by the Contract Administrator.
- E13.28 Only material placed within the designated limits will be included in the payment for "Supply and Install Pavement Repair Fabric".
- E13.29 No measurement or payment will be made for Pavement Repair Fabric removed and replaced due to improper installation or damaged materials.
- E13.30 No measurement or payment will be made for transverse and longitudinal overlap.

E14. PARTIAL DEPTH PATCHING OF EXISTING JOINTS

DESCRIPTION

- E14.1 General
 - E14.1.1 This specification covers the Partial Depth Patching of existing concrete pavement joints.
- E14.2 Referenced Standard Construction Specifications
 - (a) CW 3230 – Full-Depth Patching of Existing Slabs and Joints
 - (b) CW 3410 – Asphalt Concrete Pavement Works

MATERIALS

- E14.3 Asphalt Materials
 - E14.3.1 Asphalt material will be Type 1A supplied in accordance with Sections 5 and 6 of CW 3410.
- E14.4 Tack Coat
 - E14.4.1 Tack Coat will be undiluted SS-1 emulsified asphalt.

CONSTRUCTION METHODS

- E14.5 Planing of Joints
 - E14.5.1 Plane existing joints designated by the Contract Administrator to a minimum depth of 50 mm and a maximum of depth 90 mm to remove ravelled or deteriorated concrete. Width of joint to be planed will vary with depth.
 - E14.5.2 Should the depth of joint deterioration exceed the maximum indicated, as determined by the Contract Administrator, the entire joint shall be renewed and paid for in accordance with

CW 3230 as a full depth joint repair. Planing completed shall be paid for in accordance with Section E14.7 of this specification.

E14.5.3 Dispose of material in accordance with Section 3.4 of CW 1130.

E14.6 Placement of Asphalt Material

E14.6.1 Prior to placement of asphalt material, the planed joint shall be swept or blow clean of any loose material.

E14.6.2 Apply Tack Coat uniformly on the entire surface of the planed joint. The application rate shall not exceed 0.23 litres per square metre. The planed joint shall be dry prior to applying the tack coat.

E14.6.3 Place and compact asphalt material in accordance with Section 9.3 of CW 3410 to the satisfaction of the Contract Administrator. The finished elevation of the patch shall be flush with surrounding pavement surface.

E14.6.4 Compact the asphalt material to an average 95% of the 75 blow Marshall Density of the paving mixture with no individual test being less than 90 %.

E14.6.5 Ensure that no traffic is allowed to travel over the patched area until the asphalt has cooled to atmospheric temperature.

MEASUREMENT AND PAYMENT

E14.7 Partial Depth Planing of Existing Joints

E14.7.1 Partial Depth Planing of Existing Joints will be measured on an area basis and paid for at the Contract Unit Price per square metre for "Partial Depth Planing of Existing Joints". The area to be paid for will be the total number of square metres of joints planed in accordance with this specification, accepted and measured by the Contract Administrator.

E14.8 Asphalt Patching of Partial Depth Joints

E14.9 Asphalt Patching of Partial Depth Joints will be measured on an area basis and paid for at the Contract Unit Price per square metre for "Asphalt Patching of Partial Depth Joints". The area to be paid for will be the total number of square metres of joints patched in accordance with this specification, accepted, and measured by the Contract Administrator.

E15. SUPPLY AND INSTALL WATERMAIN AND WATER SERVICE INSULATION

DESCRIPTION

E15.1 Notwithstanding 3.12 of CW 2110, this specification covers the supply and installation of insulation in roadway excavations over watermains and water services.

E15.2 Referenced Standard Construction Specifications

- (a) CW 2030 – Excavation Bedding and Backfill
- (b) CW 3110 – Sub –grade, Sub-base and Base Course Construction

E15.3 Referenced Standard Details

- (a) SD-018 - Watermain and Water Service Insulation

MATERIALS

E15.4 Acceptable insulation is:

- (a) Extruded Polystyrene rigid foam insulation – Type 4, 4" in thickness.
 - DOW - Roofmate or Highload 40
 - Owen's Corning - Foamular 350 or Foamular 400.

2" X 48" X 96", 2" X 24" X 96", 4" X 24" X 96"

E15.5 Sand Bedding :

- (a) In accordance with CW 2030

CONSTRUCTION METHODS

E15.6 Prior to the installation of any sub-base material or geotextile material, locate all existing water services. Further to SD-018, where directed by the Contract Administrator, excavate the sub-grade to allow the top of the insulation to be installed flush with the surrounding sub-grade. Install the insulation on a level surface centered over the located watermain or water service for the full width of the roadway excavation. Install sand bedding if required to level the surface. Stockpile and dispose of excavated material in accordance with CW 3110.

E15.7 Thickness of insulation is 100 mm (4"). If using 50 mm (2") panels 2 layers are required. Total width of insulation to be as directed by the Contract Administrator. Place sufficient full width panels to meet or exceed the specified width.

E15.8 Place insulation panels adjacent to each other over the specified area with no gaps between panels and less than 15mm of elevation difference along the adjoined edges. Where 2" thick panels are being used, offset the top layer to prevent the panel joints from aligning with the joints in the lower layer.

E15.9 Use full panels of insulation where possible. Where necessary cut insulation panels to obtain coverage to specified lengths. Insulation pieces shall be a minimum of dimension of 300 mm in width or length.

E15.10 Take appropriate measures to ensure panels are not displaced when installing geotextiles and during backfilling operations.

MEASUREMENT AND PAYMENT

E15.11 Watermain and Water Service Insulation shall be measured on an area basis and paid for at the Contract Unit Price per square metre of "Watermain and Water Service Insulation". The area to be paid for shall be the total square meters of watermain and water service insulation supplied and installed in accordance with this specification, accepted and measured by the Contract Administrator.

- (a) Excavation of the roadway subgrade in accordance with E15.6 will not be measured for payment and will be included in the payment for "Watermain and Water Service Insulation".

E16. ADJUSTMENT OF SPRINKLER HEADS AND/OR DRAINAGE PIPE

DESCRIPTION

E16.1 Further to CW 3210, this Specification covers the adjustment of existing sprinkler heads and/or drainage pipe within the City of Winnipeg right-of-way to match proposed boulevard grading requirements.

MATERIALS

E16.2 Sprinkler Heads and Irrigation Pipe

E16.2.1 If, in the opinion of the Contract Administrator new irrigation piping is required it shall be Series 100, High Density Polyethylene pipe and conform to CSA B137.0 and B137.1, CGSB-41-GP-25m and ASTM D-1248-78. Fittings shall be approved brass saddle fittings at head connections and socket-fusion external fittings at pipe connections. All fittings will be sized to fit pipe diameter and of a pressure rating equal to or better than adjacent pipe. Three elbow swing joints shall be unplasticized schedule 80 threaded PVC pipe and schedule 40 fittings.

CONSTRUCTION METHODS

- E16.3 Contractor to locate and mark existing sprinkler heads and irrigation piping prior to undertaking any excavations of boulevards.
- E16.4 Contractor shall verify with Contractor Administrator that existing sprinkler heads and piping are functional prior to any grade adjustments.
- E16.5 Raise or lower existing sprinkler leads and relocate up to 2.0 metres to match finished grade of grassed area. Ensure sprinkler head is plumb and maintain existing sprinkler head direction.
- E16.6 Adjust existing irrigation lines to maintain existing cover requirements. The Contractor may be required to lower or raise irrigation lines or supplement with additional length of pipe. Pipe material to match or exceed existing pipe material.
- E16.7 Contractor is responsible to replace any damaged sprinkler heads or irrigation lines as a result of construction activities.
- E16.8 Upon completion of adjustments after final acceptance of sodded areas, the Contractor shall arrange for the inspection sprinkler heads and irrigation system with the Contract Administrator to ensure proper functioning of system.
- E16.9 Contractor to repair any deficiencies to the satisfaction of the Contract Administrator.

MEASUREMENT AND PAYMENT

- E16.10 Adjustment of Sprinkler Heads and/or Drainage Pipe
 - E16.10.1 Adjustments of existing sprinkler heads and/or drainage pipe will be measure on a unit basis and paid for at the Contract Unit Price per unit for "Adjustment of Sprinkler Head and/or Drainage Pipe". The number of units to be paid for will be the total number of sprinkler heads and/or drainage pipe adjusted in accordance with this specification, accepted and measured by the Contract Administrator.
- E16.11 Replace Existing Sprinkler Pipe
 - E16.11.1 Replacement of existing sprinkler pipe will be measured on a linear metre basis and paid for at the Contract Unit Price for "Replace Existing Sprinkler Pipe". The length to be paid for shall be the total number of metres of pipe supplied and installed in accordance with this Specification, accepted and measured by the Contract Administrator.

E17. HYDRO EXCAVATION

DESCRIPTION

- E17.1 This specification shall cover the works and locations as directed by the contract administrator for the removal of earthen material immediately adjacent to underground utilities infrastructure by means of high pressure water spray, and the recovery of excavated material by vacuum type means or equivalent method as approved by the Contract Administrator.

EQUIPMENT

- E17.2 Hydro-Excavation equipment shall be capable of maintaining a minimum working pressure of 10,000 psi, at a rate of flow of 10 to 12 gallons per minute. The unit should be adjustable, so as to provide adequate pressure to remove earthen material identified by the Contract Administrator.
- E17.3 Spray head shall be equipped with a rotating type nozzle in order to provide a wider path of cut.

CONSTRUCTION METHODS

- E17.4 Hydro-Removal of Earthen Material

E17.4.1 Earthen material adjacent to utility entity shall be sprayed with high pressure water so as to remove all such material identified by the Contract Administrator.

E17.5 Recovery of Excavated Material

E17.5.1 The recovery of excavated material shall be done using a vacuum type method, or other type method as approved by the Contract Administrator.

E17.5.2 The recovery of material shall follow immediately behind the excavation, to avoid excavated areas from filling with excavated material.

E17.5.3 The use of mechanical sweepers will not be allowed.

E17.5.4 Dispose of material in accordance with Section 3.4 of CW 1130-R2.

MEASUREMENT AND PAYMENT

E17.6 Hydro-Excavation

E17.6.1 Hydro-Excavation of earthen material and its recovery and disposal will be paid for at the Contract Unit Price per hour for "Hydro Excavation", which price shall be payment in full for completing all operations herein described and all other items incidental to the work included in this Specification.

E18. SOFT EXCAVATION TO EXPOSE UNDERGROUND UTILITIES

E18.1 Description

E18.1.1 This specification covers the soft excavation to expose underground utilities to determine the depth of the underground utility and whether it will interfere with the installation of proposed Works on site.

E18.1.2 These underground utilities include, but are not limited to, Manitoba Hydro cables, MTS cables, CPR, existing sewers, and existing watermains.

E18.2 Materials

E18.2.1 Backfill Material

(a) Backfill material for backfill of shafts after hydro-excavation has been completed shall consist of sand as per City of Winnipeg Standard Construction Specification CW 2030.

E18.3 Construction Methods

E18.3.1 Prior to commencement of any construction works adjacent to underground utilities, the Contractor shall use soft digging or hand excavation to expose the underground utilities.

E18.3.2 Once the elevation of the top of the pipe or duct has been determined the resulting excavation shall be backfilled with bedding sand to the elevation of the existing ground.

E18.4 Measurement and Payment

E18.4.1 Soft excavation to expose underground utilities will be considered incidental to the Work. No measurement and payment will be made within this section.

E19. CONCRETE CONSTITUENT MATERIALS, MIX DESIGN REQUIREMENTS, AND HOT AND COLD WEATHER CONCRETING

DESCRIPTION

E19.1 General

- E19.1.1 PORTLAND CEMENT CONCRETE PAVEMENT WORKS shall be in accordance with CW3310-R17, PORTLAND CEMENT CONCRETE PAVEMENT WORKS, except as otherwise specified herein.
- E19.1.2 This specification covers Portland cement concrete constituent materials and design requirements for the preparation of Portland Cement Concrete for all concreting operations relating to the construction of pavements, curbs, gutters, private approaches, bull-noses, median slabs, median, safety median and boulevard splash strips, sidewalk and other related concrete works.
- E19.1.3 This specification also covers hot and cold weather concreting.
- E19.1.4 Replace 2.0 Definitions of CW 3310-R17, PORTLAND CEMENT CONCRETE PAVEMENT WORKS with 1.2 of this specification.
- E19.1.5 Replace 5.3 Portland Cement Concrete Constituent Materials of CW 3310-R17, PORTLAND CEMENT CONCRETE PAVEMENT WORKS with 2.0 MATERIALS of this specification.
- E19.1.6 Replace 6.0 Design Requirements of CW 3310-R17, PORTLAND CEMENT CONCRETE PAVEMENT WORKS with 3.0 DESIGN REQUIREMENTS of this specification.
- E19.1.7 Replace 9.8. Weather Conditions of CW 3310-R17, PORTLAND CEMENT CONCRETE PAVEMENT WORKS with 4.0 HOT AND COLD WEATHER CONCRETING of this specification.
- E19.1.8 Replace 13.0 Basis of Payment of CW 3310-R17, PORTLAND CEMENT CONCRETE PAVEMENT WORKS with 5.1 BASIS OF PAYMENT FOR CW 3310-R17 of this specification.
- E19.1.9 Replace 13.0 Basis of Payment of CW 3230-R8, FULL-DEPTH PATCHING OF EXISTING PAVEMENT SLABS AND JOINTS with 5.2 BASIS OF PAYMENT FOR CW 3230-R8 of this specification.
- E19.1.10 Replace 13.0 Measurement and Payment for CW 3235-R9, RENEWAL OF EXISTING MISCELLANEOUS CONCRETE SLABS with 5.3 MEASUREMENT AND PAYMENT FOR CW 3235-R9 of this specification.
- E19.1.11 Replace 4.0 Measurement and Payment for CW 3240-R10, RENEWAL OF EXISTING CURBS with 5.4 MEASUREMENT AND PAYMENT FOR CW 3240-R10 of this specification.
- E19.1.12 Replace 13.0 Basis of Payment for CW 3325-R5, PORTLAND CEMENT CONCRETE SIDEWALK with 5.5 BASIS OF PAYMENT FOR CW 3325-R5 of this specification.
- E19.1.13 This specification also replaces 2.0 Definitions, 5.3 Portland Cement Concrete Constituent Materials, 6.0 Design Requirements, 9.8. Weather Conditions, and 13.0 Basis of Payment of CW3310-R17, PORTLAND CEMENT CONCRETE PAVEMENT WORKS where other specifications (e.g. CW3230-R8, CW3235-R9, CW3240-R10, CW3325-R5) reference CW3310-R17, PORTLAND CEMENT CONCRETE PAVEMENT WORKS.
- E19.1.14 All requirements and tests shall be in accordance with the latest edition of CSA A23.1-19/CSA A23.2-19, except as otherwise specified herein.
- E19.2 Definitions
- E19.2.1 Reinforced Concrete Pavement - A Portland Cement Concrete pavement with distributed steel reinforcement in the pavement slab and with deformed tie bars across longitudinal joints and smooth dowels across transverse contraction joints. Distributed steel reinforcement consists of smooth or deformed bars.
- E19.2.2 Plain-Dowelled Pavement - A Portland Cement Concrete pavement with no reinforcing steel in the pavement slab and with deformed tie bars across longitudinal joints and smooth dowels across transverse contraction joints.

- E19.2.3 Type 1 Concrete shall be used for expressways, major arterials, minor arterials, industrial/commercial collectors, residential major collectors, residential minor collectors, and industrial/commercial local pavements.
- E19.2.4 Type 2 Concrete shall be used for residential roads and alleys, curb and gutter sections, curbs, commercial approaches, residential approaches, miscellaneous concrete slab and splash strips. Type 1 Concrete can be used instead of Type 2 Concrete.
- E19.2.5 Type 3 is early opening concrete and shall be used for 24 hours early opening after placement.
- E19.2.6 Type 4 is early opening concrete and shall be used for 72 hours early opening after placement.
- E19.2.7 Type 5 Concrete shall be used for Sidewalks. Type 1 or Type 2 Concrete can be used instead of Type 5 Concrete.
- E19.2.8 Type 6 Concrete is cold weather concreting and shall replace all other concrete types for all applications when cold weather exists, except Type 8.
- E19.2.9 Type 7 is concrete for restoration of utility pavement cuts.
- E19.2.10 Type 8 is concrete for temporary restoration.
- E19.2.11 Coarseness Factor - A measure of the coarseness of the combined aggregate materials being incorporated into the concrete mix, defined as the percentage of all plus 2 500 sieve particles, which are also retained on the 10 000 sieve. Coarseness Factor = 100 (cumulative % retained on 10 000 Sieve divided by the cumulative % retained on 2 500 Sieve).
- E19.2.12 Hot weather is defined as one or a combination of the ambient air temperature being at or above 27 °C, or when there is a probability of the temperature rising above 27 °C during the concrete placing period (as forecast by the nearest official meteorological office), or the evaporation rate that exceeds 0.75 kg/m² /h due to high concrete temperature (maximum temperature of 32 °C for fresh concrete), low relative humidity and high wind speed that tends to impair the quality of freshly mixed or hardened concrete by accelerating the rate of moisture loss and rate of cement hydration, or otherwise causing detrimental results.
- E19.2.13 Cold weather is defined as a period when there is a probability of the ambient air temperature falling below 5 °C within 24 hours of placing or the average daily temperature for three consecutive days has fallen to, or is expected to fall, below 5°C as forecast by the nearest official meteorological office. The daily temperature is the mean temperature which is the average of the maximum and minimum temperature during the period from midnight to midnight.
- E19.2.14 The protection period is the time required to prevent concrete from being affected by exposure to cold weather and to develop a minimum compressive strength of 24 MPa. Concrete compressive strength shall be determined by maturity meters and field cured cylinders. In no case shall the protection period be less than seven (7) days.

MATERIALS

E19.3 Concrete Constituent Materials

E19.3.1 Aggregates

- (i) Aggregate shall consist of crushed stone or gravel or a combination of these materials conforming to the requirements of this Specification.
- (ii) Each of the fine- and coarse-fractions of the combined aggregate shall meet all the requirements of CSA A23.1, Table 10 (FA1) and Table 11, respectively and shall be handled and weighed separately to maintain uniformity. The supplier shall provide the City of Winnipeg, Research and Standards Engineer with test data in accordance with CSA A23.2-30A to demonstrate that the material will produce concrete of acceptable quality that meets all the relevant requirements of this Specification.

- (iii) The combined aggregate gradation and allowable deviations shall comply with the requirements in Table CW 3310.1.

TABLE CW 3310.1 - Combined Aggregate Gradation Limits and Allowable Deviations

Sieve Size	Percent of Total Dry Weight Passing Each Sieve	Allowable Deviation From The Job Mix Formula, % By Mass Passing Sieve
28 000	100%	-
20 000	90% - 100%	± 2%
14 000	75% - 95%	± 2%
10 000	60% - 75%	± 3%
5 000	35% - 50%	± 3%
2 500	27% - 35%	± 2%
1 250	20% - 30%	± 2%
630	10% - 20%	± 2%
315	5% - 10%	± 2%
160	1% - 4%	± 1%
80	0% - 2%	± 1%

- (iv) The fineness modulus of fine aggregate shall be not less than 2.3 nor more than 3.1.
- (v) Aggregates shall conform to CSA-A23.1, Clauses 4.2.3.1 to 4.2.3.6. Each of the fine- and coarse-fractions shall comply with the physical requirements in Table CW 3310.2 and the test results shall be provided with the mix design submittal.

TABLE CW 3310.2 - Limits for Deleterious Substances and Physical Properties of Aggregates

Material	Parameter	Test Method	Maximum Limits	Frequency of Test
coarse aggregate	Clay lumps	CSA A23.2-3A	0.25%	2 years
	Low density granular material	CSA A23.2-4A	0.5%	2 years
	Material finer than 80 µm	CSA A23.2-5A	1.0%	1 year
	Relative density and absorption	CSA A23.2-12A	Note*	1 year
	Flat and elongated particles - Flat particles - Elongated particles	CSA A23.2-13B	25% 40%	1 year
	Petrographic examination** – PN	CSA A23.2-15A	125	1 year
	Unconfined freeze-thaw	CSA A23.2 24A	6%	Twice per season
	Alkali-silica reactivity	CSA A23.2-25A	0.15%	2 years
	Alkali-carbonate reactivity	CSA A23.2-26A	Note*	1 year
	Micro-Deval	CSA A23.2-29A	17%	Twice per season
fine aggregate	Clay lumps	CSA A23.2-3A	1%	2 years
	Low density granular material	CSA A23.2-4A	0.5%	2 years
	Material finer than 80 µm	CSA A23.2-5A	3.0%	1 year

	Organic impurities	CSA A23.2-7A	free from injurious amounts	2 years
	Petrographic examination**	CSA A23.2-15A	Note**	1 year
	Micro-Deval	CSA A23.2-23A	20%	1 year
	Alkali-silica reactivity	CSA A23.2-25A	0.15%	2 years

- *No acceptance/rejection values; however, the results shall be submitted.
- **Petrographic examinations shall be used to calculate the petrographic number (PN), to provide an appraisal of the physical-mechanical quality of coarse aggregate. Determination of PNs applies solely to coarse aggregates and should not be used for fine aggregates. The petrographic report for the fine aggregate shall include a comment on the suitability of the material for use in the production of concrete mix.
- The Coarseness Factor of the combined aggregate shall be between 45 and 65.
- Quarried limestone and dolomite shall not be acceptable as concrete aggregate materials.

E19.4 Hydraulic Cement

E19.4.1 Hydraulic Cement shall be either General Use (GU) or General Use Limestone (GUL) conforming to the requirements of the latest edition of CSA A3001. High-early-strength Portland cement (HE) may also be used for cold weather concreting only. Cement shall be kept in weather tight storage that will protect it from moisture and contamination, and in such a manner as to permit inspection, sampling and identification, where required, of each lot.

E19.5 Supplementary Cementing Materials

E19.5.1 Fly ash shall conform to the requirements of CSA A3001 Class F. Fly ash shall be added to concrete mixtures as a separate constituent material. The use of blended hydraulic cement is not permitted.

E19.6 Water

E19.6.1 Potable water, which is water suitable for human consumption, is permitted to be used as mixing water in concrete without testing. Non-potable water and combined water shall conform to ASTM C1602M, Standard Specification for Mixing Water Used in the Production of Hydraulic Cement Concrete. The concrete supplier shall maintain documentation on the characteristics of the mixing water in compliance with the requirements of Tables 1 and 2 in ASTM C1602M. Testing to verify compliance with the requirements in Table 1 shall be conducted on the Type 1 hand placement paving mix with fly ash. The testing frequency for mixing water shall be in accordance with Appendix X1 of ASTM C1602M. Information on the testing frequency of the concrete mixing water shall be included in the concrete suppliers' quality control program. The source(s) of concrete mixing water and test data indicating compliance with ASTM C1602M shall be provided with the Mix Design Statement submitted to the City of Winnipeg, Research and Standards Engineer.

E19.7 Admixtures

E19.7.1 Air-Entraining Admixture

- (i) The air-entraining admixture shall conform to the requirements of ASTM C260, Standard Specification for Air-Entraining Admixtures for Concrete.

E19.7.2 Chemical Admixtures

- (i) Chemical admixtures shall conform to the requirements of ASTM C494, Standard Specification for Chemical Admixtures for Concrete. Chloride-based chemical admixtures will not be permitted under any circumstances.

E19.7.3 Cold-Weather Admixture Systems

- (i) Cold-weather admixture systems shall conform to the requirements of ASTM C1622, Standard Specification for Cold-Weather Admixture Systems.

DESIGN REQUIREMENTS

E19.8 Concrete Suppliers

E19.8.1 The City of Winnipeg, Research and Standards Engineer will maintain a list of approved concrete suppliers. To obtain approval, concrete suppliers must annually submit the following information to the Research and Standards Engineer prior to April 1st:

- (i) Concrete suppliers Approval Guidelines and Application is available at the City of Winnipeg, Corporate Finance, Material Management Division website at: <https://www.winnipeg.ca/matmgmt/Spec/Default.stm>
- (ii) Names of suppliers and sources for all materials and admixtures
- (iii) Concrete mix designs with unique mix design codes signed and dated by person selecting the mix proportions
- (iv) Copy of valid Concrete Manitoba certificate for concrete batch plant
- (v) Copies of valid scale calibration reports for the concrete batch plant
- (vi) Test data for aggregates (in accordance with clause 2.1.1)
- (vii) The mill certificate for the cement and fly ash including chemical and physical composition and analysis, fly ash source and name of supplier.
- (viii) Sieve analysis test reports for the individual aggregates and the combined aggregate gradations to be used in the concrete. The sieve analysis test reports shall be representative of the material to be used during concrete production.
- (ix) Performance data from trial batches prior to construction to demonstrate the concrete mix will achieve the performance criteria in Table CW 3310.3.

Table CW 3310.3: Performance Criteria and Testing

	Time (day)	Type 1	Type 2	Type 3, and Type 6	Type 4	Type 5	Type 7**	Type 8
A minimum of one (1) set* of concrete compressive strength tests for the slipform paving mix with and without fly ash according to CSA A23.2-9C	@ 1	--	--	20 MPa	--	--	--	--
	@ 3	15 MPa	15 MPa	--	20 MPa	--	--	--
	@ 7	20 MPa	20 MPa	--	--	--	--	--
	@ 28	35 MPa	32 MPa	35 MPa	35 MPa	--	--	--
A minimum of two (2) sets* of concrete compressive strength tests for the hand placement paving mix with and without fly ash according to CSA A23.2-9C	@ 1	--	--	20 MPa	--	--	--	--
	@ 3	15 MPa	15 MPa	24 MPa	20 MPa	12 MPa	20 MPa	12 MPa
	@ 7	20 MPa	20 MPa	--	--	--	--	--
	@ 28	35 MPa	32 MPa	35 MPa	35 MPa	30 MPa	35 MPa	30 MPa
Air-void test according to ASTM C457	@ 28	See Note***						
Rapid chloride penetrability test (RCPT) according to CSA A23.2-23C	@ 56	See Note ****						

Minimum Compressive Strength (MPa)	-	-	20	-	-	20	-	-
- @ 1 days	15	15	-	20	-	24	Note 1*	-
- @ 3 days	-	-	-	-	-	-	-	-
- @ 7 days	35	32	Note 1*	Note 1*	30	Note 1*	-	30
- @ 28 days								
Maximum Rapid Chloride Penetrability Test*** (coulombs) @ 56 days. (see Note 3)	1500	1750	Note 1*	Note 1*	-	Note 1*	-	-

*The concrete shall meet Type 1 or Type 2 based on the application.

**The use of fly ash in concrete mix will be permitted. The Contractor will have the option to replace cement up to but not exceeding the above limits, by weight of total cementitious materials, depending on the concrete type. The use of fly ash will be permitted when the average daily temperature is 10°C and rising for the next five (5) consecutive days of placement as forecast by the nearest official meteorological office. The use of fly ash will not be permitted when the average daily temperature is below 10°C and the average daily temperature for more than five (5) consecutive days has fallen to, or is expected to fall, below 10°C within fourteen (14) days of placement as forecast by the nearest official meteorological office unless authorized in writing by the City of Winnipeg, Research and Standards Engineer.

***The concrete supplier shall develop and submit maturity relationships for Type 1 and Type 6 mixes.

***Rapid chloride penetrability test will be required where there is evidence of concrete damage as a result of inadequate curing and adverse weather conditions, including hot weather, wind, rain, sleet, snow and cold weather. The Contract Administrator shall be allowed access to all sampling locations and reserves the right to take samples for testing at any time.

Table CW 3310.4: Concrete Properties

E19.14 Plant Quality Control

- E19.14.1 The concrete supplier shall provide quality control for the plant to ensure all materials meet the approved mix designs. This information shall be submitted bi-weekly and will be monitored by the City of Winnipeg, Research and Standards Engineer. Failure to submit the quality control results shall be cause for immediate suspension of the concrete supplier.
- E19.14.2 A new mill certificate for cement and fly ash shall be provided monthly during production.
- E19.14.3 Check tests of any concrete constituent materials may be undertaken by a Testing Laboratory designated by the City of Winnipeg, Research and Standards Engineer. The concrete supplier shall be equipped with a suitable means or device for obtaining a representative sample of the cement and fly ash. The device shall enable the sample to be readily taken in proximity to the cement or fly ash weigh hopper and from a container or conveyor holding only cement or fly ash to prevent contamination. Any materials which fails to comply with the requirements of CSA A3001 will be rejected, notwithstanding any certificate of acceptance that may have been previously given. Materials that has been rejected must be removed immediately by the concrete supplier.

HOT AND COLD WEATHER CONCRETING

- E19.15 The Contractor shall be responsible for taking all necessary measures to protect freshly laid concrete from adverse weather conditions, including hot weather, wind, rain, sleet, snow and cold weather, except as otherwise specified herein.
- E19.15.1 Hot weather concreting
- (i) When the ambient air temperature is at or above 27 °C, or when there is a probability of the temperature rising above 27 °C during the placing period (as forecast by the nearest official meteorological office), the Contractor shall provide protection for the concrete from the effects of hot and/or drying weather conditions.
 - (ii) When drying conditions are greater than or equal to 0.75 kg/m²/hr as estimated by use of Figure D1, Appendix D, Guidelines for Curing and Protection of CSA A23.1, the plastic concrete surface shall be protected from drying by application of an evaporation retardant. The evaporation retardant shall be applied according to the manufacturer's recommendations.
- E19.15.2 Cold weather concreting
- (i) When there is a probability of the air temperature falling below 5 °C within 24 h of placing or the average daily temperature for more than three successive days is

fallen to, or is expected to fall, below 5°C as forecast by the nearest official meteorological office, cold weather concreting requirements shall apply.

- (ii) 4Concrete shall be placed on unfrozen base material, free of water, snow, and ice. Frozen base material will be identified by measuring the surface temperature using infrared thermometers or similar devices. If the surface temperature is less than or equal to 0°C, the base will be considered frozen. The Contractor shall use suitable heating methods to maintain the base temperature above 0°C. Salt shall not be used to thaw ice, snow, or frost.
- (iii) Type 6 Concrete shall be used for cold weather concreting.
- (iv) Where less than 30 cubic meters of concrete will be placed, the Contractor shall protect the concrete using a minimum of one layer of insulated tarp with R-value more than 5 for a minimum of seven (7) days after completion of placing operations unless otherwise specified by the Contract Administrator.
- (v) Where 30 cubic meters of concrete or more will be placed, a minimum of three maturity meters shall be used. One maturity meter shall be placed in the final 4 m of paving, and the two other maturity meters shall be placed at locations designated by the Contract Administrator. Each maturity meter shall be capable of recording the time and temperature at three depths, ½ inch below the surface, mid slab and ½ inch above the bottom of the pavement. Locations where the maturity meters are placed shall be protected in the same manner as the rest of the concrete.
- (vi) The Contract Administrator shall provide all necessary wires and connectors for maturity meters. The Contractor shall be responsible for the placement, protection, and maintenance of all wires and connectors. No additional measurement or payment will be made for the placement, protection, and maintenance of all wires and connectors.
- (vii) The Contractor shall maintain the internal concrete temperature above 10 °C during the protection period, a minimum of seven (7) days after completion of placing operations, and until the concrete has developed a minimum compressive strength of 24 MPa. Temperature and concrete compressive strength shall be determined by maturity meters and field cured cylinders. A minimum of four (4) readings for temperature shall be collected in the first three (3) days and then two times daily thereafter.
- (viii) The Contractor shall provide suitable protection methods to the Contract Administrator for approval such as insulation (blankets and boards), heating systems such as electric blankets and hydronic heating systems, unheated or heated enclosures, or a combination of the methods to maintain the internal concrete temperature above 10 °C. In no case shall the protection method be less than one layer of insulated tarp with R-value more than 5.
- (ix) If the internal concrete temperature at any location in the concrete falls below 10 °C but not less than 5°C during the curing period, supplemental heat shall be introduced immediately.
- (x) If the internal concrete temperature at any location in the concrete falls below 5 °C during the curing period, cores shall be collected and tested at 28 days. The cores will be tested in accordance with ASTM C856, Standard Practice for Petrographic Examination of Hardened Concrete and CSA A23.2-14C, Obtaining and testing drilled cores for compressive strength testing. Concrete damaged by frost, as determined by the compressive strength test or Petrographic analysis, shall be removed and replaced at the Contractor's expense. All costs associated with coring, transmittal of cores, and petrographic examination and compressive testing shall be borne by the Contractor regardless of the outcome of the examination.
- (xi) If the internal concrete temperature at any location in the concrete falls below 0 °C during the curing period, concrete shall be removed and replaced by the Contractor at his own expense.
- (xii) The protection method shall not be completely removed until the concrete has cooled to the temperature differential given in CSA A23.2, Table 20. The Contractor shall provide suitable methods for gradual cooling to the Contract Administrator for

approval such as loosening the forms while maintaining cover with plastic sheeting or insulation, gradual decrease in heating inside an enclosure, or turning off the heat and allowing the enclosure to slowly equilibrate to ambient temperature. If the concrete cracks due to a sudden temperature change, concrete shall be removed and replaced by the Contractor at his own expense.

- (xiii) Concrete damaged as a result of inadequate protection against weather conditions shall be removed and replaced by the Contractor at his own expense.
- (xiv) No additional measurement or payment will be made for cold weather concreting

BASIS OF PAYMENT FOR CW 3310-R17

E19.16 Concrete Pavements, Median Slabs, Bull-noses and Safety Median

E19.16.1 Construction of concrete pavements, median slabs, bull-noses and safety median will be paid for at the Contract Unit Price per square metre for the "Items of Work" listed here below, measured as specified herein, which price shall be payment in full for supplying all materials and performing all operations herein described and all other items incidental to the work included in this Specification. The unit price shall be reduced for deficiencies in pavement thickness as per Clause E.35.18 of this Specification.

Items of Work:

- a. "Construction of 250 mm Type (*) Concrete Pavement (**)(***)"
- b. "Construction of 230 mm Type (*) Concrete Pavement (**)(***)"
- c. "Construction of 200 mm Type (*) Concrete Pavement (**)(***)"
- d. "Construction of 150 mm Type (*) Concrete Pavement (**)(***)"
- e. "Construction of Type (*) Concrete Median Slabs (***)"
- f. "Construction of Monolithic Type (*) Concrete Median Slabs (***)"
- g. "Construction of Type (*) Concrete Safety Medians (***)"
- h. "Construction of Monolithic Type (*) Concrete Curb and Sidewalk (***)"
- i. "Construction of Monolithic Type (*) Concrete Bull-noses"

* Specify the Concrete Type

** Specify either Reinforced or Plain-Dowelled

*** Specify Slip Form Paving if required

**** Specify referenced Standard Detail

E19.17 Concrete Pavements for Early Opening

E19.17.1 Construction of concrete pavements for early opening will be paid for at the Contract Unit Price per square metre for the "Items of Work" listed here below, measured as specified herein, which price shall be payment in full for supplying all materials and performing all operations herein described and all other items incidental to the work included in this Specification. The unit price shall be reduced for deficiencies in pavement thickness as per Clause E.35.18 of this Specification.

Items of Work:

- a. "Construction of 250 mm Type (*) Concrete Pavement for Early Opening (**)(***)"
- b. "Construction of 230 mm Type (*) Concrete Pavement for Early Opening (**)(***)"
- c. "Construction of 200 mm Type (*) Concrete Pavement for Early Opening (**)(***)"
- d. "Construction of 150 mm Type (*) Concrete Pavement for Early Opening (**)(***)"

* Specify either Type 3 or Type 4

** Specify either Reinforced or Plain-Dowelled

*** Specify Slip Form Paving if required

E19.18 Pavement Thickness Tolerance

E19.18.1 At the option of the Contract Administrator, pavement thickness may be determined by coring pavement sections representing each day's pour and determining the pavement thickness by averaging the depth of the cores.

- E19.18.2 Pavement found deficient in thickness by more than five (5%) percent shall be paid for at the reduced price. The reduced price = PR x contract price;
PR is in % and TD is in %
Where: $PR = 100 - [(TD - 5) / 5] \times 25$
Where: TD = thickness deficiency greater than or equal to 5%, up to 10%.
- E19.18.3 When the pavement thickness is deficient by more than ten (10%) percent and the judgement of the Contract Administrator is that the area of such deficiency should not be removed and replaced, payment will be fifty (50%) percent of Contract Unit Price.
- E19.18.4 The cost of initial cores will not be paid for by the Contractor. Additional cores requested by the Contractor to determine the extent of areas deficient in thickness, shall be paid for by the Contractor.

E19.19 Concrete Curbs, Curb and Gutter, and Splash Strips

- E19.19.1 Construction of concrete curbs, curb and gutter, and splash strips will be paid for at the Contract Unit Price per metre for the "Items of Work" listed here below, measured as specified herein, which price shall be payment in full for supplying all materials and performing all operations herein described and all other items incidental to the work included in this Specification.

Items of Work:

- a. "Construction of Type (*) Concrete Barrier Curb (**)"
 - b. "Construction of Type (*) Concrete Modified Barrier Curb (**)"
 - c. "Construction of Type (*) Concrete Curb and Gutter (**)"
 - d. "Construction of Type (*) Concrete Mountable Curb (**)"
 - e. "Construction of Type (*) Concrete Lip Curb (**)"
 - f. "Construction of Type (*) Concrete Curb Ramp (**)"
 - g. "Construction of Type (*) Concrete Safety Curb (**)"
 - h. "Construction of Type (*) Concrete Splash Strips (**)"
- * Specify the Concrete Type
** Specify height, type and Referenced Standard Detail
***Specify height, monolithic or separate, type, width, and referenced Standard Detail

- E19.19.2 No measurement or payment shall be made for supply or placement of bonding grout for concrete curbs.
- E19.19.3 Drilled curb ramp tie bars are to be paid in accordance with CW 3230.

E19.20 Dowel Assemblies

- E19.20.1 Supply and installation of dowel assemblies will be paid for at the Contract unit Price per metre for "Supply and Installation of Dowel Assemblies", measured as specified herein, which price shall be payment in full for supplying all materials and performing all operations herein described and all other items incidental to the work included in this Specification.

E19.21 Drilled Tie Bars and Dowels

- E19.21.1 Supply and installation shall be in accordance with clause 9.2.3 of CW 3310-R17.

BASIS OF PAYMENT FOR CW 3230-R8

E19.22 Full Slab Replacement

- E19.22.1 Replacement of complete slabs will be paid for at the Contract Unit Price per square metre for the "Items of Work" listed here below, measured as specified herein, which price shall be payment in full for supplying all materials and for performing all operations herein described and all other items incidental to the work included in this Specification.

Items of Work: Slab Replacement

- a. 250mm Type (*) Concrete Pavement (**)
- b. 230mm Type (*) Concrete Pavement (**)

- c. 200mm Type (*) Concrete Pavement (**)
- d. 150mm Type (*) Concrete Pavement (**)
* Specify the Concrete Type
** Specify either Reinforced or Plain-Dowelled

E19.23 Full Depth Partial Slab Patches

E19.23.1 Full-depth partial slab patches will be paid for at the Contract Unit Price per square metre for "Items of Work", listed here below, measured as specified herein, which price shall be payment in full for supplying all materials and for performing all operations herein described and all other items incidental to the work included in this Specification.

Items of Work: Partial Slab Patches

- a. 250mm Type (*) Concrete Pavement (**)
- b. 230mm Type (*) Concrete Pavement (**)
- c. 200mm Type (*) Concrete Pavement (**)
- d. 150mm Type (*) Concrete Pavement (**)
* Specify the Concrete Type
** Specify class of patch

E19.24 Dowels in Drilled Holes

E19.24.1 Installation of dowels into hardened concrete will be paid for at the Contract Unit Price for "Drilled Dowels"*, measured as specified herein, which price shall be payment in full for supplying all materials and for performing all operations herein described and all other items incidental to the work included in this Specification.

*Specify diameter(s) of dowels

E19.25 Tie Bars in Drilled Holes

E19.25.1 Installation of tie bars into hardened concrete will be paid for at the Contract Unit Price for "Drilled Tie Bars"* measured as specified herein, which price shall be payment in full for supplying all materials and for performing all operations herein described and all other items incidental to the work included in this Specification.

*Specify size(s) of tie bars.

MEASUREMENT AND PAYMENT FOR CW 3235-R9

E19.26 Removal of Miscellaneous Concrete Slabs

E19.26.1 Removal of miscellaneous concrete slabs will be measured on an area basis and paid for at the Contract Unit Price per square metre for the "Items of Work" listed here below. The area to be paid for will be the total number of square metres of existing miscellaneous concrete slabs removed in accordance with this specification, accepted and measured by the Contract Administrator.

Items of Work: Miscellaneous Concrete Slab Removal

- a. Median Slab
- b. Monolithic Median Slab
- c. Safety Median
- d. 100mm Sidewalk
- e. 150mm Reinforced Sidewalk
- f. Bullnose
- g. Monolithic Curb and Sidewalk

E19.27 Installation of Miscellaneous Concrete Slabs

E19.27.1 Installation of miscellaneous concrete slabs will be measured on an area basis and paid for at the Contract Unit Price per square metre for the "Items of Work" listed here below. The area to be paid for will be the total number of square metres of miscellaneous concrete

slabs installed in accordance with this specification, accepted and measured by the Contract Administrator.

Items of Work: Miscellaneous Concrete Slab Installation

- a. Type (*) Concrete Median Slab**
- b. Type (*) Concrete Monolithic Median Slab**
- c. Type (*) Concrete Safety Median**
- d. Type (*) Concrete 100mm Sidewalk**
- e. Type (*) Concrete 150mm Reinforced Sidewalk***
- f. Type (*) Concrete Bullnose**
- g. Type (*) Concrete Monolithic Curb and Sidewalk**
 - * Specify the Concrete Type
 - ** referenced Standard Detail to be specified
 - *** renewal area to be specified

E19.27.2 All costs for installing sign support clamps and constructing isolations for boulevard and median appurtenances will be included in the payment for the "Items of Work" listed for miscellaneous concrete slab installation.

E19.27.3 All costs for excavation, sub-grade compaction, placement of sub-base, placement of leveling course and backfill materials, slabs installation and boulevard grading to the limits as identified in Section 3.2 of CW 3235-R9 will be included in the payment for the "Items of Work" listed for Installation of Miscellaneous Concrete Slabs.

E19.27.4 Additional base course over and above leveling course material will be paid in accordance with CW 3110.

E19.28 Miscellaneous Concrete Slab Renewal

E19.28.1 Miscellaneous concrete slab renewal will be measured on an area basis and paid for at the Contract Unit Price per square metre for the "Items of Work" listed here below. The area to be paid for will be the total number of square metres of existing miscellaneous concrete slabs removed and installed in accordance with this specification, accepted and measured by the Contract Administrator.

Items of Work: Miscellaneous Concrete Slab Renewal

- a. Type (*) Concrete Median Slab**
 - b. Type (*) Concrete Monolithic Median Slab**
 - c. Type (*) Concrete Safety Median**
 - d. Type (*) Concrete 100mm Sidewalk* (***)
 - e. Type (*) Concrete 150mm Reinforced Sidewalk (***)
 - f. Type (*) Concrete Bullnose**
 - g. Type (*) Concrete Monolithic Curb and Sidewalk**
 - * Specify the Concrete Type
 - ** referenced Standard Details to be specified.
 - *** renewal area to be specified.
1. Less than 5 sq. m
 2. 5 sq. m to 20 sq. m
 3. Greater than 20 sq. m

E19.28.2 All costs for the slab removal, excavation, sub-grade compaction, placement of leveling course and backfill materials, slabs installation and boulevard grading to the limits as identified in Section 3.3 of CW 3235-R9 will be included in the payment for the "Items of Work" listed for Miscellaneous Concrete Slab Renewal.

E19.28.3 Additional base course over and above leveling course material will be paid in accordance with CW 3110.

E19.28.4 All costs for installing sign support clamps and constructing isolations for boulevard and median appurtenances will be included in the payment for the "Items of Work" listed for Miscellaneous Concrete Slab Renewal.

E19.29 Adjustment of Precast Concrete Sidewalk Blocks

- E19.29.1 Adjustment of precast concrete sidewalk blocks will be measured on an area basis and paid at the Contract Unit Price per square metre for "Adjustment of Precast Sidewalk Blocks". The area to be paid for will be the total number of square metres of precast concrete sidewalk blocks adjusted to grade in accordance with this specification, accepted and measured by the Contract Administrator.
- E19.29.2 No measurement or payment will be made for any precast sidewalk blocks damaged or lost during replacement.
- E19.30 Supply of Precast Concrete Sidewalk Blocks
- E19.30.1 Supply of precast concrete sidewalk blocks will be measured on an area basis and paid at the Contract Unit Price per square metre for "Supply of Precast Sidewalk Blocks". The area to be paid for will be the total number of square metres of precast concrete sidewalk blocks supplied in accordance with this specification, accepted and measured by the Contract Administrator.
- E19.31 Removal of Precast Concrete Sidewalk Blocks
- E19.31.1 Removal of precast concrete sidewalk blocks will be measured on an area basis and paid at the Contract Unit Price per square metre for "Removal of Precast Sidewalk Blocks". The area to be paid for will be the total number of square metres of precast concrete sidewalk blocks removed in accordance with this specification, accepted and measured by the Contract Administrator.

MEASUREMENT AND PAYMENT FOR CW 3240-R10

- E19.32 Concrete Curb Removal
- E19.32.1 Concrete curb removal will be measured on a length basis and paid for at the Contract Unit Price per metre for the "Items of Work" listed here below. The length to be paid for will be the total number of metres of concrete curb removed in accordance with this specification, accepted and measured by the Contract Administrator.
- Items of Work: Concrete Curb Removal**
- a. Barrier*
 - b. Modified Barrier*
 - c. Curb and Gutter
 - d. Mountable Curb
 - e. Lip Curb
 - f. Modified Lip Curb
 - g. Curb Ramp
 - h. Safety Curb
 - i. Splash Strips**
- * Integral or Separate to be specified.
** Monolithic or Separate.
- E19.32.2 Removal of existing asphalt material immediately in front of the curb that is required for installation will be included in the payment for the "Items of Work" listed for Concrete Curb Removal when the asphalt overlay is not identified to be removed.
- E19.33 Concrete Curb Installation
- E19.33.1 Concrete curb installation will be measured on a length basis and paid for at the Contract Unit Price per metre for the "Items of Work" listed here below. The length to be paid for will be the total number of metres of concrete curb or splash strip installed in accordance with this specification, accepted and measured by the Contract Administrator.

Items of Work: Concrete Curb Installation

- a. Type (*) Concrete Barrier**
- b. Type (*) Concrete Modified Barrier**
- c. Type (*) Concrete Curb and Gutter**
- d. Type (*) Concrete Mountable Curb**

- e. Type (*) Concrete Lip Curb**
- f. Type (*) Concrete Modified Lip Curb**
- g. Type (*) Concrete Curb Ramp**
- h. Type (*) Concrete Safety Curb**
- i. Type (*) Concrete Splash Strips***
 - * Specify the Concrete Type
 - ** reveal height, type and reference to Standard Detail to be specified.
 - *** reveal height, monolithic or separate, type, width and reference to Standard Detail to be specified.

E19.33.2 The placement and compaction of asphalt material immediately in front of the curb will be included in the payment for the "Items of Work" listed for Concrete Curb Installation when the asphalt overlay is not identified to be removed.

E19.33.3 No payment will be made for leveling course.

E19.33.4 Base course will be paid in accordance with CW 3110.

E19.33.5 Supply and placement of bonding grout for concrete curbs will not be measured for payment.

E19.34 Concrete Curb Renewal

E19.34.1 Concrete curb renewal will be measured on a length basis and paid for at the Contract Unit Price per metre for the "Items of Work" listed here below. The length to be paid for will be the total number of metres of concrete curb or splash strip removed and installed in accordance with this specification, accepted and measured by the Contract Administrator.

Items of Work: Concrete Curb Renewal

- a. Type (*) Concrete Barrier** (***)
- b. Type (*) Concrete Modified Barrier**
- c. Type (*) Concrete Curb and Gutter** (***)
- d. Type (*) Concrete Mountable Curb**
- e. Type (*) Concrete Lip Curb**
- f. Type (*) Concrete Modified Lip Curb**
- g. Type (*) Concrete Curb Ramp**
- h. Type (*) Concrete Safety Curb**
- i. Type (*) Concrete Splash Strips (***) (****)

* Specify the Concrete Type

** reveal height, type and referenced Standard Detail to be specified.

*** renewed length to be specified.

1. Less than 3 m
2. 3 m to 30 m
3. Greater than 30 m

*** reveal height, monolithic or separate, type, width and reference to Standard Detail to be specified.

E19.34.2 All costs for removal, excavation, sub-grade compaction, leveling course and backfill materials, curb installation and boulevard grading to the limits as identified in Section 3.4 of CW 3240-R10 will be included in the payment for the "Items of Work" listed for Concrete Curb Renewal.

E19.34.3 Base course will be paid in accordance with CW 3110.

E19.34.4 For installation lengths greater than 30 metres, the length will include breaks for approaches, isolations or fixed obstacles such as light standards or poles.

E19.34.5 Curb ramp tie bars are to be paid in accordance with CW 3230.

E19.34.6 Supply and placement of bonding grout for concrete curbs will not be measured for payment.

E19.35 Concrete Sidewalks

E19.35.1 Construction of concrete sidewalks will be paid for at the Contract Unit Price per square metre for "100 mm Type (*) Concrete Sidewalk", measured as specified herein, which price shall be payment in full for supplying all materials and for performing all operations herein described and all other items incidental to the work included in this Specification.

E19.36 Leveling Course

E19.36.1 No payment shall be made for leveling course.

E19.37 Excavation, Sub-grade Compaction, and Base Course

E19.37.1 Excavation, sub-grade compaction, and additional base course shall be paid for in accordance with Specification CW 3110.

E20. LANDSCAPING CURB

DESCRIPTION

E20.1 This specification shall cover the supply and installation of concrete landscaping curb, as noted on the Drawings or as directed by the Contract Administrator.

MATERIAL & CONSTRUCTION METHOD

E20.2 Supply and install curb in accordance with CW 3310 – Portland Cement Concrete Pavement Works and SD-204.

E20.3 Construct 150 mm reveal concrete landscaping curb integral with the monolithic curb and sidewalk.

MEASUREMENT AND PAYMENT

E20.4 Supply and installation of concrete landscaping curb will be measured on a length basis and paid for at the Contract Unit Price for "Landscaping Curb (150 mm reveal ht)", supplied and installed in accordance with the Specification and accepted and measured by the Contract Administrator.

E21. CONSTRUCTION OF BARRIER CURB FOR ASPHALT PAVEMENT

DESCRIPTION

E21.1 This Specification covers the construction of Barrier Curb for Asphalt Pavement-on Waterford Av.

GENERAL

E21.2 Referenced Standard Construction Specifications and Standard Detail Drawings:

- (a) CW 3110 – Sub-grade, Sub-base and Base Course Construction
- (b) CW 3310 – Portland Cement Concrete Pavement Works
- (c) CW 3240 – Renewal of Existing Curbs
- (d) Standard Detail Drawings SD-200A

CONSTRUCTION METHODS

E21.3 Further to CW 3310, the contractor shall construct the Barrier Curb for Asphalt Pavement as per Standard Detail Drawing SD-200A.

E21.4 Construction of Barrier Curb for Asphalt Pavement- A – Standard Detail Drawing SD-200A

- E21.4.1 Place and compact 50mm sub-base material for roadway in accordance with the Standard Detail Drawing SD-200A and Specification CW 3110.
- E21.4.2 Supply and install 20M tie-bars into sub-base material as shown on the Standard Detail Drawing SD-200A
- E21.4.3 Drill holes into the sub-base at a maximum depth of 150mm, with a drilling diameter of 2mm greater than the diameter of the tie bar.
- E21.4.4 Supply and install 2-10M longitudinal deformed bars for reinforcement as shown on the Standard Detail Drawing SD-200A.
- E21.4.5 Supply and install 2-19.1mm dowels at transverse joints every 6.0 meters as shown on the Standard Detail Drawing SD-200A. All dowels shall be thoroughly lubricated with asphaltic cut-back.
- E21.4.6 Provide a minimum of 40mm cover between reinforcing steel and the finished concrete surface.
- E21.4.7 Transverse joints will be saw cut every 3.0 meters. Transverse joints are to be saw cut to a maximum depth of 25mm, so as to not saw cut into the 10M longitudinal deformed bars and 19.1mm dowels.
- E21.4.8 Construct lip curb for asphalt pavement (40mm ht) at private approaches in accordance with Standard Detail Drawing SD-202B. 1-10M longitudinal deformed bar for reinforcement and 1-19.1mm dowel only required for lip curb for asphalt pavement at transverse joint.
- E21.4.9 Construct Modified Barrier Curb for Asphalt Pavement (180mm ht) in accordance with Standard Detail Drawing SD-203B and SD-200A. Install 20M tie-bars into sub-base material, 2-10M longitudinal deformed bars for reinforcement and 2-19.1mm dowels at transverse joint.
- E21.4.10 Construct Ramp Curb for Asphalt Pavement (8-12mm ht) at sidewalk ends in accordance with Standard Detail Drawing SD-229C. Install 1-10M longitudinal deformed bar for reinforcement and 1-19.1mm dowel only required for lip curb for asphalt pavement at transverse joint.
- E21.4.11 Place concrete utilizing slip-form paving equipment in accordance with Specification CW 3310 unless otherwise directed by the Contract Administrator.
- E21.4.12 Place and compact 50mm sub-base material as backfill behind barrier curb for asphalt pavement within excavated area approximately 150mm deep or as directed by the Contract Administrator. Place and compact suitable site material as backfill behind barrier curb to allow for 100mm of topsoil and sod below top of barrier curb. Care must be taken so as to not disturb the new Barrier curb for asphalt pavement during placing and compaction of 50mm sub-base material and suitable site material.

MEASUREMENT AND PAYMENT

- E21.5 Construction of barrier curb for asphalt pavement-A shall be measured on a length basis and paid for at the Contract Unit Price per metre of "Construction of Barrier Curb for Asphalt Pavement-A". The length to be paid for shall be the total number of meters supplied and installed in accordance with this Specification, accepted and measured by the Contract Administrator.
- E21.6 Construction of lip curb for asphalt pavement shall be measured on a length basis and paid for at the Contract Unit Price per metre of "Construction of Lip Curb for Asphalt Pavement". The length to be paid for shall be the total number of meters supplied and installed in accordance with this Specification, accepted and measured by the Contract Administrator.
- E21.7 Construction of modified barrier curb for asphalt pavement-A shall be measured on a length basis and paid for at the Contract Unit Price per metre of "Construction of Modified Barrier Curb for Asphalt Pavement-A". The length to be paid for shall be the total number of meters supplied

and installed in accordance with this Specification, accepted and measured by the Contract Administrator.

- E21.8 Construction of ramp curb for asphalt pavement shall be measured on a length basis and paid for at the Contract Unit Price per metre of "Construction of Ramp Curb for Asphalt Pavement". The length to be paid for shall be the total number of meters supplied and installed in accordance with this Specification, accepted and measured by the Contract Administrator
- E21.9 The supply and installation of 20M tie-bars, 10M longitudinal deformed bars and 19.1mm dowels is incidental to "Construction of Barrier Curb for Asphalt Pavement", "Construction of Lip Curb for Asphalt Pavement", "Construction of Modified Barrier Curb for Asphalt Pavement", and "Construction of Ramp Curb for Asphalt Pavement." No measurement or payment will be made. Supply and placement of 50mm sub-base material for backfill to be paid for as per payment item "50mm Granular B".
- E21.10 Supply and placement of 50mm sub-base material for backfill to be paid for as per payment item "50mm Granular B".
- E21.11 Supply and placement of suitable site material for backfill to be paid for as per payment item "Placing Suitable Site Material".

E22. PRUNING OF EXISTING TREES AND SHRUBS

DESCRIPTION

- E22.1 Provide all labour, materials, methods, equipment and accessories for pruning of existing trees and shrubs within the limit of Work.

QUALITY ASSURANCE

- E22.2 Pruning of trees shall be provided by a person with a Manitoba Arborists Certificate with demonstrable experience sourcing and Work.
- E22.3 Contact the City of Winnipeg Forestry Branch at 204-986-2004 to arrange an on site meeting to review trees to be pruned. Meeting to include the Contract Administrator.

PRUNING METHODOLOGY

- E22.4 Prune horizontal and vertical within the limits of construction to ensure construction equipment can be operated without interfering with trees to remain.
- E22.5 Prune as required to remove dead, broken or damaged limbs.
- E22.6 Prune back to healthy growth while maintaining balanced crown shape.
- E22.7 Employ clean sharp tools.
- E22.8 Make cuts smooth and flush with outer edge of branch collar near the main stem or branch.
- E22.9 Cuts must be smooth and sloping to prevent accumulation of water on cut.
- E22.10 Do not leave little stumps ("horns") on trunks or main branches.
- E22.11 Prune according to accepted horticultural practices as outline in "The Pruning Manual", Publication No. 1505-1977 by Agriculture Canada.

MEASUREMENT AND PAYMENT

- E22.12 No payment shall be made for pruning of existing trees. Pruning of existing trees shall be considered incidental to the Work.

E23. WATER AND WASTE SEWER REPAIRS

E23.1.1 Sewer repairs are subject to approval of WWD and may be removed if not required.

E24. INSTALLATION OF STREET LIGHTING AND ASSOCIATED WORKS

E24.1 DEFINITIONS

LIMITS OF APPROACH means the shortest distance that is permissible between live high voltage (>750 volts) conductors or apparatus and any part of a worker's body, material or tools being handled, or equipment operated.

MANITOBA HYDRO CENTRAL STORES means Manitoba Hydro's Waverley Service and Reclaim Centre - 1840 Chevrier Blvd - Winnipeg, Manitoba

OVERHEAD FEED means an electrical supply via an overhead conductor connected between streetlight standards. Typically strung between standards on a temporary basis.

OVERHEAD SOURCE means an electrical supply from Manitoba Hydro's system. (Typically an overhead conductor from a wooden distribution pole or a DIP/RISER located on a wooden distribution pole.)

RECLAIM material means existing material that has been removed from Manitoba Hydro's system and to be returned to Manitoba Hydro.

SCRAP material means existing material that has been removed from Manitoba Hydro's system and to be recycled/disposed of by the Contractor.

SURPLUS material means new material that has been requisitioned by the Contractor and not incorporated into the work at the end of the Contract.

WORK CLEARANCE means an ELECTRICAL AND/OR NATURAL GAS FACILITIES LOCATE form (see SAMPLE ONLY included as Appendix 'E') issued by each of Manitoba Hydro's Customer Service Centre (CSC) affected to permit work to commence (Permit to work).

E24.2 DESCRIPTION

E24.2.1 The work shall consist of the supply of all supervision, labour, materials (except as indicated under MATERIAL SUPPLIED BY MANITOBA HYDRO below) insurance, tools, backfill and equipment (and their maintenance), transportation, fuel, oil, meals and lodging, mobilization and de-mobilization, and warranty of workmanship as required to install and remove temporary Overhead Feeds, remove existing street light poles as required, install new street light poles and associated underground cables/conduits, all in accordance with the requirements specified in the tender documents.

E24.3 WORK LOCATIONS

E24.3.1 The proposed street light installation and removals are shown on construction drawings and are as follows:

(a) WATERFORD AV

E24.4 COORDINATION OF WORK

E24.4.1 The Contractor shall provide a minimum of ten (10) working days notice to Manitoba Hydro prior to the start of construction. The work shall be conducted and coordinated with Manitoba Hydro in a manner to ensure street lighting is maintained at all times for the duration of the work. The construction drawings provide the Proposed Sequence of Construction.

E24.4.2 The Contractor shall obtain Work Clearance from Manitoba Hydro's Customer Service Centre(s) (CSC) affected prior to the work commencing. No additional compensation shall be paid to the Contractor for delays obtaining Work Clearance for any reason.

E24.4.3 Manitoba Hydro's CSC will provide the Limits of Approach applicable to the Contractor on the Work Clearance form.

E24.5 ORIENTATION

E24.5.1 Prior to the commencement of the proposed work, the Contractor's crew foremen, electricians, and other key personnel shall attend one (1) day of orientation provided by Manitoba Hydro for various operations such as cable handling, cable splicing/termination, installation of street light poles, concrete bases, luminaires and various other construction standards and procedures. The Contractor will be responsible for all costs associated with personnel salaries, travel, sustenance and overheads, etc., during training.

E24.6 PRE-CONSTRUCTION MEETING

E24.6.1 Prior to the commencement of the work, the Contractor shall attend a pre-construction meeting with Manitoba Hydro. The agenda for this meeting shall include but not be limited to the following:

- (a) Reference the Contractor's Safe work Procedures;
- (b) Prime Contractor;
- (c) materials;
- (d) sequence of construction;
- (e) communication plan;
- (f) any training requirements & qualifications;
- (g) Drawing and Project review;
- (h) a review of the Contractor's proposed work schedule; and
- (i) any and all other topics of clarification that the Contractor and the Contract Administrator may wish to discuss.

E24.6.2 The Contractor's cost to attend this pre-construction meeting shall be incorporated into the unit prices for the work.

E24.7 QUALIFICATIONS AND CERTIFICATION

E24.7.1 The Contractor's Crew Foreman, installers and other key Contractor's Personnel shall possess the necessary certification, licensing, training, experience and familiarity with safety rules, procedures and hazards relating to the work. Journeyman Power Line Technician (PLT), Journeyman Lineman, Journeyman Cableman or Journeyman Electricians shall be required to perform portions of this work.

E24.7.2 Journeyman Power Line Technician (PLT), Journeyman Cableman and Journeyman Lineman are also required to possess a "Limited Specialized Trade Licence – 'M-P' Licence – Power Line" issued by the Province of Manitoba.

E24.7.3 Office of the Fire Commissioner Bulletin OFC 18 – 002 dated May 23, 2018 regarding Electrician Licenses discusses the requirements for a "Limited Specialized Trade Licence – 'M-P' Licence – Power Line".

For more information contact:
Office of the Fire Commissioner
500-401 York Avenue
Winnipeg, Manitoba R3C 0P8
Tel. 204-945-3373
Fax 204-948-2089
Toll Free: 1-800-282-8069

firecomm@gov.mb.ca

E24.7.4 Licensed Journeyman Electricians or Journeyman PLT or Journeyman Cableman or Journeyman Lineman ARE REQUIRED for all cable handling operations included but not limited to: disconnecting cables in the handhole, installation and removal of temporary overhead feeds, installation and connection of ground rods, streetlight cable splices, termination of streetlight cables in handholds and at luminaires. The Contractor shall employ sufficient qualified personnel on its crews to conform to the Electrician's Licensing Act. The Contractor shall be prepared to provide proof of licences to Manitoba Hydro upon request.

E24.7.5 The Contractor shall assess the hazards associated with the work and have documented Safe work Procedures to perform the work. It is the Contractor's responsibility to train employees on these procedures. The Contractor shall be prepared to provide proof of training to Manitoba Hydro upon request.

E24.8 REFERENCED STANDARD CONSTRUCTION SPECIFICATIONS

E24.8.1 In addition to these Specifications, the work to be performed by the Contractor relative to the installation and/or replacement of street lighting poles, concrete bases and associated cabling shall be in accordance with the following:

- (a) Manitoba Hydro 66kV and Below Standards;
- (b) CSA C22.3 No. 7 (latest edition);
- (c) Canadian Electrical Code (CEC) Part 1 (latest edition); and
- (d) Any other applicable codes
- (e) (collectively, the "Standards")

E24.8.2 Revisions and updates to the Manitoba Hydro 66kV and Below Standards are issued periodically and the latest issued version of the Standard will apply. For the convenience of the Contractor for bidding purposes, excerpts of the Manitoba Hydro 66kV and Below Standards have been included as Appendix 'B'.

E24.8.3 In some cases, Municipal, Provincial or Federal laws or this Technical Specification may be more stringent than the CSA Standards. Whenever conflict exists, the Contractor shall comply with the most stringent requirements applicable at the place of the work.

E24.9 TOOLS, EQUIPMENT AND MATERIALS

E24.9.1 The Contractor shall be required to provide all tools and equipment required for performing the specified tasks. Equipment shall be in good operating condition, shall be properly maintained using original equipment manufacturer replacement parts and shall be provided with letters of testing/inspection from the manufacturer when requested. Where the equipment is provided as a kit with multiple parts and tools, the kit shall be complete with all parts required to perform the designed task. Contractor fabricated tools or equipment will not be accepted for use.

E24.9.2 The Contractor shall obtain the following specific Electrical Equipment including but not limited to:

- (a) Compression tool or tools and associated dies to perform compressions to a maximum size of 1/0 Al (MD-6 compression tools shall not be used).
- (b) Approved compression tools are:

Manufacture	Type	Model No.	Range
Burndy	In-line, battery	PATMD68-14V	350 Kcmil AL
Cembre	In-line, battery	B54Y (06V081E)	4/0 AWG AL
Burndy	Pistol, battery	BUR PAT60018V	350 Kcmil AL

E24.9.3 Dies shall be of the type shown in Standard CD210-21 and CD 210-24 only, must have identical markings, and compression tool die must match die number stamped on connector.

- (a) Modiewark Model #4444 or Fluke 1AC-II Volt Alert potential Indicator
- (b) Voltage meter – Fluke model #T3C
- (c) Insulated wire cutters – used for cutting cable ends square.

E24.9.4 Alternative equipment manufacturers may be considered upon request by the Contractor and shall be approved for use by Manitoba Hydro prior to use.

E24.9.5 Manitoba Hydro may reject any tools or equipment that do not appear to be in good condition or fail to successfully provide the required function.

E24.10 MATERIAL SUPPLIED BY MANITOBA HYDRO

E24.10.1 Manitoba Hydro shall supply all street light poles, concrete bases, breakaway bases, luminaires, street light arms, ground rods, compression sleeves, grommets, nuts, electrical cables, conduits, relays, cable guards, Gel-caps and all other materials noted in the Standards. The Contractor shall sign receipts indicating the location on which the materials are to be used. The material shall be picked up by the contractor from the following locations:

E24.10.2 Manitoba Hydro Central Stores (contact personnel will be provided to the successful contractor).

E24.10.3 Materials requested will be supplied to the Contractor by Manitoba Hydro upon presentation of Manitoba Hydro's Stores Material Order Form. The Contractor shall assume all responsibilities for the loading, unloading, transportation, proper handling, secure storage and working of the materials and shall make replacements at its own expense in case any material is damaged, stolen or lost due to improper handling, storage or poor workmanship.

E24.10.4 The Contractor shall, at the time of materials release, check and confirm the quantity of materials. Shortages, discrepancies, or damages to materials shall be immediately reported in writing to Manitoba Hydro.

E24.10.5 After commencing performance of the work, the Contractor shall continually monitor all material required for the timely completion of the work and shall report additional material requirements to Manitoba Hydro a minimum of 72 hours prior to materials being required to perform the work. No additional compensation shall be paid as a result of delays due to material shortages where additional material requirements were not reported a minimum of 72 hours prior to being required for the work on an active project.

E24.11 MATERIAL SUPPLIED BY CONTRACTOR

E24.11.1 The Contractor shall be responsible to furnish gravel, sand, ¾" down limestone, ¼" down limestone, protective hose (i.e. typically 2" fire hose), duct seal and pit-run material for backfilling around street light poles and around cables as per the Standards. The cost of furnishing the above listed materials shall be incorporated into the unit prices for the work.

E24.12 SURPLUS, RECLAIM AND SCRAP MATERIAL

E24.12.1 Upon completion of the work, the Contractor shall, at its own expense, deliver to Manitoba Hydro Central Stores, all Surplus materials furnished by Manitoba Hydro and not used in the work, regardless of the location of said material at that time.

E24.12.2 In addition, the Contractor shall, at its own expense, deliver to Manitoba Hydro Central Stores all Reclaim materials from the work specifically HPS luminaires. Manitoba Hydro shall be responsible for the proper disposal of Reclaim HPS luminaires. The HPS bulb shall remain installed and unbroken in the Reclaim luminaire. The Contractor shall handle the Reclaim luminaires with care and shall avoid breaking the bulb or refractor.

E24.12.3 Manitoba Hydro's preference is to recycle as much Scrap Material as practicable. The Contractor is responsible to remove the Scrap Material, transport to the recycler or Manitoba Hydro approved disposal site, pay for any disposal fees and may retain any recycling value.

E24.13 DE-ENERGIZATION AND LOCKOUT

E24.13.1 **Manitoba Hydro** - Where a standard is supplied from an Overhead Source, Manitoba Hydro's staff shall be responsible to disconnect and isolate the street light standard or standards between the standard and Overhead Source. Some street light standards may be temporarily fed from an Overhead Source. This Overhead Source shall be disconnected and removed by Manitoba Hydro staff prior to commencing with the work. The streetlight circuits will not be Locked Out by Manitoba Hydro.

E24.13.2 **The Contractor** - The Contractor shall assess the hazards associated with the work and employ its own Safe Work Procedure for the work to be performed. The Contractor's Safe Work Procedure shall include provisions that the street light circuits will not be Locked Out by Manitoba Hydro. The Contractor's Safe Work Procedure shall achieve Lock Out or techniques equivalent to Lock Out.

E24.13.3 The Contractor shall complete a job planning form (an example is included as Appendix 'F') on a daily basis before any work commences and provide Manitoba Hydro with copies of the job plans if requested.

E24.14 TEMPORARY OVERHEAD FEEDS

E24.14.1 Manitoba Hydro in consultation with the Contractor will determine if temporary lighting will be provided by the existing street lights or from the new street lights.

E24.14.2 When using the existing poles for temporary lighting, Manitoba Hydro shall remove an Overhead Source in accordance with DE-ENERGIZATION AND LOCKOUT section above, prior to the Contractor installing a #4 duplex overhead conductor between the existing poles. The #4 duplex overhead conductor will normally be attached to the tenon of the davit arm near the luminaire with a pre-form grip. Older poles may require a spool insulator be attached to the pole using a pre-form grip to support the #4 duplex overhead conductor. A short length of 2C/#12 copper conductor is connected to the terminals of the luminaire brought out and connected to the #4 duplex overhead conductor. The final span to the Overhead Source shall be installed by Manitoba Hydro.

E24.14.3 When using the new poles for temporary lighting, the Contractor shall install the new bases, poles and #4 duplex overhead conductor. The #4 duplex overhead conductor will be attached to the tenon of the davit arm near the luminaire with a pre-form grip. A short length of 2C/#12 copper conductor is connected to the terminals of the luminaire brought out and connected to the #4 duplex overhead conductor. The final span to the Overhead Source shall be installed by Manitoba Hydro.

E24.14.4 All material used to provide the temporary overhead feed shall be returned to Manitoba Hydro. Care shall be taken to coil and tag Reclaim conductor for reuse. If used, insulators shall be handled carefully to prevent breakage.

E24.15 SAFE EXCAVATION

E24.15.1 The work shall be performed in accordance with the requirements of Manitoba Hydro's Safe Excavation and Safety Watch Guidelines (latest revision) included as Appendix 'C' and Manitoba Workplace Safety and Health Regulation 217 latest revision.

E24.16 SAFE HANDLING

E24.16.1 The Contractor shall apply handling techniques in accordance with Manitoba Workplace Health and Safety Regulation 217 (latest revision).

E24.17 ELECTRIC CABLES AND CONDUITS

- (a) The Contractor shall use diligent care and proper equipment in handling of all cables, so as not to injure the jacket and avoid gouging, kinking, scratching or abrading the cables. If any material is damaged to any extent, the Contractor shall repair the damages at its own expense, in a manner approved by Manitoba Hydro or will be charged the full cost of the damaged items.
- (b) Cable reels shall not be dropped and must be handled and placed/stored in an upright position at all times and shall not be laid flat for any purpose or reason. Cable reels shall be adequately supported on hard surface to prevent the reel from sinking into the ground that can cause undue stress on the cables. Cable reels should be inspected for damages prior to use. If a cable reel is found to be defective, such defect shall be reported immediately to Manitoba Hydro.
- (c) The Contractor shall place all material and string the cables in such a manner as to cause the least interference with normal use of the land, street or roadway. All material shall be unloaded in a manner to preserve its condition, prevent loss and/or theft and permit easy access for Manitoba Hydro's inspection.
- (d) The Contractor shall provide Manitoba Hydro's inspector sufficient opportunity, in the sole discretion of Manitoba Hydro, to inspect the work.

E24.18 PRECAST CONCRETE BASES

- E24.18.1 The Contractor shall handle, store, transport and unload the precast concrete bases in a manner to prevent damage to the threaded bolts and conduit casing.
- E24.18.2 Precast Concrete Bases are extremely heavy. Approximate weight of pre-cast concrete bases are found in the Standards. The Contractor shall only use equipment rated for such weight.

E24.19 STREET LIGHT POLES AND ARMS

- E24.19.1 The Contractor shall handle, store, transport, and provide proper load securement for the poles and arms in a manner to prevent damage.

E24.20 LUMINAIRES

- E24.20.1 The Contractor shall handle, store, transport and unload the luminaires in their original packaging and in a manner to prevent damage.

E24.21 SMALL MATERIAL

- E24.21.1 Photo electric cells, shorting caps, shims, nut covers and associated supplies shall be kept in a suitable warehouse provided by the Contractor at its own expense. Photo electric cells shall be transported and stored in such a manner as to prevent breakage.

E24.22 CARE OF MATERIALS

- E24.22.1 The Contractor shall assume all responsibilities of all the materials and shall replace, at its own expense, any materials damaged, stolen or lost due to improper handling or poor workmanship.

E24.23 WIRE AND CABLE REEL STORAGE

- E24.23.1 Cable reels shall be stored with the flanges upright and resting on a hard surface. At temporary storage sites where the soil may be soft, preservative-treated plywood sheets may be used to keep the flanges from sinking into the ground.
- E24.23.2 If cable reels must be pancaked or stored on their side in vertical racks, do not lift the reel by the top flange. Spacers (two 2 X 4s placed wide side up) should be placed under the bottom flange and between the reels in order to create a space to insert the forks and lift the reels without damaging the cable.

E24.24 REEL HANDLING

- E24.24.1 When off-loading reels from a truck, reels shall be lowered using a hydraulic gate, hoist or forklift truck. When a reel is rolled from one point to another, care must be taken to see that the reel does not straddle objects such as rocks, pipes, curbs or wooden blocks which could damage the cable or protective covering. A reel should always be rolled on hard surfaces to avoid sinkage and in the opposite direction to the cable wraps to ensure that the reel is rolled in such a direction as to tighten the cable on the reel.
- E24.24.2 When using a hoist, install a mandrel through the reel arbour hole and attach a sling. Use a spreader bar approximately 6 inches longer than the overall reel width placed between the sling ends just above the reel flanges. This will prevent bending of the reel flanges and damage to the cable.
- E24.24.3 If a forklift is used to move a reel, the reel is to be approached from the flange side. Position the forks such that the reel is lifted by both reel flanges. The lift forks shall not contact the cable.
- E24.24.4 Returnable reels shall be returned promptly to Manitoba Hydro Central Stores and in no case later than three (3) days after the completion of the work unless otherwise mutually agreed between the Contractor and Manitoba Hydro.

E24.25 PRESSURIZED WATER/VACUUM EXCAVATION

- E24.25.1 Pressurized water/vacuum excavation (PW/VE) shall be used to daylight all buried utilities and structures where excavation by other mechanical means would be expected to provide a physical risk to that utility or structure.
- E24.25.2 The work shall be performed in accordance with the requirements of Manitoba Hydro's Safe Excavation and Safety Watch Guidelines (latest revision) included as Appendix 'C'.

E24.26 REMOVAL STREET LIGHT POLE FROM EXISTING BASE

- E24.26.1 This shall include all work required to remove a street light pole from an existing base as set forth in this Technical Specification. The pole may be on an existing precast concrete base, steel power installed screw base or poured in place concrete base.
- E24.26.2 The Contractor shall furnish all labour, supplies and materials (except as indicated in the Section "MATERIAL SUPPLIED BY MANITOBA HYDRO") necessary for the removal of the street light pole from the existing base. Care shall be taken to preserve the luminaire. The luminaire shall be reinstalled on the new street light pole or returned to Manitoba Hydro's stores as instructed by the Manitoba Hydro.
- E24.26.3 The Contractor shall be responsible to transport all Surplus and Reclaim materials to Manitoba Hydro Central Stores and transport and dispose of all Scrap material as set forth in this Specification.

E24.27 REMOVAL OF BASE AND DIRECT BURIED STREET LIGHT POLE

- E24.27.1 This shall include all excavation, whether by auger, pressurized water/vacuum excavation, by hand, or by other methods which may be necessary to remove a base or direct buried street light pole. The base may be poured in place concrete, steel power installed or precast concrete.
- E24.27.2 The Contractor shall be responsible to transport all Surplus and Reclaim materials to Manitoba Hydro Central Stores and transport and dispose of all Scrap material as set forth in this Specification.
- E24.27.3 The Contractor is responsible to supply all backfill material as specified in the Standards and carry out all backfill, compacting and leveling of all excavations and voids for removed bases and direct buried street light poles so as to be ready for top soil and seed or sod or as directed by Manitoba Hydro.

E24.28 INSTALLATION OF FOUNDATION - CONCRETE BASE

- E24.28.1 This shall include all excavation, whether by auger, pressurized water/vacuum excavation, by hand, or by other methods which may be necessary to replace or install a concrete base as set forth in this Specification.
- E24.28.2 The Contractor shall furnish all labour, supplies and material (except as indicated in the Section "MATERIAL SUPPLIED BY MANITOBA HYDRO") necessary to install a new or replace a concrete base. Excavation for the precast concrete base shall be to a diameter and depth specified in Standard CD 300-6. All excess material is to be removed by the Contractor.
- E24.28.3 The concrete base shall be set on a bed of ¾" down limestone. The concrete base backfill material shall be compacted in lifts no more than 150 mm. Backfill material shall be ¾" down limestone. Compacting of backfill material shall be done using a hydraulic tamper. Alternative tamping methods shall be approved by Manitoba Hydro. Underground cables entering the concrete base shall be protected by a length of protective hose supplied by the Contractor and a layer of sand surrounding the cables to protect it from the limestone. The concrete base shall be installed level in all 4 directions. Final grade must be established prior to installing the concrete bases.
- E24.28.4 The completed backfill shall be at least equal in compaction to undisturbed soil, as required by the Municipal authorities or elsewhere in this Specification. The Contractor shall level all excavations.
- E24.28.5 Should settlement occur in the excavation and cause a depression in the surface, the Contractor shall repair the surface. Placing of additional backfill material due to settlement shall be at the Contractor's expense.
- E24.28.6 The concrete base shall be oriented in the proper direction to allow the easy entrance of the underground cables into the plastic pipe preinstalled in the concrete base. Care shall be taken to prevent damage to the insulation or jacket of the conductors. The cable shall be left long enough to extend one (1) metre beyond the top of the hand hole.

E24.29 BASE MOUNTED STREET LIGHT POLES

- E24.29.1 This shall include all work required to install the street light pole on the concrete base as set forth in this Specification.
- E24.29.2 The Contractor shall furnish all labour, supplies and material (except as indicated in the Section "MATERIAL SUPPLIED BY MANITOBA HYDRO") necessary for the installation of the pole (straight shaft or davit) on the concrete base.
- E24.29.3 Unless otherwise specified on the construction drawings, the Contractor shall orient the poles so that the hand hole is on the left side of the pole when viewed from the road. A worker should be able to see oncoming traffic when working in the hand hole.
- E24.29.4 The Contractor shall level the street light pole in all 4 directions. Leveling shims may be used.
- E24.29.5 Tightening of bolts shall be performed in a manner that brings the surfaces up evenly. All nuts shall be tightened and torqued in accordance with Standard CD 300-9. The Contractor shall install the nut covers included with the pole.
- E24.29.6 Unless otherwise specified, excess underground cable and 2C-12 wire shall be left inside the hand hole with the hand hole cover loosely installed.
- E24.29.7 Existing street light poles may have street signs attached. The Contractor shall remove the signs from the existing pole and temporarily reattach the signs to the new pole. The Contractor shall notify Manitoba Hydro of the location where the signs have been removed.

E24.30 LUMINAIRES AND ASSOCIATED WIRING

- E24.30.1 The Contractor shall furnish labour, supplies and material (except as indicated in the Section "MATERIAL SUPPLIED BY MANITOBA HYDRO") necessary to install the

luminaire and associated wiring. Unless otherwise specified, the luminaire shall be installed with a tilt of zero (0) degrees. The Contractor shall install a length of 2 conductor No. 12 gauge (2C-12) wire from the terminals of the luminaire, through the arm (if applicable), down the pole to the hand hole. One (1) metre of 2C-12 wire shall be left at the hand hole. Impact equipment (air or electric) shall not be used to tighten luminaire mounting bolts. The Contractor shall be liable for damage due to over tightening.

E24.30.2 The Contractor shall verify the luminaire voltage matches the source voltage as shown on the construction drawings. If luminaire voltage does not match the source voltage, the Contractor shall re-wire the luminaire in accordance with the wiring diagram provided.
NOTE: Not applicable for LED luminaires.

E24.30.3 As specified on the construction drawings, the luminaire will require either a photo electric cell (PEC) or shorting cap installed. When installing the PEC the eye shall be oriented north. The Contractor shall also install the appropriate wattage bulb in the luminaire.
NOTE: Bulb installation not applicable for LED luminaires.

E24.31 BREAK AWAY BASES

E24.31.1 Break away bases shall be installed in accordance with Standard CD 300-10. The height of the concrete base above grade shall not exceed 50mm. The surface of the concrete base shall be flat and level. A reaction plate shall be installed between the concrete base and the break-away base.

E24.31.2 The Contractor shall torque the couplers in accordance with Standard CD 300-10. Impact tools shall not be used to tighten or torque couplers or nuts associated with a break away base.

E24.32 SPLICING/CONNECTING CABLES

E24.32.1 The electric cable shall be spliced/terminated as per Standards CD 215-12, CD 215-13, CD 310-1, CD 310-4, CD 310-9 and CD 310-10 with the exception that the Contractor will use a GELCAP-SL-2/0 splice kit (See Appendix 'D'). Termination in the hand hole may include the installation of an inline fuse holder.

E24.32.2 The Contractor shall furnish all labour, supplies and material (except as indicated in the Section "MATERIAL SUPPLIED BY MANITOBA HYDRO") necessary to splice/terminate the street light conductor(s).

E24.33 EXCAVATION

E24.33.1 The Contractor shall furnish all labour, supplies and material (except as indicated in the Section "MATERIAL SUPPLIED BY MANITOBA HYDRO") necessary for the completion and maintenance of grade and line of the street light cables and conduit including water control if found to be necessary. The trench shall be graded to conform to the street light cables and conduit so that the street light cables and conduit rest firmly on a smooth surface throughout its length. All stones or other objects which, in the opinion of Manitoba Hydro might damage the street light cable jacket and conduit shall be removed. Where the presence of rock or other condition prevent a satisfactory bed for the cables, 150 mm of well-tamped, clean soil or ¼" down crushed limestone shall be placed in the bottom of the trench. In this case, the spoil bank from trenching operations shall not be allowed to fall into the trench or mix with the soil to be used in backfilling the trench. Loose debris or foreign matter and the spoil bank shall be placed so as not to hinder drainage, damage property, or obstruct traffic.

E24.33.2 Trenches shall be dug to such a depth that will provide a minimum cover of 600 mm from final grade in sodded areas and 1000 mm in roadways in accordance with Standard CD 305-1.

E24.34 LAYING CABLES

E24.34.1 Cables are to be lowered in the trench in an orderly fashion so as to maintain a consistent path and straight alignment. All cables shall be lowered in a continuous run (NO

SPLICING) and in accordance with the construction drawings; and shall maintain the necessary separation, where required. All cables shall be of continuous runs and capped and sealed if they are not being installed in the pole at that time. Cables shall not be dragged over paved surfaces.

- E24.34.2 Once a cable is cut its ends must be sealed immediately with an approved and appropriately sized, heat shrink or cold shrink sealing cap to prevent moisture ingress unless the cable is being installed in the pole at that time.
- E24.34.3 During the removal of the cable, the reels shall be placed on jacks, stands or trailers with a bar through the arbour holes which will allow the reel to be turned easily, and the cable to be paid out. Cables can be paid out from the bottom or the top of the reel. Cable in coils shall be handled in a similar manner. This can be achieved by supporting the coil in a vertical plane and rotating it by hand as the cable is carefully uncoiled. The cable shall never be pulled over the flange of a reel, or pulled off the side of a coil, since this will introduce a twist in the cable.
- E24.34.4 During installation, under no circumstance is the cable to be subjected to a bending radius tighter than that detailed in the Standards.
- E24.34.5 Where specified in the Standards or on the construction drawings, the Contractor shall install the street light cable in a conduit.

E24.35 INSTALLING CONDUIT AND CABLE BY BORING (HORIZONTAL DIRECTIONAL DRILLING)

- E24.35.1 The Contractor shall dig the approaches and openings necessary to install boring equipment, and the boring equipment used shall be of such a nature as to minimize the opening size required. The boring equipment shall produce a straight hole without unnecessary dips or bends. The bore hole shall be only slightly larger than the outside diameter of the conduits or cables to minimize possible settlement. Cables and conduits shall be pulled in with pulling eyes or using a kelly grip in a manner so as to guard against damage.
- E24.35.2 During construction as the drill bit crosses each existing facility a lookout shall be assigned by the Contractor to visually confirm the drill bit is maintaining a minimum 300 mm clearance from the existing facility all in accordance with Manitoba Hydro Safe Excavation and Safety Watch Guidelines (latest revision) included as Appendix 'C'. Maximum pulling tensions on any streetlight cable shall be limited to 2.9 kN/0.65 kips.
- E24.35.3 Drilling fluids and associated waste materials shall be disposed of in a manner that minimizes environmental effects.
- E24.35.4 The Contractor shall properly compact the backfill material and will be responsible for placing additional material should settlement occur for the duration of the warranty period.

E24.36 BURIED UTILITY CROSSINGS

- E24.36.1 All buried obstructions are not necessarily shown on the reference drawings and the locations of those indicated are approximate only.
- E24.36.2 The Contractor shall determine the location of all buried obstructions and shall notify the appropriate authorities and obtain all necessary permits prior to excavation, trenching and directional drilling near or across such obstructions. All buried obstructions where the new buried cable route crosses other utilities including but not limited to gas, water, sewer, telephone and electric lines shall be exposed as per each utilities guidelines by the Contractor, including the use of Pressurized Water/Vacuum Equipment (PW/VE) where necessary. Should any damage occur to such lines during the course of the work, the Contractor shall be responsible for the damage and the costs of repairs to buried obstructions caused by its operations and shall fully indemnify the City of Winnipeg and Manitoba Hydro from and against all claims arising out of such damage. Manitoba Hydro Safe Excavation and Safety Watch Guidelines (latest revision) included as Appendix 'C' shall be followed when crossing natural gas pipelines and electrical cables by the directional boring method.

E24.36.3 The PW/VE technique, used to expose underground plant in certain conditions, must be performed in accordance with each utility's requirements, including but not limited to Manitoba Hydro, Manitoba Telecom Services, Shaw Cable, etc. PW/VE costs that the Contractor will incur during the work must be factored into the Contractor's bid prices. The Contractor shall not be entitled to extra compensation for the use of PW/VE on the work.

E24.36.4 The Contractor shall be responsible to supply all backfill material and carry out all backfill, compacting and leveling of all excavations so as to be ready for topsoil and seed or sod or as directed by Manitoba Hydro.

E24.37 BENDING CABLES/CONDUITS AND INSTALLATION INTO STANDARDS

E24.37.1 It is desired to reduce to a minimum the required number of bends and to lay the cables/conduits to conform to the contour of the ground and maintain a normal covering. This shall be accomplished by cutting the trench slightly deeper in approaches to road crossings and drainage ditches. It is intended that the Contractor shall eliminate unnecessary bending by operating the trenching machine at various depths rather than by finishing grading the trench by hand whenever practical.

E24.37.2 Sharp bends of the cables/conduits shall be avoided at all times. All bends shall meet the requirements set out in this Specification. If excessive bending was exerted on any cable, the cable shall be replaced at the Contractor's cost. During installation, under no circumstance is the cable to be subjected to a bending radius tighter than that detailed in the Standards. At street light poles the Contractor shall install the ends of the cables into the plastic pipe preinstalled in the concrete base. Care shall be taken to prevent damage to the insulation or jacket of the conductors. Underground cables entering the concrete base shall be protected by a length of protective hose supplied by the Contractor and by a layer of sand surrounding the cables to protect it from the limestone. The cable shall be left long enough to extend one (1) metre beyond the hand hole. The street light cable in the trench shall be installed in conduit for mechanical protection and the ends sealed with duct seal supplied by the Contractor. Care shall be taken to prevent damaging the cable where it exits the conduit. The conduit shall only be installed into the concrete base if conduit sizes make it practicable.

E24.37.3 Unless otherwise directed, excess underground cable and 2C-12 wire shall be left inside the hand hole with the hand hole cover loosely installed.

E24.38 BACKFILL

E24.38.1 All backfilling material within 300 mm of the cables/conduits shall be clean, free of sod, vegetation, organic material, stones or other debris, and of a consistency as to not create significant voids or air spaces around the cables/conduits. Other backfilling material shall be free of stones greater than 150 mm on their maximum dimension. Where cinders or very acid soil are encountered or where gravel or incompressible fill is required by Municipal authorities, ¼" down crushed limestone shall be placed all around the cables for a depth of at least 300 mm. The completed backfill shall be at least equal in compaction to undisturbed soil or as directed by Manitoba Hydro. Backfill material is to be placed and compacted in lifts not exceeding 300 mm. All excess material is to be removed by the Contractor.

E24.38.2 Tamping or flushing methods must be used where necessary to give the required compaction. Where tamping is used, hand tampers shall be used to at least 300 mm above the cable before machine tamping may be used. The Contractor shall level all excavations so as to be ready for topsoil and seed or sod or as directed by the Manitoba Hydro. Should settlement occur in the excavation and cause a depression in the surface, the Contractor shall repair the surface to the satisfaction of the Manitoba Hydro at the Contractor's cost.

E24.38.3 Excavations remaining where poles have been removed shall be backfilled with spoil, pit run gravel or ¾" down limestone and compacted in lifts of 150mm as directed by Manitoba Hydro. The top 300 mm of the excavation shall be backfilled with topsoil.

E24.38.4 Excavations remaining where utility crossings have been exposed shall be backfilled with sand or clean spoil and compacted in lifts of 150mm. The top 300 mm of the excavation shall be backfilled with topsoil.

E24.38.5 Backfill of all excavations shall be in accordance with City of Winnipeg Standard Construction Specification CW 2030 (latest revision), to the satisfaction of the authority having jurisdiction and Manitoba Hydro.

E24.39 DEFECTIVE WORK & WARRANTY

E24.39.1 If any portion of the work fails to comply with the requirements of this Specification, fails within the Warranty period, or if the final tests prove or indicate the existence of any fault or defect in the work, or any part thereof, Manitoba Hydro may forthwith re-execute or make good the faulty or defective work or alter the same to make it comply with requirements of the Specification at the Contractor's expense. Manitoba Hydro shall give the Contractor notice together with particulars of such failure, fault or defect, Manitoba Hydro's cost to re-execute or make good the faulty or defective work and the Cost shall be deducted from the Contract.

E24.39.2 At the completion of the work for each location, Manitoba Hydro shall prepare and issue a Network Commissioning Report, a sample of which is included as Appendix 'G', to the Contractor. The Network Commissioning Report shall be dated indicating the commencement of the Warranty period for the work performed at the location.

E24.40 AS-BUILT DRAWING

E24.40.1 The Contractor shall provide an as-built drawing or mark-up drawing to Manitoba Hydro which accurately displays the "as-built" location of the buried street light cables, conduits and street light poles.

E24.41 MEASUREMENT AND PAYMENT

E24.41.1 Removal of 25' to 35' street light pole and precast, poured in place concrete, steel power installed base or direct buried including davit arm, luminaire and appurtenances

- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Removal of 25' to 35' street light pole and precast, poured in place concrete, steel power installed base or direct buried including davit arm, luminaire and appurtenances". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including removal of the pole, base, luminaire, appurtenances, use of pressurized water/vacuum excavation, transportation of Reclaim, Surplus and Scrap material, payment of associated disposal fees and all other items incidental to the work included in the Specification.

E24.41.2 Removal of 45' street light pole and precast, poured in place concrete, steel power installed base or direct buried including davit arm, luminaire and appurtenances

- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Removal of 45' street light pole and precast, poured in place concrete, steel power installed base or direct buried including davit arm, luminaire and appurtenances". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including removal of the pole, base, luminaire, appurtenances, use of pressurized water/vacuum excavation, transportation of Reclaim, Surplus and Scrap material, payment of associated disposal fees and all other items incidental to the work included in the Specification.

E24.41.3 Installation of Conduit and #4 AL C/N or 1/0 AL Triplex Streetlight Cable in Conduit by Open Trench Method

- (a) This pay item will be measured on a linear metre basis and paid for at the Contract Unit Price per linear metre for "Installation of Conduit and #4 AL C/N or 1/0 AL Triplex streetlight cable in Conduit by open trench method." The number of meters to be paid for at the Contract Unit Price shall be measured and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including installation of the conduit, pulling cable into the conduit, backfilling the trench, buried utility crossings, use of pressurized water/vacuum excavation and all other items incidental to the work included in the Specification.
- E24.41.4 Installation of 50 mm Conduit by Boring Method complete with Cable Insertion (#4 AL C/N or 1/0 AL Triplex)
- (a) This pay item will be measured on a linear metre basis and paid for at the Contract Unit Price per linear metre for "Installation of 50 mm conduit or conduits by boring method complete with cable insertion (#4 AL C/N or 1/0 AL Triplex)." The number of meters to be paid for at the Contract Unit Price shall be measured and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including installation of 50mm conduit or conduits by boring method, inserting the #4 AL C/N or 1/0 AL Triplex streetlight cable into the conduit(s), buried utility crossings, use of pressurized water/vacuum excavation and all other items incidental to the work included in the Specification.
- E24.41.5 Installation of cable (#4 AL C/N or 1/0 AL Triplex) by boring method.
- (a) This pay item will be measured on a linear metre basis and paid for at the Contract Unit Price per linear metre for "Installation of cable(s) (#4 AL C/N or 1/0 AL Triplex) by boring method." The number of meters to be paid for at the Contract Unit Price shall be measured and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including installation of the cable or cables by boring method, buried utility crossings, use of pressurized water/vacuum excavation and all other items incidental to the work included in the Specification.
- E24.41.6 Installation of 25'/35' Pole, Davit Arm and Precast Concrete Base Including Luminaire and Appurtenances
- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Installation of 25'/35' pole, davit arm and precast concrete base including luminaire and appurtenances." The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including installation of the pole, davit arm, base, luminaire, appurtenances, placing the cable(s) into the base, use of pressurized water/vacuum excavation and all other items incidental to the work included in the Specification.
- E24.41.7 Installation of 45' Pole, Davit Arm and Precast Concrete Base Including Luminaire and Appurtenances
- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Installation of 45' pole, davit arm and precast concrete base including luminaire and appurtenances." The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including installation of the pole, davit arm, base, luminaire, appurtenances, placing the cable(s) into the base, use of pressurized water/vacuum excavation and all other items incidental to the work included in the Specification.
- E24.41.8 Installation of One (1) 10' Ground Rod at Every Third Street Light, at the End of a Street Light Circuit or Anywhere Else as Shown on the Design Drawings. Trench #4 Ground Wire

up to 1 m From Rod Location to New Street Light and Connect (Hammerlock) to Top of Ground Rod

- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Installation of one (1) 10' ground rod at every third street light, at the end of a street light circuit or anywhere else as shown on the design drawings. Trench #4 ground wire up to 1 m from rod location to new street light and connect (hammerlock) to top of the ground rod." The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including install one (1) 10' ground rod, trench the #4 ground wire to the new streetlight pole, connect (hammerlock) ground wire to rod and all other items incidental to the work included in the Specification.

E24.41.9 Installation of Lower 3 m of Cable Guard, Ground Lug, Cable Up Pole, and First 3 M Section of Ground Rod Per Standard CD 315-5

- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Install/lower 3 m of Cable Guard, ground lug, cable up pole, and first 3 m section of ground rod per Standard CD 315-5". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including installing the lower section of cable guard, ground lug, ground rod, coiling cable(s) up the pole and all other items incidental to the work included in the Specification.

E24.41.10 Installation and Connection of Externally-Mounted Relay and PEC Per Standards CD 315-12 and CD 315-13

- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Installation and connection of externally-mounted relay and PEC per Standards CD 315-12 and CD 315-13". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including mounting the relay, PEC, wiring as per the schematic and all other items incidental to the work included in the Specification.

E24.41.11 Termination of 2/C #12 Copper Conductor to Street Light Cables Per Standard CD310-4, CD310-9 or CD310-10

- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Terminate 2/C #12 copper conductor to street light cables per Standard CD310-4, CD310-9 or CD310-10". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including connection of the 2/C # 12 copper conductor to the #4 C/N or 1/0 Al Triplex cable(s) using a GELCAP-SL-2/0 splice kit and all other items incidental to the work included in the Specification.

E24.41.12 Splicing #4 AL C/N or 2 Single Conductor Street Light Cables

- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Splicing #4 Al C/N or 2 single conductor street light cables". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including splicing the #4 AL C/N or 2 single conductor cables in accordance with Standard CD 215-12 and CD 215-13 and all other items incidental to the work included in the Specification.

E24.41.13 Splicing 1/0 AL Triplex Cable or 3 Single Conductor Street Light Cables

- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Splicing 1/0 AL triplex cable or 3 single conductor street light cables". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including splicing the 1/0 Al triplex cable or set of 3 single conductor cables in accordance with Standard CD 215-12 and CD 215-13 and all other items incidental to the work included in the Specification.
- E24.41.14 Installation of Break-Away Base and Reaction Plate on Base-Mounted Poles up to 35'
- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Installation of break-away base and reaction plate on base mounted poles up to 35'". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including installation of the reaction plate, break-away base and all other items incidental to the work included in the Specification.
- E24.41.15 Installation of Overhead Span of #4 Duplex Between New or Existing Streetlight Poles and Connect Luminaire to Provide Temporary Overhead Feed
- (a) This pay item will be measured on per span basis and paid for at the Contract Unit Price per span for "Installation of Overhead Span of #4 duplex Between New or Existing Streetlight Poles and Connect Luminaire to Provide Temporary Overhead Feed". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including attachment of the #4 duplex overhead conductor using a perform grip (c/w spool insulator(s) to davit arm if necessary), sagging conductor, connection of luminaire using 2C#12 copper conductor and all other items incidental to the work included in the Specification.
- E24.41.16 Removal of Overhead Span of #4 Duplex Between New or Existing Streetlight Poles to Remove Temporary Overhead Feed
- (a) This pay item will be measured on a per span basis and paid for at the Contract Unit Price per span for "Removal of Overhead Span of #4 duplex Between New or Existing Streetlight Poles to Remove Temporary Overhead Feed". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by the Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including removal of the #4 duplex overhead conductor, spool insulator(s) and all other items incidental to the work included in the Specification.
- E24.41.17 Expose Underground Cable Entrance of Existing Streetlight Pole and Install New Streetlight Cable(s).
- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Expose Underground Cable Entrance of Existing Streetlight Pole and Install New Streetlight Cable(s)". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including excavation and exposure of the underground cable entrance by any means necessary including use of pressurized water/vacuum excavation, installation of the new streetlight cables(s), backfill, compaction and all other items incidental to the work included in the Specification.

E25. WORKING AROUND TERASPAN FIBRE OPTIC LINES

- E25.1 The Contractor is not responsible to protect or restore any Teraspan fibre optic lines that must be removed during normal construction practices.

E25.2 The Contractor shall not remove any portion of a Teraspan fibre optic line before receiving written approval from the Contract Administrator.

E26. SITE REQUIREMENTS FOR ACCESSIBILITY

E26.1 The Contractor shall provide the Contract Administrator with an Accessibility Plan at least five (5) Business Days prior to the commencement of any Work on the Site but in no event later than the date specified in C4.1 for the return of the executed Contract Documents, if applicable.

E26.2 The Accessibility Plan shall demonstrate how the Contractor will accommodate the safe passage of pedestrians and cyclists in accordance with the Manual of Temporary Traffic Control, the Contract Drawings, Staging Plans, and Streets By-Law No. 1481/77 at all times for the duration of the Construction. Unless noted in the Contract, the Accessibility Plan must include a written plan for the following:

- (a) How the Contractor will maintain at least one crossing in each direction for each intersection (one north/south crosswalk and one east/west crosswalk).
- (b) How the Contractor will maintain access to bus stops within the site.
- (c) How the Contractor will maintain access to pedestrian corridors and half signals.
- (d) How the Contractor will maintain cycling facilities.
- (e) How the Contractor will maintain access to residents and businesses unless otherwise noted in the Contract.
- (f) Any required detour signage at adjacent crossings to facilitate sidewalk or active transportation pathway closures.

E26.3 The Accessibility Plan may also include figures, sketches, or drawings to demonstrate the proposed plan.

E26.4 The Accessibility Plan shall include written details on how the Contractor intends to review, maintain, and document all items related to the Accessibility Plan on-site during Construction, including, but not limited to:

- (a) Signage
- (b) Temporary Ramping
- (c) Transit Stops
- (d) Detour Signage

E26.5 At minimum, the Contractor shall review the site conditions on a daily basis to ensure the all features related to the Accessibility Plan are in place. The site review is intended to correct deficiencies as a result of unforeseen events such as wind, traffic, or the general public. Deficiencies that are direct result of the Contractors actions must be corrected immediately.

E26.6 Any changes to the Accessibility Plan must be submitted to the Contract Administrator a minimum of 5 Working Days prior to the required change for approval.

E26.7 Upon request from the Contract Administrator, the Contractor shall provide records demonstrating that the site has been maintained.

E26.8 Failure to produce records that demonstrate that the site was maintained in compliance with the Accessibility Plan or deficiencies as a direct result of actions by the Contractor that are not immediately corrected may result in a pay adjustment. The rate of pay adjustment will be as per the following schedule:

- (a) First Offence – A warning will be issued and documented in the weekly site meeting.
- (b) Second Offence - A field instruction to immediately correct the site will be issued by the Contract Administrator.

- (c) Third and subsequent Offences – A pay reduction will be issued in the amount of \$250.00 per instance, per day.

APPENDIX 'A'

GEOTECHNICAL REPORT