

GRAPHIC LEGEND

- Parapet
- Gravel stop
- Gas line
- Control joint
- Expansion joint
- New insulated drain pipe
- Photo vantage point
- Area Label
area
no. of stories


☒ = attic vent X = leak

KEYNOTE LEGEND

- 1 core sample
- 2 chimney
- 3 AC unit
- 4 vent hood
- 5 ventilator
- 6 vent pipe
- 7 roof drain
- 8 skylight
- 9 eavestrough
- 10 firewall
- 11 antenna
- 12 ladder
- 13 stub column
- 14 roof hatch
- 15 scupper
- 16 pitch box
- 17 HVAC unit
- 18 capped curb
- 19 flag pole
- 20 electrical mast
- 21 cooling tower
- 22 splash pad
- 23 splash pan
- 24 downspout/rainwater leader
- 25 back slope
- 26 cant
- 27 increase slope to drain
- 28 cricket
- 29 parapet/wide flashing
- 30 life line anchor

Notes:
 .01 Contractor is responsible for site verifications of all dimensions
 .02 Drawings are not to be scaled for estimating purposes
 .03 All areas given are approximate
 .04 Contractor is responsible for site verification of existing roof constructions
 Stated scale is when in 11x17 format

- A1 Existing
 felt vapor barrier
 3" extruded polystyrene insulation
 1/2" fiberboard
 4 ply felt and asphalt
 gravel



Overflow drains are to be set at an elevation approximately 2" above the main drain elevation. Plumbing contractor must confirm all drain location prior to sloped insulation drawings being approved.


- 8"-0" x 16' either side of valley
- 6"-0" x 12' either side of valley
- 4"-0" x 8' either side of valley

C1, D1, E1 & F1 Construction (2020)
 (not included in 2022 scope)
 existing deck
 5/8" DensDeck
 Soprema Sopralene 180 s/p VB
 sloped type 2 EPS min 2"
 (slopes as indicated)
 2" polyisocyanurate
 3/8" Securock
 Soprema Sopralene Flam 180 Base
 Soprema Sopralene Traffic Cap

A1, B1, G1 & A2 Construction (2022)
 existing deck
 5/8" DensDeck
 SBS Vapor Barrier as specified
 2" sloped type 2 EPS min 2"
 2" polyisocyanurate
 3/8" Securock
 SBS base sheet as specified
 SBS cap sheet as specified

Approx. Area sq.m.

A1	= 767
A2	= 25
B1	= 12
C1	= 113
D1	= 262
E1	= 122
F1	= 265
G1	= 183
Total	= 1749



AGG
 Agassiz Consulting Group Ltd.
 Box 41, Warren, Manitoba R0C 3E0
 Office Phone: (204) 383-5538

Project: **WRHA Clinic**
 601 Aikins
 Winnipeg, MB

Date: February 22, 2022

Drawing No. **R-1**

File no: **4301-22** Scale: **1:200**