



## 453-2022 ADDENDUM 1

### 2023 REDWOOD AVENUE RECONSTRUCTION: SALTER STREET TO MAIN STREET

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL**

ISSUED: December 12, 2022  
BY: Craig Rowbotham  
TELEPHONE NO. 204 318-2051

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **FORM B: PRICES**

Replace: 453-2022 Form B: Prices with 453-2022 Addendum 1 - Form B: Prices. The following is a summary of changes incorporated in the replacement Bid/Proposal Submission:

Form B(R1): Add Item A24 v).

Page numbering on some forms may be changed as a result.

#### **PART D – SUPPLEMENTAL CONDITIONS**

Revise: D29.5 to read:

D29.5 The Fuel Factor (FF) rates will be set as follows:

- (a) The Fuel Factor rate shall be set at 2.7% of the monetary value for Section A identified on Form B: Prices related to Surface Works.
- (b) The Fuel Factor rate will be set at 1.2% of the monetary value for Section B identified on Form B: Prices related to Water and Waste Works.
- (c) The Fuel Factor will not apply to the following sections identified on Form B: Prices related to:
  - (a) Section C: Street Light Renewal Works;
  - (b) Section D: Mobilization/Demobilization.

Page numbering on some forms may be changed as a result.

## **PART E – SPECIFICATIONS**

Revise: E19.1 b) to read:

- (b) In addition, the Contractor shall refer to Appendix G and note the requirements for locating all gas mains within the site and determining depth of cover prior to starting the Work, specifically:
- (i) Absolutely no Work, including concrete cutting or pavement breaking, may occur over a natural gas pipeline (regardless of size) until depth of cover is determined by the Contractor by soft-dig methods.
  - (ii) Select shallow pavement removal shall be permitted only for the purpose of providing access for soft-digging to determine depth of cover.
  - (iii) Provide the station, offset, and depth of cover from existing ground to the Contract Administrator in tabular form.

## **APPENDICES**

Add: Appendix G                      Manitoba Hydro Gas Review

## **QUESTIONS AND ANSWERS**

Q1:            Can concrete pipe be used as an alternative product for the SDR26 PVC pipes and fittings?

A1:    Yes, concrete pipes and fittings can be used as an alternate product for the SDR 26 PVC pipe and fittings, only if the pipes are suitable for trenchless installation and both pipes and fittings are rated as a Class V Concrete Products.

Related Form B pay items:

- B.12. iii)
- B.13 i) and ii).