



533-2022 ADDENDUM 1

CENTRAL WASHROOM AND CHANGE ROOM UPGRADES – 2546 MCPHILLIPS STREET

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: August 23, 2022
BY: Jason Wiebe
TELEPHONE NO. 204 770-0245

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

DRAWINGS

Replace: 533-2022_Drawing_2021085MV0M1-R0 with 533-2022_Drawing_2021085MV0M1-R1

QUESTIONS AND ANSWERS

Q1: What color group is QT-1 Floor & Base?

A1: QT-1 floor and base should be Group 2 color group. Color to be confirmed on site.

Q2: Are the Cove Base fittings required behind lockers?

A2: No. The existing lockers must be flush with the wall and therefore will be affected by the coved tile base. Please delete the coved tile base from the walls behind all the lockers. However, QT-1 with coved base fittings should be installed wherever lockers are not to be located. Site confirm final layout of existing lockers. In Room Lockers 1-46A and Women's washroom 1-60A the west and south walls can receive QT-1 tile without a coved base fitting on the wall in between and either side of the lockers.

Q3: Build-Up Cove Base Fittings MB-5A & MB-5B are both listed on Finish Legend Drawing A4; which walls receive MB5-A & which walls receive MB5-B?

A3: All walls should receive MB-5B Profile. Delete any reference to MB-5A profile please.