



## 133-2023 ADDENDUM 2

### PROFESSIONAL CONSULTING SERVICES FOR PERIMETER ROAD PUMPING STATION REPLACEMENT AND ELECTRICAL UPGRADES

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: April 24, 2023  
BY: Brent Soloway  
TELEPHONE NO. (204) 451-4521

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20160708

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **PART D – SUPPLEMENTAL CONDITIONS**

Revise: D21.3 to read: The City intends to award this Contract by July 28, 2023.

#### **QUESTIONS AND ANSWERS**

- Q1: Please clarify the City's expectation regarding the scope of work requested in D3.4(h),
- A1: Assessment to determine if pump 1 and pump 2 discharge piping between the upstream and downstream isolation valves to determine if the piping is in poor condition and replace as required. Additional piping outside of the isolation valves is out of scope.
- Q2: What specific concerns does the City have with regards to the discharge piping (observed leaks, existing break-through's, age of piping etc.)?
- A2: No problems have been observed or are existing. Review is due to age and the tendency for the immediate discharge piping near the pumps to wear over time.
- Q3: What extent of the discharge piping is to be included in the review? (i.e. from pump discharge flange to force main connection; all pumps or just pumps 1 and 2?
- A3: Pump 1 and pump 2 discharge piping in the proximity of the pumps. This includes any piping between the upstream and downstream isolation valves on both pump 1 and pump 2.
- Q4: Would the City consider including an allowance for NDT to assess pipe wall thickness to be completed as part of the discharge piping review/condition assessment?
- A4: Assessment to determine if pump 1 and pump 2 discharge piping between the upstream and downstream isolation valves shall be considered in scope and the method(s) determined by the consultant. Additional piping and testing under the work allowance is not being planned for at this time.