

**APPENDIX B - TABLE E17.2 : SITE SPECIFIC MANHOLE CONDITIONS AND REPAIR REQUIREMENTS**

	<b>STREET_NAME</b>	<b>LOCATION_DETAILS</b>	<b>MANHOLE_ID</b>	<b>REPAIRS REQUIRED</b>
1	Rouge Rd	West Ave SPL	MH20002735	Replace top 0.15m precast conc risers below frame (750 diameter)
2	Rouge Rd	1st MH N or Erlandson Dr	MH20002868	Replace top 0.15m precast conc risers below frame (750 diameter)
3	Wellington Ave	MH at Strathcona	MH20009553	Replace top 0.5m precast conc risers below frame (750 diameter)
4	Macdonald Ave	1st MH W of Gomez St	MH20012244	Install Benching
5	Wolseley Ave	MH at Ruby St	MH20012514	Repair Benching
6	Wolseley Ave	MH at Lenore St	MH20012546	Replace top 0.9m precast conc risers below frame (750 diameter)
7	Westminster Ave	MH at Sherburn St	MH20013495	Replace top 0.25m precast conc risers below frame (750 diameter)
8	Portage Ave	MH at Banning St	MH20013692	Replace top 0.75m precast conc risers below frame (750 diameter)
9	Sargent Ave	MH at Simcoe St	MH20015729	Replace top 1.2m precast conc risers below frame (750 diameter)
10	Ingersoll St	MH at Grundy	MH20015894	Repair benching
11	Arlington St	MH at Wellington Ave	MH20016092	Repair Benching
12	Home St	2nd MH N of Wellington Ave	MH20016134	Repair Benching
13	Maude St	1st MH S of Henry Ave	MH20017678	Repair Benching
14	Easement	1st MH N of Logan	MH70004926	Repair Benching