


- NOTES:**
- ALL CABLES ARE CAT-6, SHIELDED ETHERNET CABLES UNLESS OTHERWISE NOTED.
  - GREYED OUT ITEMS INDICATE EXISTING EQUIPMENT OR DEVICES.

- CONTRACTOR NOTES:**
- CONTRACTOR SCOPE IS LIMITED TO THE FOLLOWING:
    - PROVIDE CAT-6 COMMUNICATION CABLES BETWEEN NETWORK SWITCHES AND PLC PANEL.
    - PROVIDE AND INSTALL CAT-6 COMMUNICATION CABLES IN SEPARATE CONDUITS TO PROVIDE REDUNDANCY PATH FOR EACH CABLE

REF. NO.	DRAWING TITLE	DRAWING NUMBER	NO.	REVISIONS	DATE	DESIGN	CHECK
3	POWER DISTRIBUTION SCHEMATIC PRIMARY CLARIFIER CONTROL PANEL CP-P8001	1-0101-AWDG-P001-001 1-0101-AWDG-P001-002					
2	PRIMARY CLARIFIER PANEL LAYOUT DIAGRAM	1-0101-ACBD-P101-001					
1	PRIMARY CLARIFIER AREA CONTROL ROOM	1-0101-AGAD-P001-001	1	ISSUED FOR GC TENDER	2024-01-08	KG	SDS
0			0	ISSUED FOR TENDER	2023-03-17	KG	SDS
REFERENCE DRAWING			NO.	REVISIONS	DATE	DESIGN	CHECK

<b>AECOM</b>		DESIGNED BY:	KG	CHECKED BY:	SDS
		DRAWN BY:	RC	APPROVED BY:	SB
SCALE:		NTS		RELEASED FOR CONSTRUCTION BY:	
DATE:		2024-01-08		DATE:	
CONSULTANT NO.:					



**ENGINEERS GEOSCIENTISTS MANITOBA**  
Certificate of Authorization  
AECOM Canada Ltd.  
No. 4671 Date: 2023/12/08

**THE CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT

NORTH END SEWAGE TREATMENT PLANT  
DCS MIGRATION  
NETWORK DIAGRAM  
PRIMARY CLARIFIERS PLC DEVICE NETWORK

CITY DRAWING NUMBER: **1-0101-ANET-P101** SHEET: **001** REV: **0A** SIZE: **A1**