



## 24-2024 ADDENDUM 1

### NORTHWOOD COMMUNITY CENTRE PLAYGROUND AND BASKETBALL COURT

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL**

ISSUED: March 14, 2024  
BY: Ian Macdonald  
TELEPHONE NO. 204 451-3069

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **PART E – SPECIFICATIONS**

Revise: E14.1 (e) (v) to read: In the presence of the Contract Administrator **and acrylic sport court installer**, the Contractor shall flood the asphalt court surface with water and mark out any depression deeper than 2mm. Prior to applying sport court surfacing, ensure that there are no depressions deeper than 2mm as per **E16.3(d)**.