

Derek Clarke, Drinking Water Officer Office of Drinking Water, Manitoba Sustainable Development Box 6000 Gimli, MB R0C 1B0

Re: Corrective Action Report For Winnipeg Public Water System, 252.00

Incident No: CAR_09-2019

Reported to ODW: January 6, 2020

Reported by: Nancy Crawford, Compliance Reporting Branch Head

Approved by: Nancy Crawford, Compliance Reporting Branch Head

Incident Date: December 8 - 14, 2019

Incident Location: Winnipeg 2-Treated (WTP)

Incident Type: Water Quality Monitoring (PWS-09-412-01 Clause 5.1)

Did not obtain three confirmatory grab samples of effluent from Filter 8. The filter was offline for maintenance from December 8 at 17:30 to December 12 at 21:55, grab samples were obtained on December 13 and 14.

Description of Corrective Actions:

<u>Environmental Standards and Water Services</u>: Reviewed monitoring requirements with staff and updated maintenance procedures to include obtaining a grab sample prior to and immediately following maintenance activities.

Test Results: See attached

LIMS Reference No: 265045 and 265201

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports

February 5, 2020



Water and Waste Department • Service des eaux et des déchets

Sample Name	Date Sampled	Sample Number	Analyzer Turbidity (NTU)	Grab Turbidity (NTU)	Time Sampled (hrs)
WTP - Filter 8	Sunday, December 8, 2019	N/S	N/S	N/S	N/A
WTP - Filter 8	Monday, December 9, 2019	263878	O/L	N/S	N/A
WTP - Filter 8	Tuesday, December 10, 2019	264171	O/L	N/S	N/A
WTP - Filter 8	Wednesday, December 11, 2019	264480	O/L	N/S	N/A
WTP - Filter 8	Thursday, December 12, 2019	264765	O/L	N/S	N/A
WTP - Filter 8	Friday, December 13, 2019	265045	0.03	0.09	9:24 AM
WTP - Filter 8	Saturday, December 14, 2019	265201	0.04	0.09	5:40 PM