

Derek Clarke, Drinking Water Officer Office of Drinking Water, Manitoba Sustainable Development Box 6000 Gimli, MB ROC 1B0 February 5, 2020

T. | Tél.: 204-986-4684

F. | Fax: 204-339-2147

winnipeg.ca/waterandwaste

RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00

Incident No: CAR-ESD-01-2020

Reported to ODW: January 16, 2020

Reported by: Courtney Diduck, Analytical Services Branch Head

**Approved by:** Brock Bradford, Acting Analytical Services Branch Head

Incident Date: January 15, 2020

**Incident Location:** Winnipeg 3-Dist (SE04)

**Incident Type:** 

1. Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

### **Description of Corrective Actions:**

#### **Environmental Standards:**

IMMEDIATELY: Contacted the ODW and re-sampled original location for bacteria, turbidity, free/total chlorine, and temperature. Monitoring was terminated after two consecutive sets of re-samples taken 24 hours apart tested negative for bacteria.

**Test Results:** See attached **LIMS Reference No:** 272032

# EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



# Water and Waste Department • Service des eaux et des déchets

Sample Name	Sample Number	Date Sampled	E Coli (MPNU/100mL)	Total Coliform (MPNU/100mL)	HPC (CFU/mL)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity-field (ntu)	Temperature (°C)	Time Sampled (hrs)
SE04	272032	15-Jan-20	<1	2	<1	0.86	1.19	0.17	4.1	15:21
SE04 (Resample)	273046	16-Jan-20	<1	<1	2	0.99	1.29	0.14	4.3	15:17
SE04 (Resample Duplicate)	273047	16-Jan-20	<1	<1	1	0.98	1.31	0.13	4.3	15:22
SE04 (Resample 2)	273048	17-Jan-20	<1	<1	<1	0.98	1.24	0.11	4.6	15:41
SE04 (Resample 2 Duplicate)	273049	17-Jan-20	<1	<1	3	1.07	1.24	0.12	4.6	15:45

## NOTES/COMMENTS:

- 1. All microbiological tests performed by contract laboratory.
- 2. N/R-No Result due to laboratory/analyst error.
- 3. N/A-Not Analyzed.