



Derek Clarke, Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
Box 6000
Gimli, MB R0C 1B0

August 12, 2020

RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00

Incident No: CAR-ESD-12-2020

Reported to ODW: July 30, 2020

Reported by: Brock Bradford, Analytical Services Branch Head (Acting)

Approved by: Heather Demchenko, Compliance Reporting Branch Head (Acting)

Incident Date: July 28, 2020

Incident Location: Winnipeg 3-Dist (SE05)

Incident Type: (choose all that apply)

1. Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

Description of Corrective Actions:

Environmental Standards:

IMMEDIATELY: Contacted the ODW and re-sampled original location for bacteria, turbidity, free/total chlorine, and temperature. Monitoring was concluded after two consecutive sets of re-samples taken 24 hours apart tested negative for bacteria.

Test Results: See attached

Reference No: 320812

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports

