



Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

October 7, 2022

RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00

Incident No: CAR-06-2022-ESD

Reported to ODW: October 7, 2022

Reported by: Nancy Crawford, Compliance Reporting Branch Head

Approved by: Courtney Diduck, Analytical Services Branch Head

Incident Date: September 25 – October 1, 2022

Incident Location: Winnipeg 2-Treated (WTP)

Incident Type: Water Quality Monitoring (PWS-09-412-02 Clause 5.1)

Description of Event:

Did not obtain four confirmatory grab samples of effluent from Filter 6 on a week containing a statutory holiday. The filter was taken offline for planned maintenance on September 28 at 7:00am, grab samples were obtained on September 25, 26, and 27, but not on September 28.

Corrective Actions:

Environmental Standards and Water Services: Reviewed monitoring requirements and maintenance procedures with staff to ensure that a grab sample is taken prior to and immediately following filter maintenance activities.

Test Results: See monthly reports

LIMS Reference No: N/A

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports