



Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

November 7, 2023

RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00

Incident No: CAR-16-2023-ESD

Reported to ODW: October 31, 2023

Reported by: Courtney Diduck, Analytical Services Branch Head

Approved by: Courtney Diduck, Analytical Services Branch Head

Incident Date: October 30, 2023

Incident Location: Winnipeg 3-Dist (SE12)

Incident Type: Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

Description and Corrective Actions:

Environmental Standards:

IMMEDIATELY: Contacted the ODW and re-sampled original location for bacteria, turbidity, free/total chlorine, and temperature. Monitoring was terminated after two consecutive sets of re-samples taken 24 hours apart tested negative for bacteria.

Test Results: See attached

Reference No: Job_1732

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Sample Name	Sample Number	Date Sampled	E Coli (MPNU/100mL)	Total Colliform (MPNU/100mL)	Heterotrophic Plate Count (CFU/mL)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity-field (ntu)	Temperature (°C)	Time Sampled (hrs)
SE12	614054	30-Oct-23	<1	1	NA	0.60	0.88	0.17	23.1	12:58
SE12_Resample 1	615467	31-Oct-23	<1	<1	<1	1.02	1.28	0.21	13.9	15:47
SE12_Resample 2	615468	1-Nov-23	<1	<1	NA	0.95	1.25	0.12	14.0	15:30

NOTES/COMMENTS:

1. All microbiological tests performed by contract laboratory.
2. OL - Autosampler or Process Offline
3. NA - Not Applicable