



Water and Waste Department • Service des eaux et des déchets
Environmental Standards Division • Division des Normes Environnementales

October 4, 2017

Our File: 040-18-18-14-00

Dr. Khalida Hai-Santiago c/o Helen Browne
300 Carlton Street (Room 4068)
Winnipeg, Manitoba
R3B 3M9

Dear Dr. Hai-Santiago:

RE: CITY OF WINNIPEG FLUORIDE MONITORING DATA

As a participant in the Provincial Water Fluoridation Program, the City of Winnipeg Water and Waste Department hereby submits the following fluoride monitoring data on analyses conducted by the Environmental Standards Division.

<u>LOCATION</u>	<u>SAMPLE NUMBER</u>	<u>DATE</u>	<u>RESULT (mg/L F)</u>
Distribution System (Composite – 39 Locations)	515411	04-Jul-17	0.48
	516218	10-Jul-17	0.53
	517025	17-Jul-17	0.71
	518005	24-Jul-17	0.73
	518762	31-Jul-17	0.75

Branch II fluoride was offline July 4 to 7 and Branch I fluoride was offline on July 7; this caused decreased fluoride levels in the distribution system.

If you have any questions on the foregoing, please call Ms. Nancy Crawford, Compliance Reporting Branch Head, at 204-986-4807.

Yours truly,

Original signed by:

Renée Grosselle
Manager of Environmental Standards

NC/HD

cc: Tim Shanks, P.Eng. Manager of Water Services (e-mail)