



Priesen Tokar Architects
 200 - 2033 Portage Avenue
 Winnipeg, Canada R3J 0K8
 Tel. 204.885.9223
 Fax. 204.831.7235

DRAWN BY: AA/BC
 CHECKED BY: CB
 DATE: APRIL 2004
 PROJECT NO.: 01716
 SHEET NO.: 01

1. ISSUED FOR 50% REVIEW
 FEBRUARY 6, 2004
 2. ISSUED FOR 75% REVIEW
 MARCH 5, 2004
 3. ISSUED FOR PRETENDER REVIEW
 APRIL, 2004
 4. ISSUED FOR TENDER
 MAY 14, 2004

R1-ADDENDUM 2: GENERAL
 REVISION

SMS ENGINEERING
 SMS Engineering Ltd. Consulting Engineers
 770 St. James Street West, Suite 1000
 Toronto, Ontario M5H 1K5
 Tel: 416-593-8888 Fax: 416-593-8889
 smseng.com

ORIGINAL
 CONTRACT DRAWING
 BONDED AND SEALED BY
 ANDY LOHSE, P.ENG.
 MAY 13, 2004

APEM
 Certificate of Authorization
 SMS Engineering Ltd.
 No. 909 Expiry: April 30, 2005

Drawings and specifications, as
 instruments of service are the
 property of the architect and
 copyright in the same being
 reserved. No reproduction
 may be made without the
 permission of the architect and
 where made, must bear his name.
 All rights are reserved for the
 architect.
 The contractor shall verify
 dimensions and data noted herein
 with conditions on the site and be
 held responsible for reporting any
 discrepancies to the architect for
 adjustment.
 This drawing shall not be used for
 building purposes until
 counterchecked by:

THE CITY OF
 WINNIPEG

OFFICE ADDITION AND RENOVATIONS
 1155 PACIFIC AVENUE
 WINNIPEG, MANITOBA

FRIESEN TOKAR ARCHITECTS

MAIN FLOOR PLAN
 PART B - LIGHTING
E2.4R1

PART MAIN FLOOR PLAN - PART B LIGHTING
 SCALE 1/80

- NOTES:
- HATCHED AREA SURROUNDING SKYLIGHTS INDICATES AREA THAT THE CEILING SYSTEM WILL BE REMOVED. ELECTRICAL TO REMOVE AND REINSTALL LIGHTING, FIRE ALARM, PUBLIC ADDRESS, ETC. AS REQUIRED. RELOCATE ANY CONDUIT/WIRING AS NECESSARY TO ACCOMMODATE NEW ROOF OPENING FOR SKYLIGHTS.
 - EXISTING CIRCUITS IN THIS AREA ARE:
 - EA-1 (EXIT SIGNALS)
 - L1-8 (NORMAL LIGHTING)
 - EA-15 (EMERGENCY LIGHTING)
 - OPEN AREA LIGHTING TO BE SWITCHED FROM HERE.
 - LIGHTING LEVEL SENSOR AND OCCUPANCY SENSOR MOUNTED ON CEILING. PROGRAMMED TO TURN OFF ADJACENT FLUORESCENT LIGHTS.
 - LIGHTING FIXTURES TO BE WIRED/CONTROLLED BY A LINE VOLTAGE DAY LIGHT SENSOR MOUNTED ON ADJACENT CEILING.
 - CIRCUITS L3-3 AND EA-6 ARE EXISTING LIGHTING CIRCUITS FOR THIS AREA.

FOR CONTINUATION, REFER TO DRAWING E2.5