



## **ADDENDUM NO. 1 to TENDER NO. 16-2004**

### **THE REPLACEMENT OF THE MONTCALM PUMPING STATION RIVERCROSSING BY HORIZONTAL DIRECTIONAL DRILLING**

ISSUED: JANUARY 23, 2004  
BUYER: Coleen Groening/clg  
TELEPHONE NO. (204) 986-2491

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
TENDER PACKAGE**

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE TENDER PACKAGE AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

v. 20031021

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender Package, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Tender may render your Tender Submission non-responsive.**

---

#### **PART D – SUPPLEMENTAL CONDITIONS**

Revise D12.1 to read:

D12.1 The Contractor shall achieve Substantial Performance by April 16, 2004

#### **PART E – SPECIFICATIONS**

E1.2 Replace Drawing 5356 and 5358 with the revised Drawings 05356-R1 and 05358-R1

Add

##### **E12 ELEVATION OF NEW FORCEMAINS**

E12.1 The Contractor shall be aware that the elevation of the new forcemain as shown on the drawings is a recommended elevation and that the final elevation of the pipe shall be determined by the Contractor and approved by the Contract Administrator and can be between elevation 195.00 and 208.00.

Replace Summary Logs 03-107-17 TH1, 03-107-17 TH2 and 03-107-17 TH3 with the following Summary Logs:

16-2004 Addendum 1 Summary Log 03-107-17 TH1.pdf  
16-2004 Addendum 1 Summary Log 03-107-17 TH2.pdf  
16-2004 Addendum 1 Summary Log 03-107-17 TH3.pdf  
16-2004 Addendum 1 Summary Log 03-107-17 TH4.pdf  
16-2004 Addendum 1 Summary Log 03-107-17 TH5.pdf  
16-2004 Addendum 1 Summary Log 03-107-17 TH6.pdf